



The COMSY - code for the Detecting of Piping Degradation due to Flow-accelerated Corrosion

André Zander

AREVA NP, Technical Center, Dept. NTCMM-G

Andre.Zander@AREVA.com / +49 9131 900 1999


Flow-induced material degradation - Contents

- ❑ *Introduction / Incidents in Power Plants*
- ❑ *Flow-induced material degradation mechanism*
- ❑ *Flow-accelerated corrosion*
(Characterization, Influence parameter, Combined effects, History)
- ❑ *COMSY program*
(Strategy, Screening and Detailed analysis)
- ❑ *Life Time Prediction Process*
(Overview, Boundary conditions, Prediction philosophy)
- ❑ *Inspection and examination record management*
- ❑ *COMSY Closed Loop Process*
- ❑ *Conclusions*
(Software modules, Characteristics)

Introduction

Incidents in power plants


caused by FAC



Flow-induced material degradation – Introduction (1)




**Pipe failures
due to FAC**



Flow-induced material degradation – Introduction (2)

Incidents in power plant piping caused by FAC



'YY plant name ⇒ occurrence year and PWR
'YY plant name ⇒ occurrence year and BWR
The above diagram shows PWR, but BWR data are also indicated at corresponding areas.

Flow-induced material degradation – Introduction (3)


Lines commonly affected by FAC attacks are:

- > Feedwater lines*
- > Condensate lines*
- > Extraction lines*
- > Discharge lines*
- > MS and reheater drainage lines*
- > Condensate drain lines and drain valves*
- > Cold crossover lines from HP-turbine to the reheater*
- > Connection lines and nozzles on the feedwater tank*
- > Blow-down lines*
- > etc.*

Areas suffering from FAC are difficult to locate, as FAC occurs only locally under specific conditions of flow, water chemistry, temperature and material behavior.


In most cases where failures occur, inspection programs have been established by ‘engineering judgment’

Flow-induced material degradation - Types, definitions, influencing parameters



Flow-accelerated corrosion - Characterization

*Horse shoe pits in
single phase flow*








*Tiger striping in
two-phase flows*



Flow Accelerated Corrosion is a chemical corrosion process which affects metals which owe their corrosion resistance to the formation of oxide layers. If the fluid at the oxide-water interface is moving, the oxide layer may be dissolved. The corresponding corrosion rate is strongly influenced by solubility of the oxide layer and the mass transfer imposed by the moving fluid.


Flow-accelerated corrosion - Influence Parameter

- > pH value and O₂ concentration of the water phase
- > Material (alloy content Cr, Mo & Cu)
- > Temperature
- > Flow velocity
- > Local turbulence, Flow profile, Pipe roughness






Flow-induced corrosion - Superposition of different flow-induced mechanisms

Enhancement of FAC by droplet impingement and cavitation effects



Flow-accelerated corrosion - History of FAC model development

Benson test facility




Ageing and Plant Life Management Strategy - Introduction

COMSY is a software tool for the aging and plant life management of mechanical components in power plants. The degradation analysis functions include lifetime prediction in respect to e.g. *flow accelerated corrosion (FAC), droplet impingement corrosion, cavitation corrosion, etc.*


This is accomplished by:

- ❑ *Focusing inspection activities on the **safety relevant** components with an existing **degradation potential***
- ❑ *Reduction of inspection effort for components with insignificant **safety relevance** and negligible **degradation potential***
- ❑ *Applying appropriate inspection techniques for the anticipated **degradation mechanism***



This task can be accomplished with a powerful software tool, specifically designed for plant life management in nuclear power plants.

- Strategy for ageing and plant life management (1)




The modeling is performed in three levels:

1. *Heat balance diagram*
Degradation potential screening, risk input
2. *P&ID diagram*
Degradation sensitivity assessment, detailed risk assessment
3. *Component data sheet*
Lifetime predictions, examination record management

The application of modeling levels flexibly depends on the necessity imposed by safety relevance and degradation potential

- Strategy for ageing and plant life management (2)




- > Screening process
Identification of susceptible systems, so resources can be focused on systems where ageing potential exists


- > Detailed analysis Modeling of relevant systems, lines and vessels:
 - > Prediction of minimum lifetime for plant elements
 - > Identification of degraded plant elements for inspection activities
 - > Evaluation of examination results
 - > Assessment on current ageing status
 - > Validation / update on lifetime prediction

- > Documentation of the as-is state of systems and components

Screening of the BoP for FAC




Plant-Wide Screening Analysis - Methodology for Identification of Degradation Sensitivity




AREVA NP has developed a *systematic screening procedure* reliably identifying system areas, which may be subject to degradation mechanisms like e.g. flow-accelerated corrosion.

- ✓ Modeling of the heat balance diagram
- ✓ Specification of system configuration
- ✓ Thermal-hydraulic parameters
- ✓ Water chemistry cycle calculation
- ✓ Specification of materials used in systems




Identification of FAC degradation potential

Plant-Wide Screening Analysis – BoP graphical functions



Plant-Wide Screening Analysis - Modeling of the BOP

Each system is represented by the connecting lines of two symbols



BOP Systemgrößen

Gruppe 1 Werte anzeigen

ID
Bezeichnung 15/01: FD von RDB
Referenz 15/001/01

Betriebsparameter

Temperatur	285,80	[°C]	<input checked="" type="checkbox"/>
Druck	69,970	bar	<input checked="" type="checkbox"/>
Dampfgehalt	0,99630		<input checked="" type="checkbox"/>
Enthalpie	2767,04	kJ/kg	<input checked="" type="checkbox"/>
Durchsatz	1981,30	kg/s	<input checked="" type="checkbox"/>

bearbeiten

Wasserchemie

total		Wasser	
pH Wert [°C]	7,00	7,00	<input type="checkbox"/>
O ₂ [ppb]	9000,00	55,17	<input checked="" type="checkbox"/>

bearbeiten

Werkstoff

X6CrNiMoTi17-12-2

bearbeiten Löschen

OK Linkbearbeiten abbrechen

15/01: FD von F

t [°C]	285,80
p [bar]	69,970
x	0,99630
h [kJ/kg]	2767,04
m [kg/s]	1981,30

Betriebsparameter

bis	Temperatur	Druck	Dampfgehalt	Durchsatz
1994,08	286,40	70,59	0,998	1698,86
1996,08	286,40	70,59	0,998	1698,86
NIA	285,80	69,97	0,996	1981,30

Durchsatz [kg/s] 1981,301
Temperatur [°C] 285,80
Druck [bar] 69,97
Dampfgehalt 0,9963
Enthalpie [kJ/kg] 2767,04


Wasserchemie Parameter Pool: BOP cycle tharony motor chemistry pool

bis	Sauerstoff [ppb]		pH at 25°C		[µM]		
	gesamt	wasser	gesamt	wasser	Leitfähigkeit	ammoniak	hydrazin
1992,06	2,627		8,737		0,000	0,121	0,011
1994,06	2,627		8,737		0,000	0,121	0,011
NIA	2,637		9,600		0,100	2,300	0,030

Erkennungstz Periode	agent	ppm	active
NIA	Ammoniak	2,300	X
	Morpholin	0,000	
	Cyclohexylamin	0,000	
	AMP	0,000	
	Boron	0,000	
	OIA	0,000	
	ETA	0,000	
	Hydrazin	0,030	X
		0,000	

Periode editieren schließen anwenden Periode löschen Periode


Start-up



1. Power uprate




2. Power uprate



For each modeled system the operating parameter will be generated.

Changing in water chemistry will be included.

Plant-Wide Screening Analysis – Water chemistry calculation




Water chemistry cycle calculation can be performed for a given injection rate of alkalizing agents and oxygen.

Plant-Wide Screening Analysis – Two-phase flow considerations


Volatility of water chemical substances

Two-phase flow influences water chemical parameters of the water film due to the distribution behavior of alkalizing agents and oxygen




Two-phase flow patterns


The flow pattern influences water/steam velocities and the local turbulence of the flow



Plant-Wide Screening Analysis – Using the Heat Balance Diagram



The results of the Water chemistry cycle calculation shows for which systems a FAC degradation potential regarding *thermal hydraulic conditions* and *water chemistry parameter* exist.




Plant-Wide Screening Analysis – Specify material data

This activity is supported by the material data catalog functionality

Each material included with the material table is specified for the related system

grade	semi-finished product	heat treatment	thickness min.	thickne
grade F 304 H	forgings	solution annealed	0	9999
grade F 347 H	forgings	solution annealed	0	9999
grade F 321 H	forgings	solution annealed	0	9999
grade F 321	forgings	solution annealed	0	9999
grade F 316	forgings	solution annealed	0	9999

Plant-Wide Screening Analysis – Lifetime prediction ranking



Select COMSY main menu function > Evaluate > lifetime prediction ranking evaluate data to generate the ranking table

Component Priority Ranking

HPPA1 / ...


	PADcode	element name	Rec-ISI	exams	factor	priority	phenomena	risk assessment
1	04 / 001 / 01 / 03	BOP cycle dummy element- St 35.8	1987,07		1,00	A1	'EC' DE	
2	04 / 001 / 01 / 01	BOP cycle dummy element- C 22.8 / 1.0460	1988,08		1,00	A1	'EC' DE	
3	04 / 001 / 01 / 04	BOP cycle dummy element- 15 Mo 3	1989,01		1,00	A1	'EC' DE	
4	04 / 001 / 01 / 02	BOP cycle dummy element- 13 CrMo 4 4	1993,06		1,00	A1	'EC' DE	
5	08 / 001 / 01 / 03	BOP cycle dummy element- St 35.8	2000,07		1,00	A1	'EC' DE	
6	03 / 001 / 01	BOP cycle dummy element- ST_ 35.8	2001,02		1,00	A1	'EC' DE	
7	08 / 001 / 01 / 01	BOP cycle dummy element- C 22.8	2001,02		1,00	A1	'EC' DE	
8	11 / 001 / 01 / 03	BOP cycle dummy element- C 22.8	2001,03		1,00	A1	'EC' DE	
9	11 / 001 / 01 / 01	BOP cycle dummy element- 15 Mo 3	2001,03		1,00	A1	'EC' DE	
10	08 / 001 / 01 / 04	BOP cycle dummy element- 15 Mo 3	2001,04		1,00	A1	'EC' DE	
11	01 / 001 / 01	BOP cycle dummy element- ST_ 35.8	2001,05		1,00	A1	'EC' DE	
12	11 / 001 / 01	BOP cycle dummy element- 13 CrMo 4 4	2003,03		1,00	A1	'EC' DE	
13	08 / 001 / 01 / 02	BOP cycle dummy element- 13 CrMo 4 4	2003,04		1,00	A1	'EC' DE	
14	02 / 001 / 01	BOP cycle dummy element- ST_ 35.8	2003,09		1,00	A2	'EC' DE	
15	16 / 001 / 01	BOP cycle dummy element- WSE 355	2005,11		1,00	A1	'EC' 'DE'	
16	05 / 001 / 01 / 01	BOP cycle dummy element- C 22.8	2006,07		1,00	B2	'EC' DE	
17	06 / 001 / 01 / 02	BOP cycle dummy element- St 37.4	2006,08		1,00	B2	'EC'	
18	06 / 001 / 01	BOP cycle dummy element- WSE 355	2006,12		1,00	B2	'EC'	
19	16 / 001 / 01 / 01	BOP cycle dummy element- 15 Mo 3	2007,02		1,00	A2	'EC' 'DE'	
20	06 / 001 / 01 / 01	BOP cycle dummy element- C 22.8	2008,08		1,00	C2	EC	
21	09 / 001 / 01	BOP cycle dummy element- 10CrMo9-10 (10 CrMo 9 10)	2010,07		1,00			
22	09 / 001 / 01 / 02	BOP cycle dummy element- 13 CrMo 4 4	2011,01		1,00			
23	09 / 001 / 01 / 04	BOP cycle dummy element- 15 Mo 3	2013,06		1,00			
24	05 / 001 / 01	BOP cycle dummy element- 10CrMo9-10 (10 CrMo 9 10)	2013,11		1,00		DE	
25	09 / 001 / 01 / 01	BOP cycle dummy element- C 22.8	2016,12		1,00			
26	09 / 001 / 01 / 03	BOP cycle dummy element- St 35.8	2018,10		1,00			
27	04 / 001 / 01	BOP cycle dummy element- 10CrMo9-10 (10 CrMo 9 10)	2018,12		1,00		EC DE	
28	07 / 001 / 01	BOP cycle dummy element- ST_ 35.8	2019,05		1,00		EC	

rough analysis
 disregard rough analysis


The ranking table serves to rank system risk potential for each system element considered.

Use export function to generate EXCEL table holding data displayed

Plant-Wide Screening Analysis – Benefit




The rough analysis results indicate which systems have a limited service life based on the operating parameters and the materials used.




As indicated by the rough analysis for a typical PWR, some 77% of the systems are definitively not at risk due to relevant degradation and need not to be examined in the future.

Detailed analysis



Detailed analysis - Modeling of relevant systems, lines and vessels



- > *Element geometry*
- > *Design criteria*
- > *Material specification*
- > *Thermal-hydraulic operation*
- > *Water chemical properties*
- > *Mechanical loads*
- > *Material certificate values, if available*

The modeling process is efficiently supported by useful engineering tools and a detailed material data library

Detailed analysis - Managing piping and vessel data

The screenshot displays the COMSY v2.06.8 NPPA2 software interface. The main window is titled "Plant data addressing" and shows a hierarchical tree of segments and sections. The "element / sub-element" list on the right includes items like "01: Outlet feedwater heater SEA2 -> S1", "02: Reducer 400 X 350 from SEA2 outlet /S1-W2", and "07: T-fitting 350 X 50 to 463 L71 / W6 - S7".

An "Element data sheet" window is open for element 07, showing the following data:

segment	08	Feed water heater drainage	UID=1050	RecISI	2012,01
section	003	Drainage line SH46Z39 / SEA2 to SEA1		priority	B1
element	07	T-fitting 350 X 50 to 463 L71 / W6 - S7		calibration factor	0,85
drawing		R51-6555/X-3-1334091 / DOC 463-L39 1/1		SchedSI	

The "Element Data" tab is active, showing geometry details for a T-fitting:

Parameter	Value
geometry code	TDCOLE+0,00
geometry factor	0,300
comment	BRANCH DN 50
diameter [mm]	355,6
DN	14.0"
X-section [m2]	0,0852191
Tnom [mm]	12,50
Torig [mm]	13,10
Tmin [mm]	5,30
allowance A [mm]	0,00
length [mm]	422,0
ovality [%]	3,00
diameter branch [mm]	355,6
position	HORI
l branch[mm]	240,0
reinforce. sA [mm]	12,7
T branch[mm]	8,0
angle rotation [°]	0,0
r pipe [mm]	3,0
r branch[mm]	10,0
l to branch[mm]	211,0

On the right, a technical drawing shows the cross-section of the T-fitting with dimensions: outer diameter $\varnothing 355.6$, inner diameter $\varnothing 339.6$, branch diameter $\varnothing 211$, and total length 422 mm. The X, Y, and Z coordinates are -8,655365, 0, and 422 respectively.

For each element modeled, the program generates an individual element data form.

Detailed analysis – Component data sheet

Element data sheet 08/003/07

segment	08	Feed water heater drainage	UID=1050	RecISI	2012,01	pheno	prio	type	RecISI	rel
section	003	Drainage line SH46Z39 / SEA2 to SEA1		priority	B1	FG	B1	FGcycl	2006,11	Ncycle =
element	07	T-fitting 350 X 50 to 463 L71 / W6 - S7		calibration factor	0,88	FIC			2012,01	Wf=0,3
drawing		R51-6555/X-3-1334091 / DOC 463-L39 1/1		SchedISI		EAC				Lf = 0
						LO				Lf = 0

Element Data | **Geometry** | Material+Design | Operation Data | Water Chemistry | Weld Joint | Inspection Data

geometry code: TDCOLE+0,00 | geometry factor: 0,300

comment: BRANCH DN 50

diameter [mm]: 355,6 | DN: 14.0" | X-section [m2]: 0,0852191

Tnom [mm]: 12,50 | Torig [mm]: 13,10

Tmin [mm]: 5,30 | allowance A [mm]: 0,00

length [mm]: 422,0 | ovality [%]: 3,00

diameter branch [mm]: 355,6 | position: HORI

l branch [mm]: 240,0 | reinforce. sA [mm]: 12,7

T branch [mm]: 8,0 | angle rotation [°]: 0,0

r pipe [mm]: 3,0 | r branch [mm]: 10,0

l to branch [mm]: 211,0

X coord. -8,655365 | Y coord. 0 | Z coord. 422


previous element | next element | new support | documentation | calculate EAC | wear rate diagram

new element | create sub-element | create link | section diagram | EAC/fatigue chart | calculate | close


The component data sheet summarizes data on relevant degradation mechanisms, component design, operating conditions, water chemistry and materials applied.

Additional information are supplemented, e.g. examination records, load cycle or specific documents

Life Time Prediction Process





Life Time Prediction Process - Overview



COMSY uses sophisticated corrosion models to conservatively predict the progress of material degradation for e.g. flow-accelerated corrosion and to determine the life expectancy for individual elements.

Life Time Prediction Process - Boundary Conditions




The evaluation of the flow-accelerated corrosion lifetime considers the influence of local turbulences in a continuous piping section.

The profile illustrates the effect of, e.g. high local turbulence on the computed wall thinning.

Life Time Prediction Process - Prediction philosophy for wall thinning rates

- > *Uncertainties on wall thinning computation are considered via a safety margin in order to ensure safe operation*
- > *The computed wear is considered the maximum probable wall thinning rate for element under specified operating conditions. The result indicates the minimum life expectancy of the element*
- > *The safety margin is reduced after measurement results are made available*




Prediction of Residual Lifetime for Plant Elements e.g. FAC / EC (erosion corrosion)



Component Priority Ranking

Feed water heater drainage / Drainage line SEA229 / SEA2 to SEA1 / ...



ID	PADcode	element name	Rectif. exams. factor	priority	phenomena	risk assessment
1	00 / 003 / 17	HEATER inlet EA1	1551,05	0,57	EC	
2	00 / 003 / 16	Expander CTRL valve VA751.1 /->S18	1551,05	0,57	EC	
3	00 / 003 / 05	Elbow 90° / W4 - W5	1557,01	0,57	EC	
4	00 / 003 / 06	Pipe from elbow to T-fitting / W5 - W6	1557,01	0,57	EC	
5	00 / 003 / 08	Elbow after T-fitting / S7 - W8	1559,06	0,57	EC	
6	00 / 003 / 11	Pipe to SEA21 SUPPORT L38-46 / S12-S13	1559,06	0,57	EC	
7	00 / 003 / 12	Elbow 45° / W11 - S12	1559,06	0,57	EC	
8	00 / 003 / 11	Elbow 90° / S9 - W10	1559,06	0,57	EC	
9	00 / 003 / 07	T-fitting 259 X 56 to 403 L78 / W6 - S7	1559,06	0,57	EC	
10	00 / 003 / 14	Reducer COHER Valve VA751.1 / S13->	2466,02	0,57	EC	
11	00 / 003 / 10	Pipe with nozzle to elbow / W9 - S10	2466,02	0,57	EC	
12	00 / 003 / 01	Outlet feedwater heater SEA2 /-> S1	2467,05	0,57	EC	
13	00 / 003 / 03	Pipe from reducer to nozzle / W2 - W3	2468,03	1	B2	
14	00 / 003 / 04	Pipe from nozzle to elbow / W3 - W4	2468,03	2	B2	
15	00 / 003 / 15	POWER Control valve VA751.1 0"X 8"	2476,09	0,57	EC	
16	00 / 003 / 09	Pipe after elbow support L39-43 / W6-W8	2475,02	0,57	EC	
17	00 / 003 / 02	Reducer 406 X 359 from SEA2 outlet S1-W2	2476,11	1	B2	



After the modeling process is completed, a **lifetime prediction** can be initiated.




The diagram indicates **predicted wall thinning rates** caused by flow accelerated corrosion which are plotted versus the length of a line.



A lifetime chart demonstrates the **predicted progress of wall thinning** versus the operating time of the plant.

Inspection and examination record management




After an **examination procedure** is completed, the **examination results** are fed into the COMSY database. Subsequently they are used for further optimize the inspection scope.


COMSY acquires and assesses **examination records** from:

- > **UT wall thickness examination**
- > **UT flaw detection**
- > **Radiographic examination**
- > **Visual inspection**
- > *Liquid penetration examination*
- > *Magnetic particle examination*

and further the capability to manage **periodic inspections**.

The COMSY Closed Loop Process for Plant Life Management





> *COMSY copes with*

- ❑ *the large number of parameters affecting flow-induced corrosion (FAC, droplet impingement erosion and cavitation erosion) as well as*
- ❑ *the complexity of their functional interdependencies.*

> *COMSY allows*

- ❑ *the reliable identification of piping elements which may suffer material loss due to FIC,*
- ❑ *to calculate the minimum residual lifetime of piping elements affected by FIC to streamline inspection effort and*
- ❑ *to check countermeasures prior to their implementation.*

COMSY is a proven and ready-to-use tool with user interfaces in different languages and provides common materials and stress calculation for various countries

Service Applications

Philippsburg 1+2
Krümmel
Isar 1+2
Brunsbüttel
Biblis A+B
Gundremmingen B
Borssele
Beznau 1
Gösgen
Leibstadt
Almaraz 1+2
Oskarshamn 3
Forsmark 1+2
Fukushima 2-1
Different fossil fired plants
OL3 lifetime design services
Chinshan 1

Software Licenses

<i>Spain :</i>	<i>Asco 1+2</i>
	<i>Almaraz 1+2</i>
	<i>Cofrentes</i>
	<i>St. Maria de Garona</i>
<i>Finland :</i>	<i>Loviisa 1+2</i>
<i>Hungary :</i>	<i>Paks 1 to 4</i>
<i>Bulgaria :</i>	<i>Kozloduy 1 to 4</i>
<i>Japan :</i>	<i>Tomari 1+2</i>
<i>Brazil :</i>	<i>Angra 1&2</i>
<i>Belgium:</i>	<i>8 fossil fired plants</i>