

Secondary Circuit Mapping of FAC and High Velocity -Two Phase Flow Mechanical Degradation Effects

M. Chocrón¹, I. Rodríguez¹, M. Contino¹, R.Saucedo² and J.Duca

(1) Comisión Nacional de Energía Atómica (CNEA)-Argentina

(2) Central Nuclear Embalse-Nucleoeléctrica Argentina S.A. (NASA)

(3) UG-Atucha II - Nucleoeléctrica Argentina S.A. (NASA)

IAEA Workshop on Erosion-Corrosion (E/C) Including Flow Accelerated Corrosion (FAC) and Environmentally Assisted Cracking (EAC) Issues in Nuclear Power Plants. 21-23 April 2009, Moscow, Russian Federation.



NA•SA

NUCLEOELECTRICA ARGENTINA S.A.

IAEA WK on EC- April 2009



Contents

- Overview
- Objectives: BOP integrated assessment program
- Evaluation of FAC
- Mechanical degradation effects:
 - Jet impingement
 - Cavitation-flashing
 - Droplet erosion
- Water Chemistry improvements
- Atucha II: BOP and Water Chemistry
- Acknowledgements

Overview: Operating N.P.Ps.

Atucha I – PVHWR – SIEMENS KWU - 1974

Embalse CANDU®600 PHWR- AECL-Cordoba-1984

Atucha II – PVHWR – SIEMENS KWU – Buenos Aires – In Construction


Objectives

- Since the start-up (1984) Embalse has been carrying out a program of ***Piping Thickness Inspection*** guided by measurement results

Since 2004, with the start up of the ***PLiM/LTO Project***, an integrated program for FAC evaluation began to be developed in order to determine the wall thinning rate of the Secondary Circuit piping and components

The Program has been developed by Embalse NPP engineering staff along with the Comision Nacional de Energia Atómica (National Atomic Energy Commission). It is documented in several international workshops and conferences.

Objectives



Evaluation of FAC

- Understanding the Flow Assisted Corrosion Degradation Mechanism and its related variables (hydrodynamics, chemistry, etc.), already acquainted after PHTS components.

$$m' = \frac{(S_w - C)}{\left(\frac{1}{k_d} + \frac{1}{k_m k_e}\right)}$$

- **Development of a Calculation Code** to predict thinning rate in relevant steam/water cycle points based on FAC theory and assisted by CFD tools.
- **Creation of a detailed Data Base** for piping and accessories (dimensions, materials, process data, chemistry conditions, inspection data, etc.)
- **Identification and Screening** of components to be inspected, repaired or replaced (ISI optimization).

Evaluation of FAC

- Examples of Data Bases

| IDENTIFICACION | | | |
|---|------------|-----------------|------------------|
| Descripción | Código BSI | Número de línea | Plano Isométrico |
| Extracción de turbina BP A (VEX TBP) al precalentador E-102A - DN 600 | 43119 | 0165 | 43119-5004-01-DD |
| VEX TBP A a E-102A - DN 600 | 43119 | 0165 | 43119-5004-01-DD |

| MATERIAL Y DATOS GEOMETRICOS | | | | | | | |
|------------------------------|-------------|------|------------------------------|----------|-------------------------------------|---------------------|-----|
| Material | Composición | | σ (N/m ²) | De 1 (m) | De 2 (m) (Sólo para reducciones) | S (m ²) | Sch |
| | % Cr | % Mo | | | | | |
| A 106B | 0,03 | 0,03 | 1,031E+08 | 0,6096 | | 0,2739 | 20 |
| A 234W PB | 0,03 | 0,03 | 1,031E+08 | 0,6096 | | 0,2739 | 20 |

| MATERIAL Y DATOS GEOMETRICOS | | | | | | | |
|------------------------------|------------------------------------|------------|----------|----------|----------------------------------|-------|----------------------|
| e 1 (m) | e 2 (m) (Sólo para reducciones) | e calc (m) | e tf (m) | Di 1 (m) | Di 2 (m) (Sólo para reducciones) | L (m) | St (m ²) |
| 0,0095 | | 0,007 | 0,008 | 0,59056 | | 0,46 | 0,853 |
| 0,0095 | | 0,007 | 0,008 | 0,59056 | | | 2,664 |

| DATOS TERMODINAMICOS Y PROPIEDADES | | | | | |
|------------------------------------|-------------------------|--------------|---|-------------|-------------|
| Densidads Kg/m ³ | Viscosidads Kg/m seg | Título xs | DFe(OH) ₂ m ² /seg | Sw (ppb) | Co (ppb) |
| 1,08 | 1,29E-05 | 0,9559 | 8,52E-09 | 20,200 | 1 |
| 1,08 | 1,29E-05 | 0,9559 | 8,52E-09 | 20,200 | 1 |

Evaluation of FAC




- As a result of the Integral BOP Life Assessment System, a wall ***thinning rate categorization*** is divided into five areas as shown in the following flow sheet:

- Green lines (very low thinning rate)
- Blue lines (low thinning rate)
- Yellow lines (moderate thinning rate)
- Orange lines (relevant thinning rate)
- Red lines (high thinning rate)

This considers not only the predicted wall thinning rate but also the different manufacture thickness in their respective location

Evaluation of FAC: Relative WTR due to FAC



Mechanical degradation effects

- Under FAC conditions, mass transfer dominates while over a critical velocity-Two phase flow, the protective oxide is mechanically removed and even the base metal attacked.
- There are no theories at the macro level capable of predicting degradation as in the case of FAC.

It has been part of the BOP assessment program to ***develop a map*** for

- 1- Jet impingement
- 2- Cavitation-flashing
- 3- Droplet erosion


Jet impingement

- Heat and mass transfer in turbulent jets extensively studied.
- Four zones can be distinguished: A-Laminar stagnation, B-High turbulence, C-Low turbulence and D-Turbulent Boundary layer as distance from jet increases.

$$\Gamma_w = 0.179 \rho U_0^2 \text{Re}^{-0.182} \left(\frac{r}{r_0}\right)^{-2.0}$$


- It can be related to FAC by shear stress analogy.
- However, CFD modeling helps with the location, extension and interpretation of damage.
- Typical of Tees and Turbine extraction lines at preheater entrance shells.

Jet impingement



Preheater showing LPT extraction lines

CFD modeling at preheater entrance




Cavitation-flashing

- In cavitation, after a depression where the fluid approaches saturation, pressure is recovered and the bubbles implote creating a microjet that damages the surface
- In flashing, bubbles tend to remain eroding the surface
- While principles are well fundamented at microscale, a SC map can only be based on the, rather obvious, cavitation number as a potential of approaching bubble pressure.

$$K = \frac{(P_{\infty} - P_v)}{\frac{1}{2} \rho V^2}$$

| | |
|---------------------|---|
| K >> 1 | Subcooled liquid with low linear velocity and absolute pressure higher enough than saturation pressure at temperature. |
| K < 0 | Supersaturated steam. |
| K = 0 | Local steam quality must be analyzed. If saturated liquid, the creation of bubbles is feasible. With high steam quality, there is no possibility of cavitation. |
| K ≈ 0 | High possibility of cavitation-flashing is expected at those locations. |

Cavitation-flashing




Cavitation-flashing expected zones (red symbols)


Dropplet erosion

- Depends on the flow, velocity, temperature, base metal and water chemistry (pH and ECP).
- In SCs of NPPs, dropplet erosion prone zones are those of straight pipes with annular flow or dropplet dispersed flow close to accesories (elbows, tees) where liquid phase impacts the walls.
- Therefore, effort has been devoted to better prediction of void fraction-TPF zones with ***annular flow by comparison among several correlations*** considering angles (Tandon, Baker and Taitel-Dukler for horizontal flow and Hewitt-Roberts for vertical flow).

Droplet erosion




Predicted void fraction after several models



Predicted flow regime after Tandon Map for horizontal flow

Droplet erosion



Predicted flow regime after Taitel-Dukler Map for horizontal flow


Annular flow prediction and comparison after several models

Table VI

| Line Tag | T (°C) | P (bar) | x | W (Kg/s) | Taitel | Tandon SM | Tandon MN | Tandon T | Tandon Z | Tandon C | Baker | H-R (Vertical) |
|----------|--------|---------|-------|----------|--------|-----------|-----------|----------|----------|----------|-------|----------------|
| 120 | 233 | 12 | 1 | 130.882 | | | | | | | | |
| 162 | 194.6 | 7.36 | 0.998 | 15.845 | * | * | * | * | * | * | | * |
| 105 | 260 | 46.9 | 0.998 | 935.156 | * | * | * | * | * | * | * | * |
| 105 | 260 | 46.9 | 0.998 | 934.955 | * | * | * | * | * | * | * | * |
| 126 | 260 | 46.9 | 0.998 | 0.202 | | | | | | | | |
| 114 | 260 | 46.9 | 0.998 | 34.626 | * | * | * | * | * | * | * | * |
| 105 | 260 | 46.9 | 0.998 | 865.703 | * | * | * | * | * | * | * | * |
| 204 | 260 | 46.9 | 0.998 | 0.117 | | | | | | | | |
| 106 | 260 | 46.9 | 0.998 | 216.21 | * | * | * | * | * | * | * | * |
| 193 | 260 | 46.9 | 0.998 | 0.25 | | | | | | | | |
| 165 | 118.6 | 1.9 | 0.956 | 11.398 | | | | | | | | * |
| 110 | 189.5 | 12.4 | 0.91 | 215.642 | * | * | * | * | * | * | * | * |
| 168 | 93.2 | 0.79 | 0.809 | 10.783 | | | | | | | | * |
| 176 | 68.86 | 0.3 | 0.673 | 14.724 | | | | | | | | * |
| 169 | 105 | 1.21 | 0.587 | 1.88 | | | | | | | | |
| 174 | 82.15 | 0.52 | 0.265 | 3.864 | | | | | | | | |
| 0532 A | 162.8 | 6.77 | 0.208 | 11.542 | * | | | | | | * | * |
| 0519 A | 162.8 | 6.77 | 0.058 | 12.879 | * | | | | | | * | * |

SM: Modified Smith; MN: Martinelli-Nelson; Z: Zivi; C: Crisholm; T: Thom; H-R: Hewitt-Roberts

Cavitation-flashing



Annular flow-Droplet erosion according to different models (circles)

Monitoring Results

- **Turbine extraction lines** (TBP-A) and **drainage lines** during 2005 Outage. Regions with localized degradation (8 out of 21 measured areas show a localized degradation $> 30\%$) have been found in the extractions of the TBP-A toward the preheater E-104A.

The highest wall thinning has been observed in the areas of the straight pipe toward the preheater, adjacent to 45° elbow.


- **Turbine extraction lines** TBP-A/C during 2007 outage: regions with localized degradation (13 out of 20 measured areas have shown localized degradation $> 30\%$) have been found in the extractions of the TBP-A/C toward E-104-A/C preheaters., again close to 45° elbows.

Monitoring Results


- Wall thickness measurements of CS high pressure preheater shells (E-101/102) to obtain information about the equipment status.

- Extension of piping thickness measurements in SGs feedwater lines during 2007 outage: given that in 2006 a break occurred in other NPP, downstream of a flow element, the plant decided to extend program considering new 45 critical zones. Only 4 (90o elbows) have shown wall thinning $> 12.5\%$ but $< 30\%$ referred to nominal thickness.

- Moisture Separator Reheater entrance pipe.





Monitoring Results




New specifically inspected zones

Water Chemistry Improvements

- pH has been gradually augmented with eventual replacement of Morpholine by ETA
- Highly beneficial impact on reduction of Fe transport along the circuit has been observed



Water Chemistry-Atucha II



| | |
|----------------------------------|--|
| Power | 744,7/693 Mwe |
| Cycle water | DeminerIALIZED water |
| Thermal power | 986,35 MWx2 = 1972,7 MW |
| No of tubes in the SCs | 6524 x 2 = 13.048 |
| Tube material and dimensions | Incolloy 800/18 x 1 mm |
| TSPs | DIN 1-4550 |
| U-bend | Incolloy 800 |
| TP cladding | DIN 1-4550 |
| Inlet and outlet SCs temperature | 313,8/277,5 oC |
| Temperature and quality of steam | 271,0 oC/54,9 bar/0,9975 |
| Nº of Moderator HXs | 4 |
| Thermal power | 50,7 x 4 = 202,8 MW |
| No of tubes | 1065 x 4 = 4260 |
| Material and dimensions | 12 x 1 mm Incolloy 800 |
| TSPs | DIN 1-4550 |
| TP cladding | DIN 1-4550 |
| Inlet and outlet Moderator HX | 194,2/140,0 oC |
| FWtrain | St 37-0 |
| Low pressure preheaters | AISI 316L |
| High pressure preheaters | AISI 316L |
| FWtank temperature | 121 oC |
| Condenser tubing | AISI 316L |
| Nº of tubes and dimensions | 2 x 35,358 = 70,716 / 21 x 0,7 x 15239 |
| Material | AISI 316L |
| Cases extraction box | AISI 316L |
| Chemistry | High AVT |

Water Chemistry-Atucha II



Feed Water

| Control Parameters | Normal Operation Values | Action Level 1 | Action Level 2 | Action Level 3 |
|---|-------------------------|----------------|----------------------|----------------|
| pH a 25°C | > 9.8 | < 9.8 | --- | --- |
| Cationic Conductivity [$\mu\text{S}/\text{cm}$] ¹⁾ | < 0.15 | > 0.2 | --- | --- |
| Oxygen [mg/Kg] | < 0.005 | > 0.005 | > 0.02 ²⁾ | > 0.1 |

- (1) Caused by only strong anions; organics and CO₂ are not to be considered.
 (2) Power reduction is not required.

| Diagnostic Parameters | Normal Operating Values |
|---|-------------------------|
| Hydrazine [mg/Kg] | > 0.02 |
| Specific Conductivity [$\mu\text{S}/\text{cm}$] | < 15.0 |
| Ammonia [mg/Kg] | 10.0 - 12.0 |

| Complementary Parameters | Normal Operating Values |
|--------------------------|-------------------------|
| Iron [mg/Kg] | < 0.001 |

Feed water specifications

Steam Generator Blowdown

| Control Parameters | Normal Operation Values | Action Level 1 | Action Level 2 | Action Level 3 |
|---|-------------------------|----------------|----------------|----------------|
| Cation Conductivity [$\mu\text{S}/\text{cm}$] ¹⁾ | < 0.2 | > 1.0 | > 2.0 | > 7.0 |
| Sodium [mg/Kg] | < 0.005 | > 0.05 | > 0.1 | > 0.5 |

- 1) Caused by only strong anions; organics and CO₂ are not to be considered.

Steam Generator specifications

| Diagnostic Parameters | Normal Operating Values |
|--|-------------------------|
| pH at 25°C | > 9.6 |
| Chlorides (Cl ⁻) [mg/Kg] | < 0.01 |
| Sulphates (SO ₄ ⁻²) [mg/Kg] | < 0.01 |
| Ammonia [mg/Kg] | < 1,5 |

| Complementary Parameters | Normal Operating Values |
|--------------------------|-------------------------|
| Iron [mg/Kg] | < 0.005 |
| SiO ₂ [mg/Kg] | < 0.1 |

Acknowledgements

- The IAEA is gratefully acknowledged for the support given through the Projects RLA 4021 and 4091

Thank you for your attention!

