



Strål
säkerhets
myndigheten

Swedish Radiation Safety Authority

Ageing Management and LTO of NPPs – Swedish perspective

Michael Knochenhauer

Director, Nuclear Power Plant Safety


Swedish Radiation Safety Authority

IAEA / Senior Regulator's Meeting 16-17/9 2015



Swedish nuclear facilities

- 7 ASEA-Atom BWRs (5 different designs)
- 3 Westinghouse PWRs (2 different designs)



Forsmark NPP

Westinghouse SE
Fuel manufacturing

SFR
Final storage
Low/interm. waste



Ringhals NPP

Studsvik
Research reactors
closed

Oskarshamn NPP


Barsebäck NPP
Closed

CLAB
Central intermediate
Spent fuel storage






Age of Swedish NPPs






Ageing management






Physical ageing of components and structures

The “bath tube curve” as basis for NPP lifetime





General operating experience so far shows another picture (mechanical components)





Some data from the OECD-NEA OPDE





Figure 8: Pipe Degradation & Failure by Calendar Year



Inspection and control have worked well – so far



- No major safety consequences
- Most degradation events have been detected by ISI
 - but some misses have been reported
- Detection of degradation have often led to extensive replacement measures
 - to prevent further failures



Research is important

- Research activities and operating experience world wide
 - have led to a situation where substantial knowledge has been accumulated about degradation mechanisms that can affect components and structures in NPPs
- However, degradation history shows clearly that our knowledge base must be continuously updated based on
 - further research, and detailed damage analyses, which often reveal other circumstances than those expected
- Continued international cooperation will be important
 - such as the IAEA IGALL, OECD-NEA OPDE/CODAP







Long-term operation (LTO)

- IAEA definition of LTO is
“operation beyond an established time frame set forth by, for example, license term, design, standards, license and/or regulations, which has been justified by safety assessment, with consideration given to life limiting processes and features of systems, structures and components”
- This means that both the formal and real conditions for LTO varies between NPPs and countries



Internationally recommended practice



- to have a formal process with the clear position on long-term operation either through
 - a License Renewal process, or
 - by a PSR process focusing on LTO





LTO involves some new challenges for both licensees and authorities

- Organisations, resources and expertise must be adaptable to manage new safety issues that might arise
 - e.g. in terms of design bases used, ageing / degradation mechanisms that can affect the long term
- Effective programs for ageing management must be in place
 - Inspection, testing, monitoring, maintenance, replacements
 - Is important before LTO, but even more as NPPs becomes older
- Legal and supervisory framework needs to be reviewed
 - with more focus on ageing issues and ageing management activities





LTO is not only about physical ageing

- Technological ageing (obsolete equipment)
 - for example I&C
 - Difficulties in obtaining spare parts, problems with maintenance and repair
- Generation shifts within organizations
 - Important tacit knowledge may disappear from organizations
 - It can relate to specific maintenance practices, applied but undocumented design bases for certain equipment, etc.
- Plant documentation
 - Poor archiving of detailed design and manufacturing documentation
 - Detailed design and manufacturing documentation has been left with suppliers and manufacturers who have gone out of business



Validity of operating licenses - the formal situation in Sweden

- An operating license for a Swedish nuclear power reactor under both the Nuclear Activities Act and the Environmental Code is a favouring permit without time limitation
- It can not be withdrawn as long as
 - the provisions of laws, government ordinances and SSM's regulations are met, and
 - the conditions and obligations under the license are met





How will the conditions for LTO of Swedish NPPs be examined?

- By a PSR process specifically addressing LTO
- It must be shown that the plant with its SSCs can be used / operated beyond the time originally planned for and with the assumptions which were made when designing the SSCs
 - including revalidation of design analyses, other verifying analyses (TLAA) and environmental qualifications for the extended period
 - and that there are no degradations and deteriorations of various types
- or make the necessary replacements



Investigation of long-term safety in the Swedish nuclear power industry

- Conclusions in SSM's reporting of the government assignment (2012):
 - Safety can be maintained over the long term, provided that
 - additional safety improvements are made
 - the licensees apply effective ageing management,
 - this is examined regularly in the time ahead in the form of in-depth PSR
- Furthermore, it is essential that
 - a good safety culture is maintained
 - also ensuring that other safety-related conditions pertaining to organisations and human resources are maintained and developed





Recommendation from SSM reporting / Special attention on:

- Irradiation embrittlement of reactor pressure vessels, taking account of effects that can substantially increase the rate of embrittlement
- Fatigue, taking account of impact from the reactor water environment on areas sensitive to fatigue
- The condition of tendons and steel liners in reactor containments
- Degradation mechanisms that can influence reactor containments' concrete and metal parts
- Possibilities for reliable inspections and testing of reactor containments
- The validity of environmental qualifications of electrical, instrumentation and control equipment as well as parts with polymer construction materials



More can be read on: www.ssm.se

The screenshot shows the homepage of the Swedish Radiation Safety Authority (SSM). The header includes the organization's name and logo, navigation links for 'Anpassa', 'In English', 'Webbkarta', 'Lättläst', 'Teckenspråk', 'Övriga språk', and 'Kontakt', and a search bar. A secondary navigation bar contains 'Start', 'Yrkesverksam', 'E-dokument', 'Om myndigheten', 'Forskning', 'Lagar och författningar', 'Publikationer', 'Frågor och svar', and 'Press'. The main content area features a left sidebar with a menu, a central article titled 'Långsiktig säkerhetsutveckling', and a right sidebar with 'Länkar'. The article text discusses the government's 2010 mandate to assess the long-term safety development of Swedish nuclear power plants, mentioning the Fukushima Dai-ichi incident and the resulting regulatory changes.

Strålsäkerhetsmyndigheten
Swedish Radiation Safety Authority

Anpassa In English Webbkarta Lättläst Teckenspråk Övriga språk Kontakt

Start Yrkesverksam E-dokument Om myndigheten Forskning Lagar och författningar Publikationer Frågor och svar Press

Strålsäkerhetsmyndigheten / Vårt säkerhetsarbete / Långsiktig säkerhetsutveckling

Långsiktig säkerhetsutveckling

Säkerheten vid de svenska kärnkraftverken kan upprätthållas även långsiktigt förutsatt att kraftbolagen genomför ytterligare säkerhetsförbättringar och att de förstärker sina åtgärder för kontroll och underhåll av reaktorerna. Det visar en analys som Strålsäkerhetsmyndigheten har genomfört på uppdrag av regeringen.

Den 8 april 2010 gav regeringen Strålsäkerhetsmyndigheten i uppdrag att redovisa en analys av den långsiktiga säkerhetsutvecklingen inom den svenska kärnkraften. Uppdraget omfattar en samlad utvärdering av hur kärnkraftreaktorerna uppfyller myndighetens krav på säkerhetsmoderniseringar, en bedömning av vilka ytterligare krav på säkerhetsförbättringar som behövs för långa drifttider (över 40 år) och förhållanden som kan vara avgörande för att driva en reaktor under längre drifttider. Myndigheten har även analyserat den svenska tillsynsmodellen inom reaktorsäkerhetsområdet. Efter olyckan vid det japanska kärnkraftverket Fukushima Dai-ichi utvidgade regeringen uppdraget att även omhänderta erfarenheter därifrån. Analysen presenterades för regeringen den 31 oktober 2012.

Analysen, som redovisas i en samlad rapport och mer utförligt i tre delrapporter, visar att säkerheten vid de svenska kärnkraftverken kan upprätthållas även långsiktigt förutsatt att kärnkraftverken genomför ytterligare säkerhetsförbättringar och att de förstärker sina åtgärder för kontroll och underhåll av reaktorerna.

Läs den samlade rapporten: [Utredning avseende den långsiktiga säkerhetsutvecklingen i den svenska kärnkraften och åtgärder med anledning av olyckan i Fukushima.](#)


Länkar

- » Lagen om kärnteknisk verksamhet
- » Strålskyddslagen
- » Strålsäkerhetsmyndighetens författningssamling



Legislation and regulations

- A major review of legislation and regulations for nuclear installations and other activities involving radiation is in progress
- SSM will in this context clarify and define both the regulations and general advice about
 - ageing management
 - safety assessments and TLAA
 - the role and content of PSR
- in the light of the licensees' plans for LTO of the Swedish NPPS





Status of SALTO reviews

- Ringhals NPPs
 - Pre-SALTO Ringhals 1 and 2 in 2014
 - Follow-up SALTO in 2016
 - Full-scope SALTO for Ringhals 3 and 4 in 2018
- Forsmark NPPs
 - Pre-SALTO planned for 2016
- Oskarshamn NPPs
 - In preparation to request SALTO review



Conclusions

- Experience shows that effective ageing management must continuously be taken into account
 - from the design phase and throughout the planned period of operation
- In regulatory evaluation of potential for LTO focus on ageing management is necessary but not sufficient
- Other aspects that must be considered are
 - implemented and need for additional safety improvements
 - application of lessons learned from operating experience
 - adequate licensee staff resources and performance
 - security at the plant



Conclusions

- The Swedish licensees have announced that they intend to operate the NPPs longer than originally planned
 - 3 for 50 years and 7 for 60 years (currently under reconsideration!)
- SSM will take position on LTO within the framework of a PSR for each plant
 - Efforts are under way to analyse and evaluate several PSR involving transition to LTO
- Work is also underway to revise and clarify SSM's regulations, including the requirements for
 - ageing management
 - safety assessments and TLAA
 - PSR as a basis for decisions on LTO