




# NATIONAL REPORT OF BRAZIL 2011

FOR THE  
4th REVIEW MEETING OF THE  
JOINT CONVENTION ON THE SAFETY OF SPENT  
FUEL MANAGEMENT AND ON THE SAFETY OF  
RADIOACTIVE WASTE MANAGEMENT

---

OCTOBER 2011



*This page intentionally left blank*

**JOINT CONVENTION ON THE SAFETY OF  
SPENT FUEL MANAGEMENT AND ON  
THE SAFETY OF RADIOACTIVE  
WASTE MANAGEMENT**

**NATIONAL REPORT OF BRAZIL FOR THE 4<sup>th</sup> REVIEW MEETING**

**October 2011**

*This page intentionally left blank*

## **FOREWORD**

On 29 September 1997, the Joint Convention on the Safety of Spent Fuel Management and on the Safety of Radioactive Waste Management was open for signature at the headquarters of the International Atomic Energy Agency in Vienna. Brazil signed the Convention on October 11<sup>th</sup>, 1997 and ratified it by the Legislative Decree 1019 of November 14<sup>th</sup>, 2005. Brazil deposited the instrument of ratification with the Depositary on 17 February 2006.

Brazil has not participated in the First Review Meeting and presented the National Report for the Second Review Meeting under the condition of “late ratifier”. Therefore, the Report was not reviewed by the Parties according to the normal review process.

The National Report of Brazil 2008 was presented to the Parties of the Convention within the time schedule for review. Thereby, Brazil participated in the Third Review Meeting of the Contracting Parties to the Joint Convention in May 2009, in Vienna, Austria.

This present report, an update of the Brazilian National Report presented to the Joint Convention in October 2008, contains a description of the Brazilian policy and program related to the safety of nuclear energy, and an article-by-article description of the measures Brazil is taking to implement the Convention obligations, according to the format of document INFIRC/604.

The Brazilian National Report 2011 was prepared by a group composed of representatives of the various Brazilian organizations with responsibilities related to safety of spent fuel and radioactive waste.

The Convention objectives are to achieve and maintain a high level of nuclear safety worldwide in spent fuel and radioactive waste management. One of the obligations of the Parties to the Convention is the preparation of a periodical National Report describing the measures taken to implement each of the obligations of the Convention, including a description of the policies and practices related to spent fuel and radioactive waste management and an inventory of related material and facilities.

*This page intentionally left blank*

## CONTENTS

|  |           |
|--|-----------|
| <b>Section A - INTRODUCTION</b> .....                                      | <b>1</b>  |
| A.1 - The Brazilian Nuclear Policy .....                                   | 1         |
| A.2 - The Brazilian Nuclear Programme .....                                | 2         |
| A.2.1 - Nuclear Power Plants.....  | 3         |
| A.2.2 - Research Reactors (RR).....  | 3         |
| A.2.3 - Nuclear Installations .....  | 6         |
| A.2.4 - The Navy Programme .....   | 7         |
| A.2.5 - Radioactive Installations.....                                     | 7         |
| A.2.6 - Waste Repository at Abadia de Goiás .....                          | 9         |
| A.3 - Structure of the National Report .....                               | 9         |
| <br>   |           |
| <b>Section B - POLICIES AND PRACTICES (Article 32 - Paragraph 1)</b> ..... | <b>11</b> |
| B.1 - Introduction .....   | 11        |
| B.2 - Radioactive Waste .....  | 11        |
| B.2.1 – Types and Classification .....                                     | 11        |
| <br>   |           |
| <b>Section C - SCOPE OF APPLICATION (Article 3)</b> .....                  | <b>13</b> |
| C.1 - Definition of Scope.....   | 13        |
| <br>   |           |
| <b>Section D - INVENTORY AND LISTS (Article 32 - Paragraph 2)</b> .....    | <b>14</b> |
| D.1 - Nuclear Power Plants.....  | 14        |
| D.1.1 - Angra-1 .....  | 14        |
| D.1.2 - Angra-2 .....  | 15        |
| D.1.3 - Angra-3 .....  | 17        |
| D.1.4 - On Site Initial Storage Facility.....                              | 21        |
| D.1.5 - Old Steam Generators Storage Facility .....                        | 21        |
| D.1.6 - Waste Repository for Low and Intermediate Level Waste .....        | 22        |
| D.2 - Research Reactors.....   | 22        |
| D.2.1 - Spent Fuel Management .....  | 22        |
| D.2.2 - Radioactive Waste Management .....                                 | 24        |
| D.3 - Other Nuclear Installations.....                                     | 24        |
| D.3.1 - Brazilian Nuclear Industries (INB).....                            | 24        |
| D.4 - Navy Installations at São Paulo (CTMSP) and Iperó (CEA) .....        | 26        |
| D.5 - CNEN Institutes .....  | 26        |
| D.5.1 - IPEN.....  | 26        |
| D.5.2 - CDTN .....   | 26        |
| D.5.3 - IEN.....   | 27        |
| D.5.4 - CRCN-CO .....  | 27        |
| D.5.5 - LAPOC .....  | 28        |
| D.6 - Waste Repository at Abadia de Goiás (Closed) .....                   | 28        |

|  |           |
|--|-----------|
| <b>Section E - LEGISLATIVE AND REGULATORY SYSTEM .....</b>             | <b>31</b> |
| E.1 - Implementing Measures ( <i>Article 18</i> ).....                 | 31        |
| E.1.1 - Nuclear Licensing Process .....                                | 32        |
| E.1.2 - Environmental Licensing .....                                  | 34        |
| E.1.3 - Emergency Preparedness Legislation .....                       | 37        |
| E.2 - Legislative and Regulatory Framework ( <i>Article 19</i> ) ..... | 39        |
| E.3 - Regulatory Body ( <i>Article 20</i> ).....                       | 39        |
| E.3.1 - CNEN .....   | 40        |
| E.3.2 - IBAMA.....   | 42        |
| <br>   |           |
| <b>Section F - OTHER GENERAL SAFETY PROVISIONS .....</b>               | <b>45</b> |
| F.1 - Responsibility of the Licence Holder ( <i>Article 21</i> ) ..... | 45        |
| F.1.1 - Nuclear Power Plants .....                                     | 45        |
| F.1.2 - INB Facilities .....   | 46        |
| F.2 - Human and Financial Resources ( <i>Article 22</i> ).....         | 47        |
| F.2.1 - Human Resources.....   | 47        |
| F.2.2 - Financial Resources .....                                      | 52        |
| F.3 - Quality Assurance ( <i>Article 23</i> ).....                     | 54        |
| F.3.1 - Nuclear Power Plants .....                                     | 54        |
| F.3.2 - CNEN Installations .....                                       | 55        |
| F.3.3 - Quality Assurance at Navy Installations.....                   | 55        |
| F.3.4 - Quality Assurance at INB facilities .....                      | 55        |
| F.4 - Operational Radiation Protection ( <i>Article 24</i> ) .....     | 56        |
| F.4.1 - Nuclear Power Plants .....                                     | 58        |
| F.4.2 - INB Facilities .....   | 62        |
| F.5 - Emergency Preparedness ( <i>Article 25</i> ) .....               | 64        |
| F.5.1 - Nuclear Power Plants .....                                     | 65        |
| F.5.2 - Other Facilities (Research Reactors) .....                     | 67        |
| F.5.3 - INB Facilities .....   | 68        |
| F.5.4 - Emergency Preparedness at Navy Installations.....              | 68        |
| F.6 - Decommissioning ( <i>Article 26</i> ).....                       | 69        |
| F.6.1 - Nuclear Power Plants .....                                     | 69        |
| F.6.2 - Research Reactors .....  | 70        |
| F.6.3 - INB Facilities .....   | 70        |
| <br>   |           |
| <b>Section G - SAFETY OF SPENT FUEL MANAGEMENT.....</b>                | <b>77</b> |
| G.1 - General Safety Requirements ( <i>Article 4</i> ) .....           | 77        |
| G.2 - Existing Facilities ( <i>Article 5</i> ).....                    | 77        |
| G.2.1 - Nuclear Power Plants .....                                     | 77        |
| G.2.2 - Research reactors .....  | 80        |
| G.3 - Siting of Proposed Facilities ( <i>Article 6</i> ) .....         | 80        |
| G.4 - Design and Construction of Facilities ( <i>Article 7</i> ).....  | 80        |
| G.5 - Assessment of Safety of Facilities ( <i>Article 8</i> ) .....    | 81        |



|   |            |
|---|------------|
| G.5.1 - Nuclear Power Plants .....  | 81         |
| G.5.2 - Research Reactors .....   | 81         |
| G.5.3 - INB Facilities .....  | 82         |
| G.6 - Operation of Facilities ( <i>Article 9</i> ) .....                      | 82         |
| G.7 - Disposal of Spent Fuel ( <i>Article 10</i> ) .....                      | 83         |
| G.7.1 - Fuel from Nuclear Power Plants .....                                  | 83         |
| G.7.2 - Fuel from Nuclear Reactors .....                                      | 83         |
| <b>Section H - SAFETY OF RADIOACTIVE WASTE MANAGEMENT .....</b>               | <b>84</b>  |
| H.1 - General Safety Requirements ( <i>Article 11</i> ) .....                 | 84         |
| H.2 - Existing Facilities and Past Practices ( <i>Article 12</i> ) .....      | 84         |
| H.2.1 - Nuclear Power Plants .....  | 84         |
| H.2.2 - INB Facilities .....  | 89         |
| H.2.3 - Navy Facilities .....   | 92         |
| H.2.4 - CNEN Institutes .....   | 93         |
| H.2.5 - Research Institutions .....   | 99         |
| H.2.6 - Waste Repository at Abadia de Goiás .....                             | 99         |
| H.3 - Siting of Proposed Facilities ( <i>Article 13</i> ) .....               | 99         |
| H.3.1 - Nuclear Power Plants .....  | 99         |
| H.3.2 - Low and Intermediate Level Waste Repository .....                     | 100        |
| H.4 - Design and Construction of Facilities ( <i>Article 14</i> ) .....       | 102        |
| H.4.1 - Nuclear Power Plants .....  | 102        |
| H.4.2 - INB Facilities .....  | 103        |
| H.5 - Assessment of Safety of Facilities ( <i>Article 15</i> ) .....          | 103        |
| H.5.1 - Nuclear Power Plants .....  | 103        |
| H.5.2 - Other Facilities .....  | 104        |
| H.5.3 - INB Facilities .....  | 108        |
| H.6 - Operation of Facilities ( <i>Article 16</i> ) .....                     | 108        |
| H.7 - Institutional Control After Closure ( <i>Article 17</i> ) .....         | 109        |
| H.7.1 - Abadia de Goiás Repository .....                                      | 109        |
| <b>Section I - TRANSBOUNDARY MOVEMENT .....</b>                               | <b>110</b> |
| I.1 - Transboundary Movement ( <i>Article 27</i> ) .....                      | 110        |
| I.1.1 - Shipment of IPEN Spent Fuel to the Original Supplier Country .....    | 110        |
| I.1.2 - Packing and Repatriation of US-originated sources .....               | 112        |
| <b>Section J - DISUSED SEALED SOURCES .....</b>                               | <b>113</b> |
| J.1 - Disused Sealed Sources ( <i>Article 28</i> ) .....                      | 113        |
| J.1.1 - Disused Source Storage .....  | 113        |
| J.1.2 - Program for Collecting of Disused Sources and Radioactive Waste ..... | 113        |
| <b>Section K - PLANNED ACTIVITIES TO IMPROVE SAFETY .....</b>                 | <b>118</b> |
| K.1 - Improvements in the Nuclear Power Plants .....                          | 118        |

---

|  |            |
|--|------------|
| K.2 - Improvements in the Radioactive Waste Area .....                   | 118        |
| K.3 - New Waste Storage Facility at IPEN.....                            | 119        |
| K.4 - Plans for Decommissioning USIN .....                               | 120        |
| K.5 - Plans for a Brazilian Radioactive Waste Enterprise .....           | 121        |
| K.6 - Final Remarks .....  | 122        |
| <b>REFERENCES .....</b>  | <b>124</b> |
| <b>Section L - ANNEXES .....</b>   | <b>126</b> |
| L.1 - Annex 1 – Inventory Table .....                                    | 126        |
| L.2 - Annex 2 – List of Relevant Conventions, Laws and Regulations ..... | 133        |
| L.3 - Annex 3 – List of Abbreviations .....                              | 139        |

## LIST OF FIGURES

|  |     |
|--|-----|
| <b>Figure A.1</b> - Main Brazilian Nuclear Installations and Organizations .....   | 2   |
| <b>Figure A.2</b> - IPR-R1 – Reactor Core and Control Room.....  | 5   |
| <b>Figure D.1</b> - Angra-3 construction.....  | 20  |
| <b>Figures D.2</b> - Old steam generators storage facility .....   | 21  |
| <b>Figure D.3</b> - Interim storage facility at CRCN-CO .....  | 27  |
| <b>Figure D.4</b> - Temporary storage .....  | 29  |
| <b>Figures D.5</b> - (a) Great Capacity Container, (b) Repository at Abadia de Goiás.....  | 30  |
| <b>Figure E.1</b> - Brazilian Organizations Involved in Nuclear Safety .....   | 32  |
| <b>Figure E.2</b> - Angra-1 and 2 Radioactive Waste Storage Facilities.....  | 36  |
| <b>Figure E.3</b> - SIPRON Structure.....  | 38  |
| <b>Figure E.4</b> - Simplified CNEN Organization Chart .....   | 41  |
| <b>Figure E.5</b> - IBAMA Structure.....   | 42  |
| <b>Figure E.6</b> - DILIC Structure.....   | 43  |
| <b>Figure F.1</b> - Individual Dose in Angra-1 .....   | 59  |
| <b>Figure F.2</b> - Individual Dose in Angra-2 .....   | 59  |
| <b>Figure F.3</b> - Collective Dose in Angra-1 .....   | 60  |
| <b>Figure F.4</b> - Collective Dose in Angra-2 .....   | 60  |
| <b>Figure F.5</b> - Environmental Monitoring Program Results for 2003-2010 .....   | 61  |
| <b>Figure F.6</b> - Individual Dose 2010 - FCN .....   | 63  |
| <b>Figure F.7</b> - Collective dose - FCN .....  | 63  |
| <b>Figure F.8</b> - Mean Annual Effective Dose from Occupational Exposures – URA .....   | 64  |
| <b>Figure F.9</b> - Area occupied by USAM in Santo Amaro, SP.....  | 71  |
| <b>Figure F.10</b> - Clean area after USAM decommissioning work .....  | 73  |
| <b>Figure F.11</b> - New residential buildings built in USAM decommissioned area.....  | 74  |
| <b>Figures H.1</b> - On site initial waste storage facilities – location and schematic.....  | 87  |
| <b>Figure H.2</b> - (a) Chemical Treatment, (b) Cementation and (c) Compaction. ....   | 97  |
| <b>Figure H.3</b> - Intermediate Storage Facility Building - CDTN.....   | 97  |
| <b>Figures I.1</b> - (a) B-25 box loaded with disused industrial gauges, (b) transport shields<br>with brachytherapy and industrial sources removed from original gauges<br>original gauges..... | 112 |
| <b>Figure J.1</b> - Disused source storage at CDTN .....   | 114 |
| <b>Figure k.1</b> - New radioactive waste storage (outside and inside view) at IPEN .....  | 120 |

## LIST OF TABLES

|   |     |
|---|-----|
| <b>Table A.1</b> - Distribution of Radioactive Installation Licenses by Area (2011) .....   | 7   |
| <b>Table B.1</b> - Waste Classification .....   | 12  |
| <b>Table D.1</b> - Spent Fuel Assemblies Stored at Angra-1 .....  | 15  |
| <b>Table D.2</b> - Spent Fuel Assemblies Stored at Angra-2 .....  | 16  |
| <b>Table D.3</b> - Research Reactors in Brazil .....  | 22  |
| <b>Table D.4</b> - Fuel Element Characteristics .....   | 23  |
| <b>Table D.5</b> - SFA Inventory at Brazilians Research Reactors .....  | 23  |
| <b>Table D.6</b> - Waste stored at LAPOC .....  | 28  |
| <b>Table D.7</b> - Waste from Goiânia Accident .....  | 29  |
| <b>Table F.1</b> - Personnel involved in spent fuel and radioactive waste management at<br>Angra-1 and Angra-2 NPPs.....          | 49  |
| <b>Table F.2</b> - INB personnel – regular workforce by location .....  | 50  |
| <b>Table F.3</b> - INB personnel involved in radioactive waste management at Caetité (URA),<br>Buena (UMP) and Caldas (UTM) ..... | 50  |
| <b>Table F.4</b> - INB Personnel involved in radioactive waste management at Resende .....  | 51  |
| <b>Table F.5</b> - Personnel involved in spent fuel and radioactive waste management<br>at IPEN .....                             | 51  |
| <b>Table F.6</b> - Personnel involved in spent fuel and radioactive waste management<br>at CDTN .....                             | 52  |
| <b>Table F.7</b> - Radiation doses to workers involved in decommissioning USAM.....   | 73  |
| <b>Table G.1</b> - Spent fuel storage capacity at Angra – Number of fuel assemblies .....   | 78  |
| <b>Table H.1</b> - Waste Stored at Angra Site – Angra-1.....  | 88  |
| <b>Table H.2</b> - Waste Stored at Angra Site – Angra-2.....  | 88  |
| <b>Table H.3</b> - Types and amounts of material stored in Storage Facility A .....   | 90  |
| <b>Table H.4</b> - Amounts of Cake II stored in Botuxim.....  | 90  |
| <b>Table H.5</b> - Waste Inventory at CEA.....  | 93  |
| <b>Table H.6</b> - CDTN Waste Treatment Facilities.....   | 96  |
| <b>Table J.1</b> - Disused sources in storage .....   | 113 |
| <b>Table J.2</b> - Number of Recovered Spent Sources Collected at IEN – 2008/2011 .....   | 114 |
| <b>Table J.3</b> - Number of Recovered Spent Sources Collected at CDTN – 2008/2011.....   | 115 |
| <b>Table J.4</b> - Number of Recovered Spent Sources Collected at IPEN – 2008/2011 .....  | 117 |

## **SECTION A - INTRODUCTION**

### **A.1 - THE BRAZILIAN NUCLEAR POLICY**

The Constitution of 1988 of the Federal Republic of Brazil states in its articles 21 and 177 that the Union has the exclusive competence for managing and handling all nuclear energy activities, including the operation of nuclear power plants. The Union holds also the monopoly of the survey, mining, milling, exploitation and exploration of nuclear minerals, as well as of the activities related to industrialization and commerce of nuclear minerals and materials. The Union is also responsible for the final disposal of radioactive waste. All of these activities shall be solely carried out for peaceful uses and under the approval of the National Congress.

The national policy for the nuclear sector is implemented in accordance with the Pluriannual Plan (PPA) 2008-2011. PPA is formulated by the Executive branch of Federal Government four months before the end of the first year of the government. It defines the main strategic targets and programs of the Federal Government and must be analyzed, amended and approved by Congress. One of the components of the PPA is the National Nuclear Activities Programme (PNAN), aiming at guiding research, development, production and safe use of all forms of nuclear energy.

Another important target of the current PPA is to increase the participation of nuclear energy in the national electric power production. This involves the continuous development of technology for the design, construction and operation of nuclear power plants and industrial facilities related to the nuclear fuel cycle. The development of human resources for the establishment and continuity of these activities is also addressed in this plan.

The plan for Science and Technology also envisages the growth of nuclear technology use in other areas such as medicine, industry and food irradiation. To accomplish this, research and development institutions operate research reactors and isotope production facilities, as well as develop the related technology and train the required manpower.

The National Commission for Nuclear Energy (CNEN) was created in 1956 (Decree 40110 of 10/10/1956) to be in charge of all nuclear activities in Brazil. Later, CNEN was re-organized and its responsibilities were established by Law 4118/62 with alterations established by Laws 6189/74 and 7781/89. Thereafter, CNEN, a federal agency, through its Directorate for Radiation Protection and Nuclear Safety (DRS), has assumed Regulatory Body roles and is in charge of regulating, licensing and controlling nuclear activities in Brazil concerning Nuclear Safety, Security and Safeguards. At the same time, nuclear power generation was transferred to the government sector associated to energy issues. Furthermore CNEN, through its Directorate for Research and Development (DPD), is in charge of research and development and production of radioisotopes and, according to Brazilian Legislation, is also the governmental body responsible for receiving and disposing of radioactive waste from the whole country.

## A.2 - THE BRAZILIAN NUCLEAR PROGRAMME

The main Nuclear Installations and Organizations in Brazil are showed in Figure A.1.




Figure A.1 - Main Brazilian Nuclear Installations and Organizations

### A.2.1 - NUCLEAR POWER PLANTS

Currently, Brazil has two operating nuclear power plants (Angra-1, 640 MWe gross/ 610 MWe net, 2-loop PWR and Angra-2, 1,350 MWe gross /1,275 MWe net, 4-loop PWR). A third plant (Angra-3, 1,405 MWe gross /1,330 MWe net expected, 4-loop PWR) is currently under construction after a Governmental decision was made to restart the implementation of the Angra-3 project. Angra-1, 2 and 3 are located in a common site, near the city of Angra dos Reis, about 130 km south of Rio de Janeiro. Besides, following another Governmental decision, it has been initiated a complete research of possible sites all over the country for constructing new nuclear power plants in the near future.

The construction of nuclear power plants in Brazil has required considerable effort in qualifying domestic engineering, manufacturing and construction companies, in order to comply with the strict nuclear technology transfer. The result of this effort, based on active technology transfer, has led to an increase in the participation of domestic technology in the nuclear power sector.

Brazil has established a nuclear power utility and engineering company, Eletrobrás Termonuclear S.A. - Eletronuclear (ETN) (in 1997), a heavy components manufacturing company, Nuclebras Heavy Equipment Industry (NUCLEP), a Nuclear Fuel Factory (FCN) and a yellow-cake production plant belonging to the Brazilian Nuclear Industries (INB). Brazil also has the technology for uranium conversion and enrichment, as well as private engineering companies and research and development institutes devoted to nuclear power development. Over 15,000 individuals are involved in nuclear fuel cycle activities. With approximately only one third of its territory prospected Brazil ranks sixth in the world in terms of uranium ore reserves, which amounts to approximate 310,000 t U<sub>3</sub>O<sub>8</sub> *in situ*, recoverable at low cost.

According to the 10-year Expansion Plan of ELETROBRAS, a state holding company of the electric system, which is under the Ministry for Mines and Energy (MME) - see Figure E.1, Angra-3 is due to enter commercial operation by the end of 2015. The plant is also included in the Pluriannual Planning of the Brazilian Federal Government.

### A.2.2 - RESEARCH REACTORS (RR)

Brazil has 4 research reactors operating at CNEN institutes.

#### A.2.2.1 - The IEA-R1 Research Reactor

IEA-R1 is the largest research reactor in Brazil, with a maximum power rating of 5 MWth. IEA-R1 is a pool reactor, with light water as the coolant and moderator, and graphite and beryllium as reflectors. The reactor was commissioned on September 16, 1957, when it achieved its first criticality, and it is located at the Institute for Energy and Nuclear Research (IPEN), in São Paulo city. Although designed to operate at 5 MW, the reactor operated only at 2 MW between the early 1960's and mid 1980's, on an operational cycle of 8 hours a day, 5 days a week. IEA-R1 is currently operating at 4.0 MWth (until July 27, 2011) and 4.5 MWth (from August 01, 2011) with a 64-hour cycle

per week. The reactor originally used 93% enriched U-Al fuel elements. Currently, it uses 20% enriched uranium ( $U_3O_8$ -Al and  $U_3Si_2$ -Al) fuel that is produced and fabricated at IPEN. The reactor is operated and maintained by the Research Reactor Center (CRPq) at IPEN, Sao Paulo, which is also responsible for irradiation and other services.

The IEA-R1 reactor is located in a multidisciplinary facility which has been consistently used for research in nuclear and neutron related sciences and engineering. The reactor has also been used for training, radioisotope production for industrial and nuclear medicine applications, and for general irradiation services. Several departments of IPEN routinely use the reactor for their research and development work. Scientists and students from universities and other research institutions also use it for academic and technological research. The largest user of the reactor is the Research Reactor Center from IPEN, which is interested in basic and applied research in the areas of nuclear and neutron physics, nuclear metrology, and nuclear analytical techniques.

In the early 1960's, IPEN produced  $^{131}I$ ,  $^{32}P$ ,  $^{198}Au$ ,  $^{24}Na$ ,  $^{35}S$ ,  $^{51}Cr$  and labeled compounds for medical use. After 1980, it started producing  $^{99m}Tc$  generator kits from the fission of  $^{99}Mo$  imported from Canada. This production is continuously increasing, with the current rate of about 17,000 Ci of  $^{99m}Tc$  per year. The  $^{99m}Tc$  generator kits, with activities varying from 250 mCi to 2,000 mCi, are distributed to more than 300 hospitals and clinics in Brazil. Several radiopharmaceutical products based on  $^{131}I$ ,  $^{32}P$ ,  $^{51}Cr$  and  $^{153}Sm$  are also produced at IPEN.

Since 2001, a concerted effort has been made in order to upgrade the reactor power to 4.0 - 4.5 MWth for 2011 and 5 MWth to 2012. One of the reasons for this decision was to produce  $^{99}Mo$  at IPEN, thus minimizing the cost and reliance on only one or two international suppliers.

#### **A.2.2.2 - The IPR-R1 Research Reactor**

The IPR-R1 TRIGA Mark I Reactor, located at the Nuclear Technology Development Center (CDTN), at the campus of Federal University of Minas Gerais in Belo Horizonte, has been operating for 50 years. It was the second Brazilian RR. The IPR-R1 is a pool type nuclear research reactor, with an open water surface and the core has a cylindrical configuration (Figure A.2). The first criticality was achieved in November 1960. At present, the reactor operates at 100 kW and the certification process to operate at 250 kW is at the final stage. The operation regime of the reactor is about 12 hours per week, 40 weeks per year. The integrated burn-up of the reactor since its first criticality until present is about 83 MW-day. Due to the low nominal power, spent fuel is far from being a problem, except for aging concerns. The first fuel assembly replacement of the reactor is not expected to occur before 2015.

The IPR-R1 is mainly used for neutron activation analysis, experiments and applied research, as well as for the production of some radioisotopes, like  $^{60}Co$ ,  $^{198}Au$ ,  $^{192}Ir$ ,  $^{56}Mn$ ,  $^{24}Na$  etc, that is used in the stainless steel industry, and environmental research activities. Additionally it is also employed to train the Brazilian NPP operators.





**Figure A.2** - IPR-R1 – Reactor Core and Control Room

### A.2.2.3 - Argonauta Research Reactor

The third Brazilian RR is named Argonauta, and is located at the Institute of Nuclear Engineering (IEN) on the campus of the Federal University of Rio de Janeiro, in Rio de Janeiro city. The first criticality of the reactor was reached in February of 1965. The reactor can operate at a maximum power of 1kW during one hour or 500 W continuously. It is usually operated in the range of 170 to 340 W. The accumulated burn-up of the reactor since its first criticality is less than 1% and due to its low nominal power, storage of spent fuel is not a problem. It is used for training purposes, research, sample irradiation and for the production of some radiotracers for industrial use.

### A.2.2.4 - IPEN/MB-01 Research Reactor

The most recent Brazilian RR is IPEN/MB-01, also located at the Institute for Energy and Nuclear Research (IPEN). This research reactor is the result of a national joint program developed by CNEN and the Brazilian Navy.

The first criticality of the IPEN/MB-01 reactor was reached on November 9, 1988. From that date to March 2011, the reactor operated more than 2,587 times in order to measure Reactor Physics parameters to validate neutronic codes, train reactor operators and teach graduate and post-graduate courses. Some critical experiments are international benchmarks of the Nuclear Energy Agency (NEA-OECD). The IPEN/MB-01 reactor is a zero power reactor because the maximum power level is 100 watts with an average thermal neutron flux of about  $5.0 \times 10^8$  n/cm<sup>2</sup>.s. This neutron flux is not high enough to raise the temperature during its operation and fuel burn up. The reactor, a water tank type critical facility, has a core that consists of up 680 stainless steel fuel pins with UO<sub>2</sub> pellets inside. The diameter of the pins is 9.8 mm, and their length is 1,194 mm. The pins have an active length of 546 mm, filled with 4.3% enriched UO<sub>2</sub> pellets. The remainder of the pins is filled with Al<sub>2</sub>O<sub>3</sub> pellets.

The pins are manually inserted into a perforated matrix plane, making it possible to have any desired experimental arrangements within a 28 x 26 matrix. The control and

safety rods are composed of a total of 48 pins that contain absorbing neutron material. Each safety and control rod has 12 pins. Ten nuclear channels around the structure that sustains the matrix plate complement the critical arrangement, which is maintained within a stainless steel tank. Deionized water is used as a moderator and for the natural cooling system.

### **A.2.3 - NUCLEAR INSTALLATIONS**

#### **A.2.3.1 - Mining and Milling**

In Brazil, two facilities have been in operation. The first one, in Poços de Caldas, operated between 1982 and 1995. All the economically recoverable uranium was extracted and currently no mining activity is underway. The decommissioning and remediation plans for this unit are being prepared.

Another mining facility has been in operation since 2000 in Caetité, with reserves of 100,000 tons of  $U_3O_8$ , and a capacity of 400 tons/year of yellow cake ( $U_3O_8$ ) production, which can be expanded to 800 tons/year.

The deposit of Santa Quitéria, located in the interior of the State of Ceará, is the largest discovered uranium reserve in Brazil. An estimated 142.2 thousand tons of uranium is inter-mixed with phosphates. The economic viability of the mine depends on the exploration of the associated phosphate, which will be used in the production of fertilizers. INB hopes that the mine will be operational by 2015. It is planned to produce 1,600 tons of  $U_3O_8$  per year as a by-product of 240,000 tons of  $P_2O_5$ .

#### **A.2.3.2 - Monazite Sand Extraction**

Brazil has large natural deposits of monazite sand in its Central-East Coast. These have been in exploration since the 1950's. The only treatment facility in operation is located at Buena, in Rio de Janeiro state. The facilities in São Paulo state are no longer in operation.

#### **A.2.3.3 - Uranium Enrichment and Fuel Manufacture**

In the city of Resende, Rio de Janeiro state, there is an industrial complex which contains three units operated by INB related to the manufacture of nuclear fuel for the Brazilian Nuclear Power Plants.

In the first unit, uranium hexafluoride is converted into  $UO_2$  powder and fuel pellets are manufactured. The current nominal capacity is 165 tons/year of  $UO_2$  powder, and 120 tons/year of  $UO_2$  pellets, although only part of this is actually produced.

In the second unit, PWR fuel assemblies are manufactured using fuel pellets from the first unit and additional components imported or produced locally. The nominal capacity is 240 tons/year of uranium. From 1982 to 2010, this unit produced 1,230 fuel assemblies for Angra-1 and Angra-2.

At the same site, a third unit is underway. A plant for uranium enrichment based on ultracentrifuge technology developed by the Brazilian Navy is under initial operation since 2008. The nominal capacity of this initial phase will be 2.4 tons of SWU (Separative Work Unit).

#### A.2.4 - THE NAVY PROGRAMME

The Brazilian Navy started a nuclear technology research and development programme in 1979, with the main aim of designing, building and operating a nuclear propelled submarine. These activities are coordinated by the Navy Technological Center at São Paulo (CTMSP), which has its headquarters in the city of São Paulo and a site for experimental activities, named Aramar Experimental Center (CEA), in the city of Iperó. All the CTMSP nuclear facilities, except a small scale development laboratory, are located at CEA, and these include offices, laboratories, workshops, a pilot scale fuel manufacturing unit (LABMAT); uranium Enrichment Laboratories (LEI and USIDE) and a Radio-Ecological Laboratory (LARE). Still under construction are the UF<sub>6</sub> conversion facility (USEXA), and a land based prototype reactor (LABGENE) for a nuclear propelled submarine.

#### A.2.5 - RADIOACTIVE INSTALLATIONS

In Brazil, the Radiation Facilities, including the ones which use radioactive sources, are currently classified in 6 areas: medicine, industry, research and education, distribution, services and production of radiopharmaceuticals (cyclotrons).

In 2011, the national registry included 4,231 Radiation Facilities. Table A.1 shows the current distribution of the facilities by the areas of application. More than a hundred new facilities have been licensed every year and it is expected that this growing trend will continue in the following years.

**Table A.1 - Distribution of Radioactive Installation Licenses by Area (2011)**

| Area:   | Medicine | Industry | Research | Distribution | Services | Production (Cyclotrons) | Total |
|---------|----------|----------|----------|--------------|----------|-------------------------|-------|
| Number: | 1,498    | 1,555    | 822      | 77           | 264      | 15                      | 4,231 |

##### A.2.5.1 - Medical Installations

###### ➤ Radiotherapy Services

A total of 279 facilities are in operation or in licensing process. A national plan to equip and re-equip hospitals, with the acquisition of more than 60 LINACs, is being implemented and most of the accelerators will replace <sup>60</sup>Co radiotherapy irradiators.

###### ➤ Nuclear Medicine Services and Radiopharmaceuticals Production

The use of radioisotopes in medicine is increasing permanently. Positron emission tomography practice is well established and 5 new facilities (cyclotrons) for the production of radioisotopes have been licensed and are in operation since 2008.

### A.2.5.2 - Industrial Installations

A total of 5,385 sources are being used in industrial installations as described below.

➤ Industrial Radiography Services

The development of the Brazilian on-offshore oil and gas industry has significantly increased the demand for industrial radiography services. This has required a large effort to prepare the necessary personnel and develop the required procedures, especially for contractors.

➤ Utilization of Nuclear Measuring Instruments

The chemical, metallurgic, petrochemical, plastic, paper and other industry are increasingly using measuring instruments (gauges) based on radioactive sources. Portable instruments used for density measurement are becoming more widespread. Sources such as  $^{137}\text{Cs}$ ,  $^{241}\text{Am}$ ,  $^{90}\text{Sr}$  and  $^{85}\text{Kr}$  are the most used.

➤ Oil Exploration Well Profiling

In 2011, 7 organizations operated 24 bases for exploring oil in the North, Northeast and the Central coastal region using radioactive sources. Sources such as  $^{241}\text{Am}$ ,  $^{60}\text{Co}$ ,  $^{226}\text{Ra}$ ,  $^{137}\text{Cs}$  and  $^{241}\text{Am/Be}$  neutron sources are being used.

### A.2.5.3 - Industrial Irradiators

There are four  $^{60}\text{Co}$  large-size industrial irradiators operating in São Paulo state. They are used for sterilization of medical equipment and food irradiation. A new industrial irradiator facility is being licensed.

Regarding smaller irradiators, three units are operating in the country: two at CNEN's research centers (IPEN, in São Paulo and CDTN, in Belo Horizonte), and another one in Piracicaba, at the University of São Paulo's Center of Nuclear Energy for Agriculture, CENA.

### A.2.5.4 - Research Facilities

The use of radioisotopes in research occurs at CNEN research institutes (IPEN, IEN, and CDTN), other research centers and universities. The type of research is diverse, including nuclear physics, biology, agriculture, health, hydrology and environment. Generally, small sources of  $^3\text{H}$ ,  $^{14}\text{C}$ ,  $^{22}\text{Na}$ ,  $^{55}\text{Fe}$ ,  $^{63}\text{Ni}$ ,  $^{125}\text{I}$ ,  $^{226}\text{Ra}$ ,  $^{35}\text{S}$  e  $^{32}\text{P}$  are used for research applications.

Since 1986, IEN has been producing radio-pharmaceuticals for use in diagnostic examinations. Nowadays, the Institute produces in a commercial basis MIBG and  $^{18}\text{F}$ FDG on a commercial basis. The former is labelled with  $^{123}\text{I}$  produced via a KIPROS system (Karlsruhe Iodine Production System). This  $^{123}\text{I}$  production routine provides conditions for labelling other specials molecules. The  $^{18}\text{F}$ FDG produced in IEN is considered the newest

and most innovative technology in nuclear medicine (positron emitters). The Institute has two particle accelerators, the CV-28, which has been operating since 1974, and the RDS-111 (Siemens), which is dedicated to the production of the  $^{18}\text{F}$ .

Radioisotopes for medical uses are produced at IPEN in the Cyclotron Accelerators Center and in the Research Reactor Center. These radioisotopes, together with imported ones, are processed at the Radiopharmacy Center, following the requirements of the ISO 9002 standards and distributed just-in-time to hospitals all over the country, serving over 2.3 million patients per annum. A total of about  $6.4 \times 10^2$  TBq of  $^{18}\text{F}$ ,  $^{67}\text{Ga}$ ,  $^{123}\text{I}$ ,  $^{131}\text{I}$ ,  $^{99}\text{Mo}$ ,  $^{153}\text{Sm}$ ,  $^{35}\text{S}$ ,  $^{32}\text{P}$  and  $^{51}\text{Cr}$  compounds are processed annually at IPEN.

#### **A.2.6 - WASTE REPOSITORY at ABADIA DE GOIÁS**

Following the 1987 accident with a disused  $^{137}\text{Cs}$  source that resulted in the contamination of a significant part of the city of Goiânia, two near surface repositories with a total volume of  $3,134 \text{ m}^3$  of radioactive waste were constructed in Abadia de Goiás in 1995. The complete inventory is described in item **D.6**.

A long-term safety assessment of both repositories was done at that time confirming the safety of the two repositories. According to the requirements of the final safety assessment report, the long-term safety assessment must be repeated as part of the institutional control reporting requirements. In 2002, a second safety assessment was performed by CNEN to verify the safety of both systems. This is described in item **H.5.2.3**. Based on the safety assessment and Environmental Monitoring Programme (PMA) results, it was established that a new long-term safety assessment must be performed each ten years, the next one to be presented in 2012.

#### **A.3 - STRUCTURE OF THE NATIONAL REPORT**

This Report is a review of the first National Report presented to the 3<sup>rd</sup> Review Meeting in 2008. The second Brazilian Report for the 4<sup>th</sup> Review Meeting of the Joint Convention 2011 follows the same form and structure previously adopted and it was prepared to fulfill Brazilian commitments with the Convention [1]. Whenever possible, the information provided by the report refers to the situation as of March 2011.

Section **B** to **K** present an analysis of the Brazilian structures, actions and activities related to the Convention's obligations, and follow the revised Guidelines for the preparation of National Report [2]. In Section **B**, some details are given on the existing policies and practices. Section **C** defines the scope of application of the Convention in Brazil. Section **D** presents the inventory of installations and facilities. Section **E** provides details on the legislation and regulations, including the regulatory framework and the regulatory body. Section **F** covers general safety provisions as described in articles 21 to 26 of the Convention. Section **G** addresses the safety of spent fuel management, including during siting, design, construction and operation. Section **H** addresses the safe management of radioactive waste. Section **I** presents a case of transboundary movement of spent fuel. Section **J** details the situation of disused radioactive sources.

In general, the report presents separately the different types of facility, whenever possible. Nuclear power plants, due to their complexity, are always treated separately.

Section **K** describes planned activities to further enhance nuclear safety and presents final remarks related to the degree of compliance with the Convention obligations.

The report also contains two annexes where more detailed information is provided with respect to spent fuel storage and radioactive waste facilities, and the Brazilian nuclear legislation and regulations. A third annex presents a list of used abbreviations

## **SECTION B - POLICIES AND PRACTICES (Article 32 – § 1)**

### **B.1 - INTRODUCTION**

Brazilian practices related to spent fuel and radioactive waste management are similar to most international practices.

The policy adopted with regard to spent fuel from nuclear power plants is to keep the fuel in safe storage until an international consensus is reached about reprocessing and recycling the fuel, or disposing of it as such. Therefore, spent fuel is not considered radioactive waste in the sense of this Convention.

Regarding radioactive waste, the policy is to keep it safely isolated from the environment for the time being, while a permanent solution is expected on a national level.

The basic legislation governing this policy is the Brazilian Constitution, which establishes in its article 21 that “all the nuclear energy activities shall be solely carried out for peaceful uses and always under the approval of the National Congress”; the Law 6189 of 16 December 1989, which attributed to CNEN the responsibility for the final disposal of radioactive wastes; and the more recent Law 10308 of 20<sup>th</sup> November 2001 which established rules for the siting, licensing operation and regulation of radioactive waste storage facilities in Brazil (see also **E.2**).

### **B.2 - RADIOACTIVE WASTE**

#### **B.2.1 - TYPES and CLASSIFICATION**

The waste classification system adopted in Brazil is still based on the IAEA Safety Series No. 111-G-1.1 from 1994 [21]. Radioactive wastes are classified into three categories, as shown on Table B.1 below, where short lived are those radionuclides with half-lives equal or below 30 years such as <sup>60</sup>Co, <sup>90</sup>Sr and <sup>137</sup>Cs.

It is important to emphasize that the CNEN Norm-NE-6.05 - Radioactive Waste Management in Radioactive Facilities has been under review and a new waste classification scheme is going to be adopted, now based on the IAEA General Safety Guide No. GSG-1 from 2009 [22]. The Norm revision process was concluded and it shall be approved and implemented in 2011.

The types of waste are those normally generated by the sources presented in Section **A** of this document and are described in more detail in the inventory presented in Section **D**.

**Table B.1 - Waste Classification**

| Category   | Characteristics  | Disposal Option   |
|--|--|---|
| 1. Exempt waste  | Activity levels equal or below the exemption limits which are based on a maximum annual dose to members of the public of less than 0.01 mSv.   | No radiological restriction   |
| 2. Low and Intermediate level waste<br><br>2.1. Short lived<br><br>2.2. Long lived | Activity levels above exemption limits and heat generation equal or below 2 kW/m <sup>3</sup> .<br><br>Limitation of long lived alpha emitting radionuclides to 4000 Bq/g in individual waste packages and to an overall average of 400 Bq/g per waste package.<br><br>Long lived radionuclide concentrations exceeding limitations for short lived waste. | Near surface repository or geological.<br><br>Geological repository |
| 3. High level waste  | Heat generation above 2kW/m <sup>3</sup> and long lived alpha emitting radionuclide concentrations exceeding limitations for short lived waste (2.1).  | Geological repository   |



## **SECTION C - SCOPE OF APPLICATION (Article 3)**

### **C.1 - DEFINITION OF SCOPE**

According to the definition of the Convention and the Brazilian policies and practices described in Section **B**, the activities and facilities covered by this report include all spent fuel and radioactive waste related to the Brazilian nuclear programme described in Section **A.2**.

As mentioned in **B.1**, spent fuel from NPP's is not considered radioactive waste, pending an international consensus and a national decision about the possibility of reprocessing this fuel, or disposing it of as such.

Waste containing only natural occurring radioactive material (NORM) will be included in the scope only to the extent that they are produced in the processing of uranium and thorium containing ores, such as Monazite sand processing, as described in Sections **H.2.2.2**, **H.2.2.3**, and **H.2.2.4**.

So far, there is no spent fuel within the military or defense program in Brazil. The management of waste generated in the nuclear submarine program of the Brazilian Navy, although of minor importance and small quantity, is described in Section **D.4**.

## **SECTION D - INVENTORY AND LISTS (Article 32 – § 2)**

This section describes the facilities and activities that produce spent nuclear fuel and radioactive waste, and present a description of the inventories. More detailed information is presented in Section H and on table format in Annex 1.

### **D.1 - NUCLEAR POWER PLANTS**

As mentioned in item **A.2.1**, Brazil has two nuclear power plants in operation (Angra-1, 640 MWe gross/610 MWe net, 2-loop PWR and Angra-2, 1,350 MWe gross/1,275 MWe net, 4-loop PWR) and one under construction (Angra-3, 1,405 MWe gross/1,330 MWe net expected, 4-loop PWR,). Angra-1, 2 and 3 are located at a common site, near the city of Angra dos Reis, about 130 km from Rio de Janeiro.

#### **D.1.1 - ANGRA-1**

Site preparation for Angra-1, the first Brazilian nuclear unit, started in 1970 under the responsibility of FURNAS Centrais Elétricas SA. The initial work for construction of the plant began only in 1972 (Base Plate concrete works 29/03/1972), shortly after the contract with the main supplier of equipment, Westinghouse Electric Co. (USA), was signed. The Westinghouse contract included supply and erection of the equipment, as well as engineering and design of the plant on a turnkey basis. Westinghouse sub-contracted Gibbs and Hill (USA) in association with the Brazilian engineering company PROMON Engenharia S.A. for engineering and design.

CNEN granted the construction license for the plant in 1974. The operating license was issued in September 1981 (Res. CNEN no. 10/81, 10/09/81), at which time the first fuel core was also loaded (20/09/81). First criticality was reached in March 1982 (13/03/1982 at 20:23 h), and the plant was connected to the grid in April 1982. After a long commissioning period due to a steam generator generic design problem, which required equipment modifications, the plant finally entered into commercial operation on 1st January 1985.

In 1997, plant ownership has been transferred to the newly created company Eletrobras Eletronuclear (ETN), which has absorbed all the operating personnel of FURNAS CENTRAIS ELÉTRICAS S.A. and part of its engineering staff, and the personnel of the design company Nuclebras Engineering (NUCLEN).

##### **D.1.1.1 - Angra-1 Spent Fuel Management**

With respect to spent fuel of Angra-1, the spent fuel pool capacity has been expanded by the installation of compact racks to accommodate the spent fuel generated for the expected operational life of the unit.

The current status at Angra-1 fuel pools is presented on Table D.1.

**Table D.1 - Spent Fuel Assemblies Stored at Angra-1**

| Storage place  | Angra-1  |          |
|--|----------|----------|
|  | Capacity | Occupied |
| New Fuel Storage Room  | 45       | 0        |
| Region 1 Spent Fuel Pool   | 252      | 129      |
| Region 2 Spent Fuel Pool   | 1,000    | 605      |
| Reactor Core   | 121      | 121      |
| <b>Note:</b> By definition of INFCIRC/546 "SPENT FUEL" means nuclear fuel that has been irradiated in and permanently removed from a reactor core. Included in this inventory there are fuel assemblies that are not yet considered "spent fuel", since they may be reused in future cycles. |          |          |

#### D.1.1.2 - Angra-1 Radioactive Waste Management

Angra-1 nuclear power plant is equipped with systems for treatment and conditioning of liquid, gaseous and solid wastes. Concentrates from liquid waste treatment are solidified in cement and conditioned in 200 liter drums (up to 1998) and 1 m<sup>3</sup> steel containers (after 1998). Solid waste may be conditioned in drums or in special boxes. Gaseous waste is stored in holdup tanks. These tanks have the capacity for long-term storage. For the time being, medium and low level waste is being stored on site in a separate storage facility (see D.1.4).

Generated volume of solid radioactive waste material is kept to a minimum by preventing materials from becoming radioactive, by decontaminating and reusing radioactive materials, by monitoring for radioactivity and separating non-radioactive material prior to conditioning and storage, and by other volume reduction techniques. Procedures, personnel training and quality control checks are used to ensure that radioactive materials are properly packed, labelled and transported to the storage facility.

#### D.1.2 - ANGRA-2

In June 1975, a Cooperation Agreement for the peaceful uses of nuclear energy was signed between Brazil and the Federal Republic of Germany. Under that agreement Brazil accomplished the procurement of two nuclear power plants, Angra-2 and 3, from the German company, KWU – Kraftwerk Union A.G., later SIEMENS/KWU nuclear power plant supplier branch.

Considering that one of the objectives of the Agreement was a high degree of domestic participation, Brazilian company Nuclebras Engineering S.A. (NUCLEN) (now Eletrobras Eletronuclear (ETN), after merging with the nuclear part of FURNAS, in 1997) was founded in 1975 to act as architect engineer for the Angra-2 and 3 project, with KWU

as the overall plant designer, and, on the process, to acquire the required technology to design and build further nuclear power plants.

Angra-2 civil engineering contractor was Norberto Odebrecht Company and the civil works started on 9<sup>th</sup> September 1981. However, from 1983 on, the project suffered a gradual slowdown due to financial resources reduction. In 1991, Angra-2 works were resumed and in 1994, the financial resources necessary for its completion were defined. In 1995, a bid was called for the electromechanical erection and the winner companies formed the consortium UNAMON (seven Brazilian subcontracting companies joined to build nuclear power plants), which started its activities at the site on 1<sup>st</sup> June 1996.

Hot trial operation was started in September 1999. On 24<sup>th</sup> March 2000, after receiving from CNEN the Authorization for Initial Operation (AOI) initial core load started, followed by initial criticality on 17<sup>th</sup> July 2000, and first connection to the grid on 21<sup>th</sup> July 2000. The power tests phase was completed in November 2000. The commissioning phase was a very successful one. No major equipment problems occurred in spite of the very long storage time (~20 years), indicating the high quality of the component conservation program. The Angra-2 NPP has been operating at full power since mid November 2000 and went into commercial operation on 1<sup>st</sup> February 2001. The Authorization for Initial Operation (AOI) has been extended periodically, up to June 15, 2011, when CNEN issued the Authorization for Permanent Operation (AOP)

#### D.1.2.1 - Angra-2 Spent Fuel Management

The current status at Angra-2 fuel pools is presented on Table D.2.

**Table D.2 - Spent Fuel Assemblies Stored at Angra-2**

| Storage place   | Angra-2  |          |
|---|----------|----------|
|   | Capacity | Occupied |
| New Fuel Storage Room   | 75       | 0        |
| Region 1 Spent Fuel Pool  | 264      | 40       |
| Region 2 Spent Fuel Pool  | 820      | 400      |
| Reactor Core  | 193      | 193      |
| <p><b>Note:</b> By definition of INFCIRC/546 "SPENT FUEL" means nuclear fuel that has been irradiated in and permanently removed from a reactor core. Included in this inventory there are fuel assemblies that are not yet considered "spent fuel", since they may be reused in future cycles.</p> |          |          |

In the case of Angra-2, the spent fuel pool, which is located inside the steel containment, has two types of racks:

a) Region 1: normal racks with capacity for 264 fuel assemblies, equivalent to one full core plus one reload of fuel of any burnup and with enrichment up to 4.3%;

b) Region 2: high-density storage racks with storage capacity for 820 spent fuel assemblies. The fuel assemblies to be stored in region 2 must have a given minimum burnup, which is a function of the initial enrichment. This spent fuel storage capacity is sufficient for about 15 years (14 cycles) of operation, which means that additional spent fuel storage space will have to be provided in the medium term.

#### **D.1.2.2 - Angra-2 Radioactive Waste Management**

Angra-2 nuclear power plant is equipped with systems for treatment, conditioning, disposal and storage of liquid, gaseous and solid radioactive wastes. All Angra-2 waste treatment systems are highly automated to minimize human intervention and reduce operating personnel doses. Liquid waste is collected in storage tanks for further monitoring and adequate treatment or discharge to the environment. The concentrate resulting from the liquid waste treatment is further processed in order to reduce water content before being immobilized in bitumen and conditioned in 200-liter drums. Spent resins and filter elements are also immobilized in bitumen and conditioned in 200-liter drums. Compactable and non-compactable solid waste is conditioned in 200-liter drums. Gaseous waste is treated in the gaseous waste treatment system, where the radioactive gases are retained in delay beds containing active charcoal to let them decay well below allowable levels, before release into the environment throughout the 150 m high plant vent stack. No residues are produced in the gaseous waste treatment system, as all the system's consumables, mainly filters and delay bed fillings, are designed to last for the whole plant lifetime. The drums with waste are initially stored within the plant prior to being transported to the on site storage facility, still at the plant site.

Generated volume of solid radioactive waste material is kept to a minimum by preventing materials from becoming radioactive, by decontaminating and reusing radioactive materials, by monitoring for radioactivity and separating non-radioactive material prior to conditioning and storage, and by other volume reduction techniques. Procedures, personnel training and quality control checks are used to ensure that radioactive materials are properly packed, labelled and transported to the storage facility.

#### **D.1.3 - ANGRA-3**

On June 25, 2007 the Federal Government through its National Council for Energy Planning approved the resumption of Angra-3 construction after a 23-year interruption.

But, even before construction authorization for Angra-3 was given, some progress has been made. In 2005, following authorization for site preparation work issued by the Brazilian Institute for Environment and Renewable Natural Resources (IBAMA), the rock excavation for the plant foundation was cleaned up and stabilized. Engineering work was continued with adaptation for Angra-3 of Angra-2 materials and equipment specifications, upgrading the design with basis on the Angra-2 plant and the international operational experience as well as continuation of contacts with the potential equipment suppliers. An important formal step on the Government side was inclusion, in March

2006, of Angra-3 in the Electric Energy Expansion Decennial Planning, covering the period 2006/2015, following a detailed evaluation of Brazil's viable energy generation alternatives.

Most of its imported components are already in Brazil and the site is ready for concrete pouring. All the required engineering is essentially available since for economy and standardisation reasons Angra-3 is to be as similar as possible to Angra-2. This concept has been submitted to and accepted by CNEN, proposing "Angra-2 as-built" as the reference plant for Angra-3. In this context, the only major technical modification planned for Angra-3 is the replacement of the conventional instrumentation and control by a modern digital system. Another difference between the two units refers to the site: Angra-2 was constructed on pile foundation, while Angra-3 should be built on sound rock.

Concerning supplies, a great part of the imported equipment is already stored in the warehouses, including not only the primary circuit heavy components and the turbine-generator set but also special pumps, valves and piping material. Excellence of the preservation plan for long-term storage has been demonstrated during Angra-2 completion, whereby no relevant equipment malfunction due to long-term storage had adverse impact on plant commissioning or initial operation. The preservation measures, including the 24 months inspection program, continue to be applied for the Angra-3 components stored at the site.

For the plant construction, two licenses were required: the Construction License from the Nuclear Regulatory Commission - CNEN, based on the acceptance of a Preliminary Safety Analysis Report (PSAR) and the Installation License from the environmental regulatory body - IBAMA, based on the acceptance of an Environmental Impact Assessment (EIA).

The Preliminary Safety Analysis Report (PSAR) for the Nuclear Licensing procedure was reviewed and delivered to CNEN. In 2010, Eletrobras Eletronuclear (ETN) received a Partial Construction License from CNEN.

The environmental licensing proceeded with the preparation and submission of the Angra-3 Environmental Impact Assessment (EIA) to IBAMA. Still in the frame of the environmental licensing process, public hearings to inform the population of the contents of the EIA were held in all municipalities bordering the emergency planning zones of the Plant. ETN received the Pre-installation License from IBAMA in July 2008 and the Installation License in March 2009, both with several conditions to be fulfilled either before or during the construction phase.

Plant construction is planned to last 66 months, from starting of reactor annulus slab concrete work up to the end of power tests and start of commercial operation.

Angra-3 will be the third nuclear power plant in Admiral Álvaro Alberto Nuclear Power Station, located at Itaorna beach, in the municipality of Angra dos Reis (RJ).

This new plant will have 1,405 MWe of gross electrical output, producing about

10.9 million MWh per year - such power output is equivalent to one third of the power consumption of the State of Rio de Janeiro - and it will be similar to Angra-2, its reference plant.

Operational tests were performed for Angra-2 in 2003, when the plant operated at a gross electrical output of 1,436 MWe. Based on these tests and on Safety Analysis Calculations prepared for Angra-2, it was verified that the gross electrical output could be increased from 1,350 MWe to 1,405 MWe without major changes to the equipment.

The design for rendering effective the mentioned gross electrical output of 1,405 MWe for Angra-2 has already begun and it is expected to be ready in 2011 and implemented in 2012.

Based on the fact that Angra-2 is the reference plant for Angra-3, a procedure is being initiated with regard to the modification of Angra-3 design documents, considering the gross electrical output of 1,405 MWe. When the mentioned procedure is completed, the gross electrical output value of 1,405 MWe will be informed to the National Commission for Nuclear Energy (CNEN), as well as to other entities of the electrical energy sector, in order to duly render it formal.

By means of the Ministerial Order no. 12 of the Secretariat for Energy Planning and Development of the Ministry for Mines and Energy (SPE/MME), issued on June 22<sup>nd</sup>, 2010, the physical guarantee for Angra-3 was established taking into account the rated output of 1,405 MWe.

Owing to this similarity, a great portion of the engineering design for Angra-3 is already prepared. In addition, the experience with the construction and erection of Angra-2 showed the noteworthy technical competence of the Brazilian companies for working in this branch of activity. A significant amount of imported equipment was already bought, specially the mechanical heavy components, such as the main components of the nuclear island (reactor vessel, steam generators, pressurizer and main pumps) and the most important equipment of the BOP (turbine and electrical generator).

Angra-3 will increase the reliability of the Southeast region's grid because, together with the existing plants, Angra-1 and Angra-2, the new plant will supply approximately 70% of the electricity demands of the State of Rio de Janeiro.

On the following are described the main actions and activities related to Angra-3 construction, Figure D.1 (base: April -2011).

➤ **Nuclear Licensing**

On May 31, 2010, the Brazilian National Commission for Nuclear Energy (CNEN) granted the Construction License, which authorizes the concrete laying of the foundation slab of the reactor building (UJB), provided that Eletrobras Eletronuclear (ETN) submits to CNEN designs and calculations for the next stages of construction.

This license allowed ETN to start the concrete laying of the foundation slab of the Reactor Building on June 1<sup>st</sup>, 2010, which is the design milestone zero of the

General Executive Schedule that estimates commercial operation to start in 66 months. This period includes the activities of civil works, electromechanical erection, commissioning of the systems and operational tests.



**Figure D.1** - Angra-3 construction

➤ **Environmental Licensing**

The Preliminary License and the Installation License were granted by the Brazilian authority on environmental matters (IBAMA), respectively in June-2008 and March-2009, after all requirements of the environmental licensing were fulfilled. Among the requirements, we point out the approval of the EIA/RIMA (Environmental Impact Study/Environmental Impact Report) by the licensing entity and the carrying out of 17 Public Meetings with the neighboring communities to the Nuclear Power Station and of 8 Official Public Hearings, two in Angra dos Reis, Paraty, and Rio Claro, and one in Rio de Janeiro, and Ubatuba.

➤ **Civil Works Evolution**

The construction *Andrade Gutierrez Company*, responsible for the civil works, currently has a staff of about 2,700 employees, out of which about 80% live in the municipalities of Angra dos Reis, Paraty and Rio Claro, consistent with the company's policy of giving priority to the local labour force.

The project, which is in the initial phase of civil works (almost 8.5% of the physical progress for the concrete structures works, until the end of April 2011).

Additionally to the infrastructure site installations such as: concrete factory, carpentry, steel reinforced bars workshop, embedded pieces warehouse, 5 provisory substations etc, the main structures being constructed at present are:



reactor building, reactor auxiliary building, control building and turbine building.

#### **D.1.3.1 - Angra-3 Spent Fuel Management**

The spent fuel will be stored similarly to Angra-2.

#### **D.1.3.2 - Angra-3 Radioactive Waste Management**

The radioactive waste will be treated and initially stored within the plant, similarly to Angra-2, and then forwarded to the Waste Repository at the proper time.

#### **D.1.4 - ON SITE INITIAL STORAGE FACILITY**

The waste of Angra-1 and Angra-2 is being stored in an initial storage facility located at the Angra site. The storage facility consists of three buildings, which are submitted to CNEN inspections.

In addition to these buildings, Angra-2 NPP has an internal storage facility (UKA) with a total capacity of 1,644 two-hundred-liter drums.

For additional information, see Section **H.2**.

#### **D.1.5 - OLD STEAM GENERATORS STORAGE FACILITY**

With the replacement of Angra-1 steam generators, a new facility was constructed on site. The Old Steam Generator Storage Building is a reinforced concrete structure designed to provide shielding and storage for the two Angra-1 replaced steam generators and all associated contaminated material, see Figures D.2. In the future, it also will store the reactor pressure vessel head, one radioactive waste evaporator and one residual heat exchanger.



**Figures D.2 – Old steam generators storage facility**

It is located inside the Eletrobras Eletronuclear (ETN) property area, close to the site dock and within the site boundary. The old steam generators were arranged side by side in separate compartments. The building is designed to be seismic qualified according to Angra-1 class I structure design criteria and the concrete wall thickness provides radiological shielding according to CNEN-NE-3.01 standard and annual limit of operational dose.

#### **D.1.6 - WASTE REPOSITORY for LOW and INTERMEDIATE LEVEL WASTE**

The plans for final disposal of waste generated by Angra nuclear power complex (units 1, 2 and in the future 3), are under development, as described in items **H.3.2** and **H.5.2.2**.

### **D.2 - RESEARCH REACTORS**

#### **D.2.1 - SPENT FUEL MANAGEMENT**

Research reactors (RR) have been in operation in Brazil since the late 1950's and, as a result, some amount of spent fuel assemblies (SFA) has accumulated. Table D.3 shows the RR operating in Brazil.

Of the research reactors shown on Table D.3, up to this present moment, the only one subject to concerns related to spent fuel storage is the IEA-R1. Part of its spent fuel was returned to U.S.A., when in 1999 Brazil shipped 127 LEU and HEU fuel elements. Later, on November 2007, 33 spent fuel elements stored in the pool of the IEA-R1 reactor and containing uranium of US origin were also shipped back to Savannah River Site Laboratory, South Carolina, USA.

**Table D.3 - Research Reactors in Brazil**

|                    | <b>IEA-R1</b>    | <b>IPR-R1</b>   | <b>ARGONAUTA</b> | <b>IPEN/MB-01</b> |
|--------------------|------------------|-----------------|------------------|-------------------|
| <b>Criticality</b> | September 1957   | November 1960   | February 1965    | November 1988     |
| <b>Operator</b>    | IPEN-CNEN/SP     | CDTN-CNEN/MG    | IEN-CNEN/RJ      | IPEN-CNEN/SP      |
| <b>Location</b>    | São Paulo        | Minas Gerais    | Rio de Janeiro   | São Paulo         |
| <b>Type</b>        | Pool             | Triga Mark I    | Argonaut         | Critical assembly |
| <b>Power Level</b> | 2-5 MW           | 100 kW          | 170-340 W        | 100 W             |
| <b>Enrichment</b>  | 20%              | 20%             | 20%              | 4.3%              |
| <b>Supplier</b>    | Babcock & Wilcox | General Atomics | USDOE            | Brazil            |

These storage concerns were the driving force for Brazil to also join an IAEA Regional Project. The objectives of the Project are to provide the basic conditions to define a regional strategy for managing spent fuel and to provide solutions taking into consideration the economic and technological realities of the countries involved. In particular, to determine the basic conditions for managing RR spent fuel during operational and interim storage as well as final disposal, and to establish forms of regional cooperation for spent fuel characterization, safety, regulation and public communication.

IPR-R1 has no short- and medium-term storage problems, due to its low nominal power. The first fuel assembly replacement is not expected to occur before 2015.

The Brazilian part of the Latin American Spent Fuel Database is presented on Table D.4, showing the main characteristics of the fuel elements used in the Brazilian research reactors.

**Table D.4 - Fuel Element Characteristics**

| Facility   | Fuel Type | Fuel Material   | Enrichment     | Cladding Material |
|------------|-----------|---|----------------|-------------------|
| IEA-R1     | MTR       | U <sub>3</sub> O <sub>8</sub> -Al<br>U <sub>3</sub> Si <sub>2</sub> -Al | LEU 19.9%      | Aluminum          |
| IPR-R1     | TRIGA     | U-Zr-H  | LEU 20%        | Aluminum/SS*      |
| ARGONAUTA  | MTR       | U <sub>3</sub> O <sub>8</sub> -Al                                       | LEU-19.0-19.9% | Aluminum          |
| IPEN-MB-01 | Pin PWR   | UO <sub>2</sub> Pellets   | LEU 4.35 %     | SS                |

\*04 units at the core (Stainless steel)

The present RR spent fuel inventory is shown on Table D.5. The only reactors subject to concerns related to medium and long-term storage are IEA-R1 and IPR-R1. The other ones are low- and zero- power reactors with very low burn up. Taking these facts into consideration and the storage capacities presently available, some projections for the next 10-15 years have been made.

**Table D.5 - SFA Inventory at Brazilians Research Reactors**

| Facility   | # of FA in Present Core      | Average # used per year            | SFA Storage |            | SFA % Average Burnup |
|------------|------------------------------|------------------------------------|-------------|------------|----------------------|
|            |                              |                                    | At RR       | Outside RR |                      |
| IEA-R1     | 24 LEU, Silicide-9; Oxide-15 | ~18, expected for 120 h/week, 5 MW | 16 wet      | 0          | ~ 30                 |
| IPEN-MB-01 | 680 pins                     | NA                                 | 0           | 0          | NA                   |
| IPR-R1     | 63 rods (LEU)                | NA                                 | 0           | 0          | ~ 4                  |
| IEA-R1     | 8 LEU                        | NA                                 | 0           | 0          | NA                   |

NA = not applicable

Presently, storage facilities at IEA-R1 consist of racks located in the reactor pool with a capacity of 108 assemblies. According to the newly proposed operation schedule (4.5/5 MW, 64 hrs per week), 10-12 assemblies will be spent annually. Currently, 27 storage positions are occupied, suggesting that within 4 - 5 years the wet storage facility at the reactor will be full. It should be noted that 24 positions should be free to maintain the reactor core.

Finally, Brazil has not defined a technical solution for spent fuel or high-level waste disposal. As mentioned in **B.1**, spent fuel is not considered radioactive waste. Therefore, the policy adopted with regards to spent fuel is to keep the fuel in safe storage until an international consensus and a national decision is reached about reprocessing and recycling the fuel, or disposing of it as such.

## **D.2.2 – RADIOACTIVE WASTE MANAGEMENT**

The radioactive waste of the research reactors is managed together with the radioactive waste of the institutes to which they belong, as described in Section **D.5**.

## **D.3 - OTHER NUCLEAR INSTALLATIONS**

### **D.3.1 – BRAZILIAN NUCLEAR INDUSTRIES (INB)**

#### **D.3.1.1 - Waste from Fuel Cycle and Monazite Processing Facilities**

Formerly known as Poços de Caldas Industrial Complex - CIPC, the uranium mining and milling industrial complex is now called by Ore Treatment Unit (UTM). Located at the Poços de Caldas plateau, in the state of Minas Gerais, the unit produced, from 1982 to 1995, 1,170 ton of ammonium diuranate (yellow cake). The waste generated in this process is kept in a 29.2 hectare tailing dam system, with an actual volume capacity of 1 million cubic meters. It is estimated that 4.8 TBq (130 Ci) of  $^{238}\text{U}$ , 15 TBq (405 Ci) of  $^{226}\text{Ra}$  and 4.2 TBq (112 Ci) of  $^{228}\text{Ra}$  were disposed of in this site to the present date (See also **H.2.2.3**).

The operation of the rare-earth production line of Santo Amaro Processing Plant (USAM) in São Paulo has generated Mesothorium (a material containing  $^{226}\text{Ra}$  and  $^{228}\text{Ra}$ ) and Cake II (called Torta II - composed basically of thorium hydroxide concentrate). These materials, although not formally classified as waste, are presently stored in Poços de Caldas (UTM) and São Paulo (USIN and Botuxim). In Poços de Caldas (UTM) there are about 1,200 m<sup>3</sup> of Mesothorium and 7,250 m<sup>3</sup> of Cake II presently stored.

In the Interlagos facility (USIN), there are about 39 m<sup>3</sup> of Mesothorium and 325 m<sup>3</sup> of Cake II presently stored and in the Botuxim storage facility (São Paulo) there are about 2,190 m<sup>3</sup> of Cake II presently stored (See **H.2.2.2**).

**D.3.1.2 - Nuclear Fuel Factory - FCN**

The waste volume generated by the fuel element assembly unit and by all other pilot scale fuel cycle facilities is negligible when compared to the abovementioned figures. All the material is currently being transferred to the recently licensed initial storage facility.

**D.3.1.3 - Uranium Concentrate Unit - URA**

The Uranium Concentrate Unit (URA) project, located at the Caetité province, in the state of Bahia, adopted as a basic design assumption the minimization of effluent generation. Treatment and containment systems were introduced in order to reduce the residue, waste and effluent generation, thus minimizing the environmental impact of the facility.

The waste management systems were developed with the requirements of preserving the local environment by recycling industrial waters, as much as possible. Mine tailings are piled up on the sides of the hills in a dry condition. The depleted ore is placed together with the mine tailings, using procedures that eliminate or reduce the production of dust. Water consumption is reduced by promoting liquid effluent recycling, thus reducing treatment needs. The mud resulting from liquid residue treatment is kept in closed tailing ponds equipped with bottom and side drainage, in order to retain solid phase and allow liquid recycling.

URA produces at maximum 1,500,000 tons/year of mine tail with approximately 0.00067 %  $U_3O_8$  and 250,000 tons/year of leaching ore with approximately 0.06 %  $U_3O_8$  (uranium and the natural uranium series radionuclides). These materials are stored in the unique solid waste deposit. This deposit consists of an area surrounded by channels constructed for keeping rain water out of the deposit. The rain water that falls over the deposit is retained in the sediment tank from where it can be pumped to the mill process or to the environment, after monitoring and comparing uranium concentration in water with the predetermined maximum limit for discharge of this liquid effluent. The deposit is constructed in modular way with leaching ore piles surrounded by mine waste rocks. After the end of each module construction, its surface is covered by top soil and is re-vegetated. This construction process permits decommissioning of the solid waste deposit during the same period of mine production.

The mine tailings were located considering that the area has good geological conditions and the component rocks have good mechanical stability. The top soil was removed and retained for further recovery of the site. The area does not have any water source or surface water body. The rain water that percolates the tailing is retained in ponds and is used in the industrial process. The inclination of the side of the hill is less than eighteen percent (18 %), which enhances the efficiency of rain water drainage.

The liquid effluent of milling is stored in ponds constructed with high density plastic sheets; with drainage pipes in the bottom were the solid particles of the effluent are separated from the liquid part. This liquid part returns to the mill process and the

solid part is kept stored in the pond. After the pond is filled up the decommissioning process will start. The liquid effluent will evaporate and the dry waste will be isolated from the environment. The uranium concentrate unit will produce a total of 7,200 tons of dry waste during unit life time (400 tons/y). A layer of top soil will cover the pond and the surface will be re-vegetated.

#### **D.4 - NAVY INSTALLATIONS at SÃO PAULO (CTMSP) and IPERÓ (CEA)**

The waste volume generated by these activities is very small when compared to the figures mentioned above. All the material is currently kept on an initial storage on both sites.

At CTMSP headquarters, the radioactive waste, consisted mainly of contaminated laboratory material, is transferred to IPEN, situated on a contiguous site.

At CEA, an initial waste storage facility is available in the form of a warehouse. One hundred and eleven drums containing about 9,183.8 kg of waste are currently stored in the aforementioned facility. These are mainly contaminated materials such as plastic, paper and tools (See also **H.2.3**).

#### **D.5 - CNEN INSTITUTES**

##### **D.5.1 - IPEN**

The Radioactive Waste Management Department (GRR) was formally created in 2003 as a new research center of the Institute for Energy and Nuclear Research (IPEN), in order to perform research and development, teaching and waste treatment activities in the field of radioactive waste. The GRR is in charge of treating and temporarily storing the radioactive waste generated at IPEN, as well as those generated at many other radioactive facilities all over the country. The main features of the laboratory include units for: waste reception and segregation; decontamination; liquid waste immobilization and conditioning; in-drum compaction of compressible solids; spent sealed sources and lightning rods disassembly; primary and final waste characterization; storage of untreated and treated waste. For further description, see item **H.2.4.1**.

##### **D.5.2 - CDTN**

Besides the radioactive waste generated in its own laboratories, the Nuclear Technology Development Center (CDTN) has received disused sealed sources from other users, like industries, hospitals and universities. These sources include radioactive lightning rods, smoke detectors, nuclear gauges and teletherapy units, among others, which are stored at CDTN's interim storage facility - Sealed Sources and Treated Waste Storage Facility (DFONTE) (see **H.2.4**, Table J2 and Annex 1). As of December 2010, 1,796 disused sealed sources, 2,953 lightning rods, 3,478 smoke detectors, and ninety five 200-liter drums of treated wastes of very low activity were stored at the facility. The total

activity is  $1.83 \times 10^8$  MBq, and the volume occupied was about 21% of the total. In addition,  $3.4 \text{ m}^3$  ( $4.0 \times 10^6$  MBq) of untreated liquid wastes were in the Initial Storage Room.

The strategy implemented for the management of radioactive waste at CDTN is based on the standard CNEN-NE-6.05 and takes into account the available infrastructure. The main directives of the management program are:

- To register the waste and disused sealed source inventory using an electronic database.
- To minimize the waste generation by suitable segregation and characterization.
- To reduce the volume by chemical treatment of the aqueous liquid waste, and by compacting and cutting the solid waste;
- To solidify by cementation the sludge arising from the chemical treatment, and to immobilize the non-compactable solid waste in cement/bentonite.

### D.5.3 - IEN

Up to 2007, the Nuclear Engineering Institute (IEN) had a small area ( $120 \text{ m}^2$ ) for storage of radioactive waste. In that year, the building of a new storage installation was completed, expanding the actual capacity of storage. This new installation has a total area of  $972 \text{ m}^2$  and a net storage area of  $324 \text{ m}^2$ . IEN stores waste that has similar characteristics to the waste received at the other CNEN storage installations. Additionally, IEN also stores the radioactive waste generated in its own installations.

### D.5.4 – CRCN-CO

The Midwest Regional Center for Nuclear Sciences (CRCN-CO) has also a small interim storage facility for radioactive waste collected in the Midwest region (Figure D.3). This waste is periodically transferred to CDTN.



**Figure D.3** - Interim storage facility at CRCN-CO

**D.5.5 -- LAPOC**

The Poços de Caldas Laboratory (LAPOC) has an access-controlled room with area of 31.5 m<sup>2</sup> that contains medical and industrial radioactive sources, lightning rods and smoke detectors collected in the southern state of Minas Gerais. These sources should be transferred to CDTN or IPEN Institutes.

In this room are also stored radioactive materials collected in police apprehension and others residues from research activities listed in the Table D.6.

**Table D.6 - Waste stored at LAPOC**


| <b>RAD</b>       | <b>Type of Source</b>  | <b>Quant</b> | <b>Total Activity (Bq)</b> | <b>Date of Storage</b> |
|------------------|--|--------------|----------------------------|------------------------|
| Th-232           | Mesothorium/<br>residue  | 825 kg       | 1.06E+17                   | 1990                   |
| U-238            | Ammonium<br>uranium oxide<br>(NH <sub>4</sub> ) <sub>2</sub> U <sub>2</sub> O <sub>7</sub> | 345 L        | 1.1E+16                    | 1995                   |
| U-238            | Ammonium<br>uranium oxide<br>(NH <sub>4</sub> ) <sub>2</sub> U <sub>2</sub> O <sub>7</sub> | 37 kg        | 1.4E+16                    | 1995                   |
| U-238/<br>Th-232 | Mineral Uranium<br>Thorianite  | 2,450 kg     | 8.5E+13                    | 2007                   |
| Am-241           | Smoke detectors  | 10           | 2.3E+5                     | 1995 - nowadays        |
| Am-241           | lightning rods   | 91           | 9.1E+9                     | 1995 - nowadays        |
| <b>TOTAL</b>     |  |              | <b>1.17E+17</b>            |                        |

**D.6 - WASTE REPOSITORY AT ABADIA DE GOIAS (Closed)**

The waste generated in the decontamination process following the radiological accident with a <sup>137</sup>Cs medical source in Goiânia is currently stored in a final repository at Abadia de Goiás, a small town circa 23 km from Goiânia.

Approximately 3,150 m<sup>3</sup> of waste were generated, with an estimated overall activity lying between 47.0 TBq (1,270 Ci) and 49.6 TBq (1,340 Ci). The waste was temporarily stored in open-air concrete platforms, occupying an area of about 8.5 x 10<sup>6</sup> m<sup>2</sup> at a site near the village of Abadia de Goiás. (Figure D.4)





**Figure D.4 - Temporary storage**

The drums and the metal boxes containing waste were classified into five groups, taking into account the decay period needed for the contents of the package to reach a  $^{137}\text{Cs}$  concentration level not greater than 87 Bq/g, as described on Table D.7.

**Table D.7 - Waste from Goiânia Accident**

| GROUP<br>(Time - years)      | Number<br>Metallic<br>Boxes | Volume<br>(m <sup>3</sup> ) | Number<br>of Drums | Volume<br>(m <sup>3</sup> ) | Storage<br>Activity *<br>(TBq) | Total<br>Volume<br>(m <sup>3</sup> ) | Current<br>Activity **<br>(TBq) |
|------------------------------|-----------------------------|-----------------------------|--------------------|-----------------------------|--------------------------------|--------------------------------------|---------------------------------|
| <b>I</b><br>(t=0)            | 404                         | 686.8                       | 2,710              | 542                         | 0.06                           | 1,228.80                             | 0.0288                          |
| <b>II</b><br>(0 < t < 90)    | 356                         | 605.2                       | 980                | 196                         | 0.476                          | 801.20                               | 0.2282                          |
| <b>III</b><br>(90 < t < 150) | 287                         | 487.9                       | 314                | 62.8                        | 1,44                           | 550.70                               | 0.6904                          |
| <b>IV</b><br>(150 < t < 300) | 275                         | 467.5                       | 217                | 43.4                        | 13.67                          | 510.90                               | 6.5542                          |
| <b>V</b><br>(t > 300)        | 25                          | 42.5                        | 2                  | 0.4                         | 30                             | 42.90                                | 14.4145                         |
| <b>Total</b>                 | 1,347                       | 2,289.9                     | 4,223              | 844.6                       | 45.71                          | 3,134.50                             | 21.9161                         |

NOTE: \* Storage Activity: at the time of storage / \*\* Current Activity: as of March 2011.

The following packages were also used in Goiânia:

- 1 metal package for the headstock, with the remaining source (4.4 Tbq and with 3.8 m<sup>3</sup>, of Group V);
- 10 ship containers (374 m<sup>3</sup>, with 0.4 TBq, from Group I); and
- 8 special concrete packages (1.4 m<sup>3</sup>, with 0.7 Bq, from Group V)

According to the IAEA classification, all the radioactive waste collected in Goiânia falls into the category of “low level - short lived” waste and this allows its disposal at shallow depths, in engineered storage facilities. The Group I waste, having specific activities below 87 Bq/g, could actually be exempted from regulatory control – which means that it could effectively have been released into ordinary waste systems.

Nevertheless, it was decided to build two repositories in Goiânia: a more simplified one, called Great Capacity Container (Figure D.5.a) for the disposal of Group I waste (about 40% of the total) and a repository with more elaborate engineered barriers for the disposal of Groups II to V waste, called Goiânia Repository (Figure D.5.b).



(a)

(b)

**Figures D.5** - (a) Great Capacity Container, (b) Repository at Abadia de Goiás

In conclusion, the problem of providing final disposal for the waste generated in the Goiânia Accident is thoroughly addressed. All the waste has been disposed of in two near surface repositories, which have already been closed and with environmental restoration performed. More information on the Environmental Monitoring Program (PMA) for the repository is provided in Section **H.7** of this document.

## SECTION E - LEGISLATIVE AND REGULATORY SYSTEM


### E.1 - IMPLEMENTING MEASURES (*Article 18*)

Brazil has taken legislative, regulatory and administrative measures to ensure the safety of its nuclear facilities, including spent fuel and radioactive waste facilities.

The Federal Constitution of 1988 establishes the distribution of responsibilities among the Union, the states, the federal district and the municipalities with respect to the protection of the public health and the environment, including the control of radioactive products and installations (Articles 21, 22, 23 and 24). The Federal Government is the sole responsible for nuclear activities related to electric power generation, and also for regulating, licensing and controlling nuclear safety (Articles 21 and 22). The National Commission for Nuclear Energy (CNEN) is the national regulatory body, in accordance with the National Nuclear Energy Policy Act (Law 4118/62).

Furthermore, the constitutional principles regarding protection of the environment (Article 225) require that any installation which may cause significant environmental impact shall be subject to environmental impact studies that shall be made public. More specifically, for nuclear facilities, the Federal Constitution (Article 225, paragraph 6) provides that a specific law shall define the site of any new nuclear reactor facility. Therefore, nuclear installations are subject to both a nuclear license by CNEN and an environmental license by the Brazilian Institute for Environment and Renewable Natural Resources (IBAMA), which is the national environmental agency, with the participation of state and municipal environmental agencies as stated in the National Environmental Policy Act (Law 6938/81). These principles were established by the Federal Constitution of 1988, when Angra-1 was already in operation, and Angra-2 was in construction. Hence, licensing of these power plants followed slightly different procedures, as described below.

CNEN is located within the structure of the Ministry for Science and Technology (MCT). The relation amongst regulatory organizations and operators is shown in Figure E.1.



**Figure E.1** - Brazilian Organizations Involved in Nuclear Safety

### E.1.1 - NUCLEAR LICENSING PROCESS

CNEN was created in 1956 (Decree 40110 of 10/10/1956) to be responsible for all nuclear activities in Brazil. Later on, CNEN was re-organized and its responsibilities were established by Law 4118 of 1962 with alterations determined by Laws 6189 of 1974 and 7781 of 1989. Thereafter, CNEN became the Regulatory Body in charge of regulating, licensing and controlling nuclear activities. Since 2000, CNEN has been under the Ministry for Science and Technology (MCT).

CNEN responsibilities related to this Convention include:

- the preparation and issuance of regulations on nuclear safety, radiation protection, radioactive waste management, nuclear material control and physical protection;
- licensing and authorization of siting, construction, operation and decommissioning of nuclear facilities;
- regulatory inspection;
- acting as a national authority for the purpose of implementing international agreements and treaties related to nuclear safety, security and safeguards;
- participating in activities related to the national preparedness and response to nuclear emergencies.

Under this framework, CNEN has issued radiation protection regulations and regulations for the licensing process of radioactive and nuclear facilities, safety, security and nuclear material control during operation, management of radioactive waste, siting of waste repositories, quality assurance, reporting requirements, plant maintenance, and others (see item **L.2.3** of Annex II for a list related of CNEN regulations).

The licensing regulation CNEN-NE-1.04 [3] establishes that no nuclear installation shall operate without a license. It also establishes the necessary review and assessment process, including the specification of the documentation to be presented to CNEN at each phase of the licensing process. It finally establishes a system of regulatory inspections and the corresponding enforcement mechanisms to ensure that the licensing conditions are being fulfilled. The enforcement mechanisms include the authority of CNEN to modify, suspend or revoke the license.

The licensing process is divided in several steps:

- Site Approval;
- Construction License;
- Authorization for Nuclear Material Utilization;
- Authorization for Initial Operation (AOI);
- Authorization for Permanent Operation (AOP);
- Authorization for Decommissioning

Federal Law 9765, approved in 1998, establishes taxes and fees for each individual licensing step, as well as for the routine work of supervision of the installation by CNEN.

For the first step, site selection criteria are established in Resolution CNEN 09/69 [4], taking into account design and site factors that may contribute to violation of established dose limits at the proposed exclusion area for a limiting postulated accident. Additionally, by adopting the principle of “proven technology”, CNEN regulation NE-1.04 [3] requires for site approval the adoption of a “reference plant” for the nuclear power plant to be licensed.

For the construction license, CNEN performs a detailed review and assessment of the information received from the licensee in a Preliminary Safety Analysis Report (PSAR). The construction is followed closely by a system of regulatory inspections.

For the Authorization for Initial Operation (AOI), CNEN reviews the construction status, the commissioning program including results of pre-operational tests, the final Physical Protection Plan, updates its review and assessment of facility design based on the information submitted in the Final Safety Analysis Report (FSAR), and authorizes the nuclear material utilization. Startup is closely followed by CNEN inspectors, and hold points at different stages are established.

Authorization for Permanent Operation (AOP) is given after a complete review of commissioning test results and the solution of any deficiencies identified during construction and initial operation. The authorization establishes limits and conditions for operation and lists the programs which should be kept active during operation, such as

the radiological protection program, the physical protection program, the quality assurance program for operation, the fire protection program, the environmental monitoring program, the qualification and training program, the preventive maintenance program, the retraining program, etc. Reporting requirements are also established through regulation CNEN-NE-1.14 [5] and CNEN-NN-2.02 [19]. These reports, together with a system of regulatory inspections performed by resident inspectors and headquarters personnel, are the basis for monitoring safety and nuclear material control during operation.

The main tasks during the licensing process are the safety evaluation of the applicant documentation and the regulatory inspections. During the period of 2008-2010, 196 Evaluation Reports were issued related to Angra-1 and Angra-2 (109 were related to Angra-1, 58 related to Angra-2 and 29 for issues related to both units), out of which 35 were related to radioactive waste area. Regarding regulatory inspections, 64 ones were conducted in both units, 32 in Angra-1, 17 in Angra-2 and 15 for issues related to both units. Of these, 7 were related to the radioactive waste area. Also for Angra-3, under construction, 78 Evaluation Reports were issued and 8 regulatory inspections were conducted.

Other governmental bodies are involved in the licensing process, through appropriate consultations. The most important ones are the Brazilian Institute for Environment and Renewable Natural Resources (IBAMA), which is in charge of environmental licensing, and the coordination of the Nuclear Scientific and Technical Program of the Ministry for Science and Technology (PTCN/MCT) with respect to emergency planning aspects.

### **E.1.2 - ENVIRONMENTAL LICENSING PROCESS**

IBAMA was created on February 22<sup>nd</sup> 1989, by Law 7735 under the Ministry for Environment (MMA) with the responsibility to implement and enforce the National Environmental Policy (PNMA) established by Law 6938 of 1981. The objectives of the PNMA are to preserve, improve and recover environmental quality, ensuring the conditions for social and economic development and for the protection of human dignity. The PNMA established the National System for the Environment (SISNAMA), which is composed by the National Council for the Environment (CONAMA) and executive agencies at the federal, state and municipal levels.

Environmental licensing is a legal obligation prior to the installation of any project or activity that exploits natural resources and has a potential to pollute or degrade the environment. The environmental licensing enforcement is shared by the environmental agencies of Brazil's States and IBAMA at the federal government level. IBAMA is the agency tasked with the licensing of large projects involving impacts on more than one Brazilian state and activities of the oil and gas sectors on the continental shelf. IBAMA also carries out the licensing of the environmental component of activities and projects related to prospecting, mining, producing, processing, transporting, storing and disposing of radioactive materials at any stage or using nuclear energy in any of its forms and applications.

The regulation of nuclear activities remains with the Federal Government. The *nuclear licensing* and the *environmental licensing*<sup>1</sup> processes are independent, parallel, and complementary acts. CNEN, a federal agency, through its Directorate of Radiation Protection and Nuclear Safety, is the Regulatory Body in charge of *nuclear licensing*, which consists of regulating, licensing and controlling nuclear activities in Brazil, enforcing Nuclear Safety, Security and Safeguards. IBAMA is responsible for the environmental licensing of any installation with potentially significant socioenvironmental impact and risk, including the nuclear installations.

In the environmental licensing process, possible direct and indirect impacts of a project imposed to the external environment and communities are assessed. These include: the physical aspects (geology, hydrogeology, climate, water availability), atmospheric emissions (radioactive and conventional), and chemical generation and control of liquid and gas effluents; the interactions with biotic system (marine and terrestrial fauna and flora) and possible incorporations (bioaccumulation, toxicity); and the socioeconomic and health implications to the human populations in the vicinity of the project.

The main guidelines for the implementation of the environmental licensing are expressed in the Law 6938 of 1981 and the CONAMA Resolutions 001/86 and 237/97. The environmental licensing process includes the following steps:

- Prior License (LP), granted at the preliminary planning stage, approving the general concept of the installation and place, evaluating its environmental feasibility, and establishing the basic requirements and conditions for the next implementation phases.
- Installation License (LI), authorizing the construction of the installation in accordance with the approved specifications, programs and projects - including measures that are considered essential to protect the environment and human populations.
- Operation License (LO), authorizing the operation of the installation after the verification of the effective fulfillment of the previous license conditions, and the effective implementation of measures to protect the environment and human populations during operation.

Among the requirements for issuing a Prior License, three technical reports are presented by the project's proponent to provide IBAMA with a comprehensive set of information to support the decision-making process: an Environmental Impact Study (EIA), an Environmental Impact Report (RIMA), and a quantitative Risk Assessment (EAR) for the external public and environment.

Public participation in the environmental licensing process is ensured by legislation through public hearings prior the issuing of the Prior License (CONAMA Resolution 09/87). One of the requirements is transparency in the process, through the dissemination in official newspapers and local press of any hearing scheduled, license application made and decisions of the environmental agency.

---

<sup>1</sup> IBAMA is responsible for the Environmental Licensing, as stated in the National Environmental Policy Act, while CNEN is the nuclear regulatory body in accordance with the National Nuclear Energy Legislation.

### E.1.2.1 - Environmental Licensing of Angra-1 and 2 Radioactive Waste Storage Facilities

The construction of Angra-1 and Angra-2, including the radioactive waste stored on site, took place before the creation of IBAMA. The operation of Angra-1 started in 1981, before the current environmental regulation was established.

At that time, the State Foundation for Environment Engineering (FEEMA), now called Rio de Janeiro State Institute for Environment (INEA), the Rio de Janeiro state agency in charge of environmental matters, issued an Installation License.

Since 1989, with the definition of the legal competence of IBAMA for environmental licensing of nuclear installations, with the participation of CNEN and state and local environmental agencies, IBAMA has been involved in the licensing procedure of the Angra-1 and 2 radioactive waste storage facilities.

Currently the low and intermediate radioactive waste from the nuclear power plants are stored in three storage facilities named Storage Facility 1, 2 and 3 of the Radioactive Waste Management Centre - CGR (see Figures H.1), under operation, with Storage Facility 1 and module 2B under licensing regularization by IBAMA.

Storage Facility 1 entered operation in 1981, with the operation of Angra-1 and is almost completely full (Figure E-2). Storage Facility 2A also contains waste from Angra-1. Both storage facilities are “initial” in nature, since the radioactive wastes should be later removed to a final repository. For both storage facilities, Eletrobras Eletronuclear (ETN) has submitted basic documentation that will permit IBAMA to assess the environmental impact of their operation. This documentation will also serve as a basis to define plans and programs detailed in an Environmental Control Plan (PCA) for obtaining a formal Operating License, according to the current regulation.



**Figure E.2** - Angra-1 and 2 Radioactive Waste Storage Facilities

The operator has requested the expansion of the storage capacity of the site through the construction of a third storage facility (Storage Facility 3) at the same location. The Environmental Impact Study (EIA) and the Environmental Impact Report (RIMA) were prepared and submitted to IBAMA.



The RIMA served also as a basis for the public hearings, which took place in the surroundings of the plant, within the environmental licensing process. Based on these evaluations and taken into consideration the discussion during the hearings, IBAMA issued the Installation License. ETN obtained the IBAMA Operation License for this facility in February 2009.

#### **E.1.2.2 - Environmental Licensing of the Repository at Abadia de Goiás**

The repository at Abadia de Goiás, which belongs to CNEN, has received an Installation License from IBAMA in 1996. At present, IBAMA is following up the initial operation of the repository through reports and inspections. An Environmental Plan including air samples, sediments samples, surface water and underground water as well as external radiation doses around the two repositories has been executed every year since its construction. Further details of this environmental plan can be found under item **H** of this report.

#### **E.1.2.3 - Other Pre-existing Storage Facilities**

Other pre-existing radioactive waste storage facilities that are now also being licensed by IBAMA, are located at IPEN, CDTN and IEN (see **D.5.** and **H.2.4.**).

In 2002, IBAMA licensed CDTN facilities, including the Sealed Sources and Treated Waste Storage Facility (DFONTE) (IBAMA Operation License 225/2008, of 8 August 2002). On 28 November 2006 this license was renewed for additional six years. Since this license expires in 2012, a CDTN's team has already begun the necessary actions to renovate it.

The other two storage facilities are in a process of compliance of the existing situation with the current legislation, to obtain an Operating License. This is done through a *Commitment Agreement*, in which the organization commits itself to fulfill specific requirements established by IBAMA.

At IPEN, the existing storage for treated waste is being restructured to receive 850 m<sup>2</sup> of extra area, divided into two sheds. The first shed was concluded in 2010 and treated waste was transferred from the old building to the new one (Figure K.1). The second shed will be concluded by July, 2011 to receive untreated wastes. It is noteworthy that in the reported period 113 neutron sources were repatriated to Los Alamos National Laboratory (USA), as part of cooperation program between CNEN and IAEA.


#### **E.1.3 - EMERGENCY PREPAREDNESS LEGISLATION**

With respect to emergency preparedness, additional requirements have been established by the creation of the System for Protection of the Brazilian Nuclear Program (SIPRON).

SIPRON was established by Law 1809 of 7 October 1980. The subsequent Decree 2210 of 22 April 1997 established the Secretariat for Strategic Affairs (SAE), directly

linked to the Presidency of the Republic, as the Central Organization of SIPRON responsible for the general supervision of the preparedness and response to nuclear emergencies in the Country. In May 2003, a Governmental restructuring through Law 10683, has designated the Ministry for Science and Technology (MCT) as the state department with competence for nuclear energy policy and, as consequence, SIPRON remained under the Coordination of Nuclear Scientific and Technical Program (PTCN) of MCT. However, since 2009, a new Governmental restructuring has designated the Institutional Security Cabinet of the Presidency of the Republic (GSI/PR) as the Central Organization for SIPRON.

The SIPRON's structure includes organizations at the federal, state and municipal levels involved with licensing and control activities as well as those involved with public safety and civil defense. Operators of nuclear installations and facilities and supporting organizations are also part of SIPRON (see Figure E.3).



**Figure E.3 - SIPRON Structure**

The Decree 2210 of 1997 also established a Coordination Commission for the Protection of the Brazilian Nuclear Program (COPRON) composed of representatives of the agencies involved. Besides Eletrobras Eletronuclear (ETN), as the operator, and CNEN, as the nuclear regulatory body, other agencies are involved as support organizations of SIPRON, such as the municipal civil defense, the state civil defense, the Angra Municipality, the IBAMA, the National Road Authority, the National Army, Navy and Air

Force, and the Ministries of Health, External Relations, Justice, Finance, Planning and Budget, Transportation and Communications.

Within SIPRON, the Central Organization issued a set of General Norms for Emergency Response Preparedness [13, 14], consolidating all requirements of related national laws and regulations. These norms establish the planning, the responsibilities of each of the involved organizations and the procedures for the emergency management centers, communications, intelligence and information to the public (SIPRON General Norms are listed in item **L.2.5** of Annex II).

## **E.2 - LEGISLATIVE AND REGULATORY FRAMEWORK (*Article 19*)**

Brazil has established and maintained the necessary legislative and regulatory framework to ensure the safety of its nuclear installations, including irradiated fuel and radioactive waste. A list of existing norms and regulations is presented in Annex 2.

As mentioned before, the Law 10308 of 20 November 2001 establishes the new legal framework for the solution of the radioactive waste issue in Brazil.

The Law confirms Government responsibility for the final destination of radioactive wastes, through the action of CNEN. However, it also opens the possibility for the delegation of the administration and operation of the radioactive waste storage facilities to third parties.

The Law defines four types of storage facilities: initial, operated by the waste generator; intermediate; final (also called repository); and temporary, which may be established in case of accidents with contamination.

The Law establishes the rules for site selection, construction and operation, and licensing and control of the storage facilities by CNEN. The Law also establishes the financial arrangements for the transfer of waste to CNEN and the compensation to the municipalities that accept in their territory the construction of radioactive waste storage facilities.

Additional regulations from CNEN related to waste disposal were already in place and are being revised to conform to the new Law 10308. These include regulations CNEN-NE-6.05 on Management of Radioactive Waste in Radioactive Installations [6], CNEN-NE-6.06 on Site Selection for Radioactive Waste Storage Facilities [7], and CNEN-NN-6.09 on Acceptance Criteria for Final Disposal of Low and Intermediate Level Radioactive Waste [23].

## **E.3 - REGULATORY BODY (*Article 20*)**

As mentioned in item **E.1.1**, the National Commission for Nuclear Energy (CNEN) has been designated as the regulatory body entrusted with the implementation of the legislative framework related to safety of nuclear and radioactive installations. Other

governmental bodies are also involved in the licensing process, such as the Brazilian Institute for the Environment and Renewable Natural Resources (IBAMA).


### **E.3.1 - CNEN**

CNEN authority is a direct consequence of Law 4118/62, which created CNEN, and its alterations determined by Laws 6189/74 and 7781/89. These laws established that CNEN has the authority “to issue regulations, licenses and authorizations related to nuclear installations”, “to inspect licensed installations” and “to enforce the laws and its own regulations”.

Effective separation between the functions of the regulatory body (CNEN) and the organization in charge of the promotion and utilization of nuclear energy for electric power generation (Eletrobras Eletronuclear - ETN) is provided by the structure of the Brazilian Government in this area. While CNEN is linked to the Ministry for Science and Technology (MCT), ETN is fully owned by ELETROBRAS, a state holding company of the electric system, which is under the Ministry for Mines and Energy (MME) (see Figure E.1).

The structure of CNEN is presented in Figure E.4. The organizational unit involved with the regulating, licensing and controlling of nuclear activities is the Directorate for Radiation Protection and Nuclear Safety (DRS). Review and assessment is performed mainly by the General Coordination of Nuclear Reactors (CGRC), which is in charge of nuclear power plants and research reactors, by the General Coordination of Nuclear Fuel Cycle (CGCN), which is in charge of other nuclear installations, and by the Safeguards and Physical Protection Coordination (COSAP). The General Coordination for Medical and Industrial Installations (CGMI) is in charge of radioactive installations and medical uses. The Radioactive Waste Coordination (COREJ) is responsible for controlling radioactive waste management and for licensing of disposal facilities. The regulations and standards are developed by working groups under the coordination of the Norms Division (DINOR). In the areas of radiation protection and environmental monitoring, technical support is obtained from the CNEN’s Institutes under the Directorate for Research and Development - DPD.

Adequate human resources are provided to CNEN. A total staff of 2,635 people, out of which 85% are technical staff, is available at CNEN and its research institutes. Sixty one percent (61%) of the staff is comprised of university graduates, 18% having a master degree and 21% having a doctoral degree. DRS has 224 people in technical staff: 95 with college degrees, 69 with master degree and 60 doctoral degree.



**Figure E.4 - Simplified CNEN Organization Chart**

The main activities are review and assessment of the submitted documentation, and inspection of licensee’s activities. Inspection activities are conducted periodically for all installations and on a permanent basis for the nuclear power plants, enrichment facility and the uranium mine by resident inspectors at the respective sites. Complementary to field activities, operation follow up and nuclear material control are

performed also based on licensee reports, as required by licensing conditions and regulations CNEN-NN-1.14 [5] and CNEN-NN-2.02 [19].

DRS technical staff receives nuclear general training and specific training according to the field of work, including both academic training and course attendance, technical visits, participation in congresses and national and international seminars.

Financial resources for CNEN are provided directly from the Government budget. Since 1998, taxes and fees are being charged to the licensees, but this income is deducted from the Government funds allocated to CNEN.

Salaries of CNEN staff are subject to the Federal Government policies and administration.

### E.3.2 - IBAMA

The structure of IBAMA is presented in Figure E.5.





Figure E.5 - IBAMA Structure

The environmental licensing for nuclear installation is carried out by the Directorship of Environmental Licensing (DILIC) at the Coordination for Electrical Power, Nuclear Energy and Pipelines (COEND) and Coordination for Mining and Other Infra-Structure Projects (COMOC). The structure of DILIC is presented in Figure E.6.



**Figure E.6 - DILIC Structure**

COEND performs the environmental licensing of the Nuclear Power Plants (NPPs), the nuclear fuel cycle, the nuclear research centers (CNEN and Navy), the radioactive materials deposits, and the transportation of radioactive materials. Currently, COEND is working on the technical analysis necessary for issuing an environmental Operation License (LO) to NPPs Angra-1 and Angra-2: Angra-1 does not hold yet an environmental license, though the plant is operating (Angra-1 was built before the current environmental legislation); while Angra-2 operates based on a term of adjustment of conduct, signed by IBAMA, the Brazilian Federal Public Prosecution, and Eletrobras Eletronuclear (ETN). NPP Angra-3 holds an environmental Installation License (LI) that specifies 46 requirements that must be fulfilled by ETN prior to the issuing of an environmental LO - which includes an analysis of consequence to the external public and environment aiming at an optimization of the Emergency Plan.

Impacts from NPPs Angra-1, 2 and 3 are controlled by environmental programs and monitoring points, located in the region of Angra dos Reis, such as: quality of the drinking water program; quality of the saline waters; quality of the water derived from sewage effluents; control of the marine fauna and flora in the operational phase; control of the plankton (phytoplankton, zooplankton, benthos and nekton) zones; environmental radiological control during operation; sampling and analyses of marine material and livings program; fish, algae, beach sands, platform marine sediments, sea water; sampling and analyses of terrestrial material program, such as cow milk, pasture, runoff water, underground water, river water, diverse plantations (bananas), adjoining soils; sampling and analyses of the air, i.e., particulate, iodine, precipitation; and program of tritium analyses in samples of aquatic sectors (rain and runoff water). In the environmental analysis, direct influence has been established as the radio up to 15 km from the CNAAA (Admiral Álvaro Alberto Nuclear Power Station, in Angra dos Reis), which involves the municipalities of Paraty and Angra dos Reis with a total of 206,845 inhabitants (data from 2010 of the Brazilian Institute of Geography and Statistics - IBGE); and indirect influence as the radio up to 50 km from the CNAAA, which cover sixteen municipalities with a total estimated of 802,749 inhabitants (IBGE - 2010).

COEND is also in charge of the environmental licensing of the Uranium Enrichment and Nuclear Fuel Factory (FEC), located in Resende. The complex comprises three units operated by INB: the Uranium Enrichment Plant and the UO<sub>2</sub> Producing Pellets Plant - both hold environmental Operation Licenses (LOs) and programs for environmental control are in course; and the Nuclear Fuel Assembly Plant that does not hold a valid environmental license - COEND is currently working in the regularization of the plant.

COMOC carries out the environmental licensing of uranium mines in the municipalities of Santa Quitéria and Caetité and the decommissioning activities of the Ore Treatment Unit of Poços de Caldas (UTM):

- The Santa Quitéria project consists of the exploration and processing of phosphate ore, associated with uranium in a deposit owned by INB (Brazilian Nuclear Industries). COMOC has recently issued a draft of the Terms of Reference for the elaboration of an environmental impact assessment and an environmental impact report, studies that will provide IBAMA with technical information for the decision making of a Prior Licensing (LP).
- The Caetité's unit of concentrate uranium (URA) comprises a mine and a processing plant, whose final product is U<sub>3</sub>O<sub>8</sub> in the form of ammonium diuranate (yellow cake). The URA has already been granted an LO and COMOC recently issued an LI allowing the setup and conversion of the open-pit mining into an underground mode of mining.
- The Mining-Industrial Complex of the Poços de Caldas Plateau (CIPC), now renamed to Ore Treatment Unit of Poços de Caldas (UTM), is currently undergoing decommissioning. COMOC is working on the development of an environmental monitoring program for the site, establishing September 2011 as the deadline to UTM present IBAMA with the final version of a program for rehabilitation of the degraded areas.



## SECTION F - OTHER GENERAL SAFETY PROVISIONS

### F.1 - RESPONSIBILITY OF LICENCE HOLDER (*Article 21*)

The Brazilian legislation defines the operating organization as the prime responsible for the safety of a nuclear or radioactive installation, including the management of spent fuel and radioactive waste.

Therefore, to obtain and maintain the corresponding licenses, the operating organization must fulfill all the requirements established in the legislation and in the ensuing regulations listed in Annex 2.

#### F.1.1 - NUCLEAR POWER PLANTS

In the case of nuclear power plants, the regulation CNEN-NE-1.26 [8] defines the operating organization as the prime responsible for the safety of a nuclear installation by explicitly stating: **“The operating organization is responsible for the implementation of this regulation.”**

Eletronuclear S.A. - Eletronuclear (ETN), as the owner and operator of the Angra-1 and Angra-2 plants, and Angra-3 (under construction), has issued an Integrated Safety Management Policy stating its commitment to safe operation, as follows:

Eletronuclear (ETN) is committed to clean power generation and high safety standards.

Therefore, its staff commitment to perform all safety-related activities in an integrated manner is essential, laying emphasis upon Nuclear Safety, which includes Quality Assurance and Environmental as well as Occupational Safety, Occupational Health and Physical Protection.

The following principles must be heeded:

1. Nuclear Safety is a priority, precedes productivity and economic aspects and should never be impaired for any reason.
2. Legal requirements and other requirements related to the various integrated safety aspects should be complied with.
3. Personnel and service supplier qualification training should ensure knowledge on the various integrated safety aspects required for proper performance of safety-related work.
4. People health and safety hazards and also environmental impacts should be preventively minimized or eliminated.
5. Communication procedures inside and outside the Company should be transparent and appropriate so that any unsafe condition can be promptly reported.

6. The Company should seek to improve continuously its Integrated Safety Management practices.

For the proper implementation of this safety policy, ETN established a program comprising all levels of the organization that complies with the concept included in the IAEA's document Safety Series 75, INSAG 4, of the International Nuclear Safety Group (INSAG), in line with the safety objectives and requirements, considering the appropriate management structures, the necessary resources, training, adequate self-assessment, external reviews and human performance programs and tools with good results in the last years.

CNEN, through the licensing process, and especially through its regulatory inspection program, ensures that the regulatory requirements for safe operation are being fulfilled by the licensee. The licensee reports periodically to CNEN in accordance with regulation CNEN-NE-1.14 [5]. In addition, CNEN maintains a group of resident inspectors on the site, who can monitor licensee performance on a daily basis. Finally, a number of regulatory inspections by headquarter staff take place every year, focusing on specific topics or operational events.

#### **F.1.2 - INB FACILITIES**

As the organization responsible for the operation of its Industrial Units, INB prioritizes safety in all of its activities as a basic principle. As the oversight body, CNEN maintains a program of constant inspections in addition to a resident inspector in INB facilities, whose job it is to track the operating routine of the units and report any occasional abnormality. Internal audits in the areas of Quality Assurance, Environment and Workplace Safety are routinely performed in all facilities in order to detect any situation that may represent an unsafe operating condition. Additionally, with a view to enhancing safety culture in the company, INB accepted the invitation extended by the International Atomic Energy Agency (IAEA) to cooperate in project SEDO (Safety Evaluation During Operation), the results of which will serve as parameters for application to other manufacturing facilities of member countries of the IAEA. The IAEA SEDO safety review mission took place in April-May-2007 comprising 43 recommendations for the safety management improvement. A follow-up mission was held in October-2010 and the results were 7 recommendations totally fulfilled, 6 recommendations not satisfactorily addressed and 30 recommendations being fulfilled and considered satisfactorily addressed.

As will be mentioned in Section **F.3.4**, the FCN Resende unit has implemented systems which are certificated in the areas of quality assurance, environment and occupational safety, collaborating with the security system of the company.

Furthermore, at the request of INB, the IAEA assembled a Uranium Production Site Appraisal Team (UPSAT) to assist INB to improve the operational and safety performance of its uranium production facility of Caetité. This mission was a peer review based on the IAEA Safety Standards and world best practices.

## F.2 - HUMAN AND FINANCIAL RESOURCES (*Article 22*)

### F.2.1 - HUMAN RESOURCES

#### F.2.1.1 - Nuclear Power Plants

Adequate human resources are available at Eletrobras Eletronuclear (ETN) with its own personnel or from contractors. Currently ETN has a total of 2,560 employees on its permanent staff, distributed as follows:

- 814 (32%) have a university degree;
- 981 (38%) are technicians;
- 234 (9%) are managers, most of them with a university degree;
- The remainder 531 (21%) are administrative personnel.

A Project called "Determination of the Technological Know-how of Eletrobras Eletronuclear" was initiated in 2001, which aimed at the identification, in a formalized and systematic way, of the existing know-how within the company. In particular, loss of knowledge due to personnel retirement was the most important aspect of this program. This was a pilot project with the main objective of introducing Knowledge Management as a systematic approach in the company, in order to preserve the essential knowledge necessary for the safe and efficient construction and operation of its nuclear installations.

The planned actions within this program have been accomplished. The major knowledge gaps have been identified and actions to fulfill these gaps are being implemented. The results are available for further routine use by the different technical organization units of the company.

An important new activity in the content of Knowledge Management is the involvement of ETN in the development, conducted by the holding company ELETROBRAS, of a Corporate University that will serve the several affiliated utilities.

Activities related to qualification, training and retraining of plant personnel are performed by the Training and Simulator Department of ETN. Three main areas exist at the training facilities, close to the site:

- General Training Center
- Angra-2 Simulator Training Center
- Maintenance Training Center.

Two additional blocks (~700 m<sup>2</sup>) for classroom and mechanical, electrical and I&C maintenance labs training are being finished, to support identified needs of better practical maintenance training and additional classroom space for the Angra-3 personnel.

The existing Angra-2 simulator is undergoing a major hardware and software upgrade with completion planned for the end of 2011.

Furthermore, the process of implementation of two additional fullscope simulators is under way, one for the Angra-1 NPP, whose operators have been up to now trained abroad and one for the Angra-3 NPP, presently under construction. Both simulators are expected to be completed in 2014.

The requirements for organization and qualification of Angra-1, Angra-2 and now Angra-3 staff are established in chapter 13 of the respective FSARs. Implementation and updating of these requirements are subject to CNEN audits.

Specialized training is also provided for the different groups of plant personnel, as listed below:

- Maintenance and Chemistry personnel follow an extensive qualification program established in the Plant Operations Manual, which is subject to CNEN audits.
- Radiological Protection technicians, the Fire Brigade and Security personnel follow an extensive qualification program based on CNEN regulations, which is also subject to CNEN audits.

A detailed training program for the Angra-3 future staff was developed. To date more than 200 new employees are in classroom or on-the-job training. The training duration depends on the specific position to be occupied by the trainee, varying from 1-2 months up to 2-3 years for licensed operators.

Beyond the requirements of the regulations, it has been a permanent policy of the Operation and Production Directorate to occupy important management positions at the plants with licensed or former licensed operators. Furthermore, key engineers belonging to Technical Support and Outage Planning are receiving SRO training and certification with the dual purpose of acquiring a better knowledge of the operation processes and improving of interfaces between their areas and Operations.

Technical Exchange Visits and Reviews of the training program and training center by experts from the International Atomic Energy Agency, the Institute of Nuclear Power Operations (INPO) and the World Association of Nuclear Operators (WANO) have provided valuable contribution to the identification and implementation of good practices for enhancing the quality of the training activities.

A total of 36 qualified personnel are directly involved in waste and spent fuel management, as described in the Table F.1.

CNEN monitors the adequacy of the human resources of the licensee through the evaluation of its performance, especially through the analysis of the human factor influence on operational events. The training and retraining program is also evaluated by CNEN within the licensing procedure and through regulatory inspections.

**Table F.1** - Personnel involved in spent fuel and radioactive waste management at Angra-1 and Angra-2 NPPs

| Qualification                      | Quantity | Education         |
|------------------------------------|----------|-------------------|
| Radiological Protection Supervisor | 4        | University degree |
| Senior Reactor Operator            | 2        | University degree |
| Nuclear Physicist                  | 2        | University degree |
| Nuclear Engineer                   | 4        | University degree |
| Engineering Support                | 1        | University degree |
| Operators                          | 7        | Technical degree  |
| Radiological Protection Technician | 6        | Technical degree  |
| Auxiliary Technician               | 10       | Secondary         |

Radiation Protection Supervisor certification is done in accordance with regulation CNEN-NN-3.03 "Certification of the Radiation Protection Supervisor Qualification" [9]. There are seven Radiation Protection Supervisors qualified for Angra-1 and Angra-2, and four qualified for Waste Management. Other four Radiation Protection Supervisors are qualified for the Environmental Monitoring Laboratory.

#### F.2.1.2 - INB Facilities

In recent years INB sponsored a number of training events, including a Technology Training Program for twenty-nine engineers, in partnership with the Federal University of Rio de Janeiro. This training program was focused on maintaining the know-how and nuclear technology of the company, in light of the retirement of senior engineers with specific knowledge on the nuclear fuel cycle.

Activities related to training planning and management are a shared responsibility between the Personnel Assignment and Training sections. Three main employee qualification events are normally undertaken:

**Compulsory Courses:** Training programs essential to performing a specific task. The participation on such courses is mandatory, as a consequence of the requirements of control, oversight and licensing bodies.

**Education Scholarships:** Masters Degree, undergraduate and graduate training programs, and foreign language courses. The application of the knowledge acquired in these courses is expected to contribute to improving employee's job performance and the company's results.

**Nonregular courses:** Other personnel training programs as deemed necessary to improve employee's professional performance and the company's results.

At present, INB has a total of approximately 1,120 employees. Table F.2 shows INB regular workforce by location at each of the company units.

**Table F.2** - INB personnel – regular workforce by location

| Location           | University degree | Technical degree | Secondary  | Total        |
|--------------------|-------------------|------------------|------------|--------------|
| Resende, RJ        | 248               | 285              | 90         | 623          |
| Rio de Janeiro, RJ | 108               | 3                | 62         | 173          |
| Caetité, BA        | 33                | 112              | 18         | 163          |
| Buena, RJ          | 6                 | 52               | 18         | 76           |
| Caldas, MG         | 21                | 45               | 6          | 72           |
| São Paulo, SP      | 1                 | 2                | 3          | 6            |
| Fortaleza, CE      | 2                 | 1                | 0          | 3            |
| Santa Quitéria, CE | 0                 | 0                | 2          | 2            |
| Brasília, DF       | 1                 | 0                | 1          | 2            |
| <b>Total</b>       | <b>420</b>        | <b>500</b>       | <b>200</b> | <b>1,120</b> |
| <b>Percentage</b>  | <b>38%</b>        | <b>45%</b>       | <b>18%</b> | <b>100%</b>  |

Table F.3 shows the qualification of INB personnel directly involved with radioactive waste management at Caetité, Buena and Caldas facilities.

**Table F.3** - INB personnel involved in radioactive waste management at Caetité (URA), Buena (UMP) and Caldas (UTM)

| Qualification                       | Quantity | Education         |
|-------------------------------------|----------|-------------------|
| Radiological Protection Supervisor  | 3        | University degree |
| Engineering Support                 | 6        | University degree |
| Radiological Protection Technicians | 8        | Technical degree  |
| Auxiliary Technicians               | 12       | Secondary         |

**Table F.4** shows the qualification of INB personnel involved with radioactive waste management at Resende facilities, where nuclear fuel is manufactured.

**Table F.4** - INB Personnel involved in radioactive waste management at Resende

| Qualification                       | Quantity | Education         |
|-------------------------------------|----------|-------------------|
| Radiological Protection Supervisor  | 2        | University degree |
| Engineering Support                 | 4        | University degree |
| Operators                           | 2        | Technical degree  |
| Radiological Protection Technicians | 15       | Technical degree  |

Certification of radiation protection supervisors is done in accordance with regulation CNEN–NN-3.03 “Certification of Radiation Protection Supervisor Qualification” [9].

### F.2.1.3 - Other Installations

All nuclear or radioactive installations licensed by CNEN must have a certified Radiation Protection Supervisor, authorized in accordance with regulation CNEN-NN-3.03 [9]. The regulation requires different qualification for each different type of installation.

Besides that, sufficient qualified staff should be available for handling radioactive waste. For instance, at IPEN, the staff of the radioactive waste unit is shown on Table F.5, together with the spent fuel management staff.

**Table F.5** - Personnel involved in spent fuel and radioactive waste management at IPEN

| Qualification                       | Quantity | Education         |
|-------------------------------------|----------|-------------------|
| Radiological Protection Supervisor  | 2        | University degree |
| Senior Reactor Operator             | 7        | University degree |
| Physicist                           | 2        | University degree |
| Chemist                             | 4        | University degree |
| Nuclear Engineer                    | 4        | University degree |
| Engineering Support                 | 4        | University degree |
| Operators                           | 14       | Technical degree  |
| Radiological Protection Technicians | 1        | Technical degree  |
| Auxiliary Technicians               | 5        | Secondary         |

At CDTN a total of 27 qualified people are directly involved in waste and spent fuel management. Table F.6 shows the profile of the CDTN staff that is involved on the waste and spent fuel management activities. Among them, eight have doctoral degrees and six have master degrees. At CDTN, all the staff that works with radioactive waste management received training in Brazil and abroad in this subject. They are trained to

work with administrative and technical activities. Specialized internal and external training is available for the whole staff, including radiation protection and safety courses. Technical visits, courses and meetings are included in this training, and the majority of the staff has had some training in other countries, through IAEA and CNPq (Brazilian Research and Development Council) programs.

**Table F.6** - Personnel involved in spent fuel and radioactive waste management at CDTN

| Qualification                       | Quantity | Education         |
|-------------------------------------|----------|-------------------|
| Radiological Protection Supervisor  | 2        | University degree |
| Senior Reactor Operator             | 2        | University degree |
| Senior Reactor Operator             | 3        | Technical degree  |
| Nuclear Engineering                 | 10       | University degree |
| Radioactive Waste Technicians       | 7        | Technical degree  |
| Radiological Protection Technicians | 2        | Technical degree  |
| Operator                            | 1        | Secondary         |

At IEN, 19 people are involved in waste management and radiation protection. Out of these, 8 have university degrees.

## F.2.2 - FINANCIAL RESOURCES

### F.2.2.1 - Nuclear Power Plants

As a governmental enterprise, Eletrobras Eletronuclear (ETN) has its financial situation subjected to the holding company ELETROBRAS, which controls all federal electric utilities in Brazil.

The basic source of revenue of ETN comes from selling electric power from Angra-1 and Angra-2 (1,885 MWe of net installed capacity), through a long-term energy supply contract ending in 2012, at a guaranteed minimum rate, which is 145,48 R\$/MWhr (~90 US\$/MWhr, in May 2011). The long-term contract is one of the mechanisms applied to protect the nuclear generation from unforeseeable situations that might occur with the ongoing liberalization of the Brazilian electric power market.

Adequate funds are made available through annual budgets, which include the waste management program. For illustration purposes, the 2011 ETN budget for the waste management program is estimated in about R\$17.8 million (~US\$ 10 million).

The provision of funds for decommissioning activities is obtained from ratepayers, and is included in the tariff structure, during the same period of depreciation of the plant (3.3%/year). For Angra-1, presently, a reference decommissioning cost of 307 million dollars is estimated. For Angra-2 the decommissioning costs are estimated in about 426 million dollars.



### F.2.2.2 - Nuclear Fuel Cycle Plants

Brazilian Nuclear Industries (INB) is a mixed economy company (state and privately-owned), under the share control of CNEN and linked to the Ministry for Science and Technology (MCT). INB is in charge of exercising the monopoly of the Union in the nuclear fuel cycle area that covers the stages from the uranium mining to the manufacturing of the fuel elements used in the Angra-1 and Angra-2 nuclear power plants.

The company headquarters are in the city of Rio de Janeiro, with regional offices in the cities of Brasília, São Paulo and Fortaleza and industrial units located in the following places:

- In Caetité, Bahia, the Uranium Concentrate Unit (URA) is located and in operation. At URA, the uranium ore is extracted and processed for the production of uranium concentrate ( $U_3O_8$ );
- The Nuclear Fuel Factory (FCN) are located in Resende, in the state of Rio de Janeiro. FCN comprises: manufacturing of components and assembly of fuel elements and, uranium enrichment plant (three cascades), reconversion of  $UF_6$  and chip manufacturing;
- In Buena, in the state of Rio de Janeiro, the Heavy Minerals Processing Unit (UMP) is in operation. This activity is not associated to the nuclear fuel cycle, but it is where the following minerals are extracted: zirconite, rutile, ilmenite and monazite;
- In Caldas, Minas Gerais, the first uranium mine of Brazil is located, together with the Ore Treatment Unit (UTM). The industrial activities there have been discontinued because they ceased to be economically viable. Currently, decommissioning and environmental remediation are being developed.

#### Operational Revenue:

- The company's main client is ETN, operator of the nuclear power plants Angra-1 and Angra-2.
- Gross revenue from the sale of goods and services comprises the revenue relative to the contracts of i) uranium concentrate, ii) conversion, enrichment and management and iii) fuel element manufacturing, signed with ETN for the reloads of Angra-1 and Angra-2, as well as the sale of products of the Heavy Minerals Unit - Buena.
- Budget resources of the National Treasury - resources of the tax budget of the Union, passed on by the National Treasury Secretariat, intended for payment of expenses with personnel (salaries, benefits and labor sentences).

### F.2.2.3 - Other Installations

At all CNEN's institutes the funds for the spent fuel and waste management come from the general budget that is provided by the Ministry for Science and Technology. At CDTN, some additional funds come from the FAPEMIG (Minas Gerais State Foundation for Research Support), IAEA, FINEP (Research and Projects Financing), CNPq (National

Council for Scientific and Technological Development) and other governmental Institutions, through special projects.

### **F.3 - QUALITY ASSURANCE (Article 23)**

The requirement for a quality assurance program in any nuclear installation project in Brazil is established in the licensing regulation [3]. Specific requirements for the programs are established in a specific regulation, Quality Assurance for Safety in Nuclear Power Plants and Other Installations, CNEN-NN-1.16 [10], which is based in the IAEA code of practice 50-C-QA Rev.1 - Quality Assurance for Nuclear Power Plants, but with the introduction of the concept of an Independent Technical Supervisory Organization (OSTI) [11].

#### **F.3.1 - NUCLEAR POWER PLANTS**

Eletrobras Eletronuclear (ETN) has established its quality assurance program in accordance with the requirements mentioned above. The corresponding procedures have been developed and are in use. The program provides the control of the activities influencing the quality of items and services important to safety. These activities include both spent fuel storage and radioactive waste management. Quality assurance programs are described in Chapter 17 of the FSAR.

The Quality Assurance Superintendence (SQ.G), reporting to the Planning, Management and Environment Directorate (DG), is responsible for the establishment and supervision of the ETN Quality Assurance System.

The Quality Assurance Superintendence (SQ.G) is responsible for the coordination and performance of internal and external audits in order to verify compliance with all aspects of the quality assurance program. All audits are performed according to written procedures. In the case of internal audits, people involved with activities being audited have no involvement in the selection of the audit team. Audit reports are distributed to, and formally analyzed by the audited organizations. In the period 2009/2011, up to this date, 170 external audits and 70 internal audits were conducted.

Audits and inspections by CNEN verify that quality assurance requirements are being implemented and that the quality assurance has been effective as a management tool to ensure safety. During the period of 2009-2011, CNEN conducted 40 audits or regulatory inspections in Angra-1, 2 and 3.

The Quality Assurance Superintendence (SQ.G) also takes part of the Committee for Nuclear Operation Analysis (CAON), which is a collective body under the coordination of the Operations Coordination Superintendence (SC.O) whose purpose is to examine, follow-up and analyze issues concerning Angra-1 and 2 operational safety and to make recommendations to improve safety. In the same way, the Superintendence participates in the Plant Operation Review Committees (CROU's), which are collective bodies under each respective unit manager with the responsibility to review and analyze, on a closer basis, questions related to the operation of the units.

### **F.3.2 - CNEN INSTALLATIONS**

CNEN has also established its own Nuclear Safety Policy [17] and Quality Assurance Policy [18]. Under these policies, all units have to establish their own quality assurance system.

Besides, some units which are involved with industrial production have been independently certified by external organizations, such as the ISO 9000 certification obtained in 2002 by IPEN for its 4 centres: Cyclotron Accelerator Centre, Nuclear Engineering Centre, Radiopharmacy Centre and Research Reactor Centre.

As another example, the Radioactive Waste Management Program of CDTN is also subject to Quality Assurance procedures. The Quality Assurance (QA) System is divided in two parts. The first one contains CDTN's QA Manual, where the general policies are described together with ten general procedures. The second part comprises the specific QA Manuals for the laboratories and special services. They are in force within the scope of the Program, establishing the applicable standards and the responsibilities for the different sections of the institute involved. Specific procedures on Waste Management regulate the operational activities, such as waste segregation, collection, treatment and tests for waste product quality assessment.

IEN had, in the last 3 years, concluded the infra-structure necessary for full operation of its new storage facility, establishing routines and responsibilities related to waste management in this new installation. In the present year, IEN will begin the process of licensing the installations for operation, based on the new standards and regulations prescribed by CNEN for waste management and licensing.

### **F.3.3 - QUALITY ASSURANCE AT NAVY INSTALLATIONS**

The quality required by the projects developed at the Navy Technological Center (CTMSP) has been assured by the application of procedures and instructions prescribed by a Quality Management System, since the beginning of the activities, in accordance with Standard CNEN- NN-1.16 – Quality Assurance for Safety of Nuclear Power Plants and Other Installations [10], applicable during the lifetime of the installation, including: siting, design, construction, commissioning, operation and decommissioning. For the stages of commissioning and operation of the nuclear facilities, the requirements of CNEN-NN-1.16 are complementary to those of the Standard CNEN-NE-1.26 - Operational Safety of Nuclear Power Plants [24].

In the CTMSP organizational structure, the Nuclear Quality and Safety Superintendence, directly subordinated to the Director, is responsible for the Quality Management System, being independent of all other organizational sectors of CTMSP.

### **F.3.4 - QUALITY ASSURANCE AT INB FACILITIES**

According to the requirements of the standard CNEN-NN-1.16 [10], INB systematically submits to CNEN updates of the Quality Assurance Program Procedures

(PGQs) for its facilities.

In 1996, the company implemented and certified, per NBR ISO 9001 Standard, the Quality Assurance System for the Nuclear Fuel Factory at Resende. Subsequently, in 2007, by adopting management standards NBR ISO 14001 and OHSAS 18001, INB expanded the scope of certifications in the areas of environment and occupational safety, respectively, through its Integrated Management System - SIG. The unit was re-certified in 2010 by a team of BR TÜV (company responsible for the certification of nuclear facilities in Brazil) until 25 May 2012, when the certification must be renewed.

It is worth noting that the requirements of the referred standards, besides being in line with CNEN-NN-1.16 prioritizes customer satisfaction, management responsibility, process control and the use of quality indicators with pre-established targets.

The greatest advantage of adopting such standards through an integrated management system at the Nuclear Fuel Factory (FCN/INB) consists in the fact that the company controls and continually improves its processes for activities pertaining to quality, environment, safety, health and physical protection.

Other units of INB operate with the Quality Assurance System on the basis of CNEN-NN-1.16 standard, and strictly focus on nuclear safety.

#### **F.4 - OPERATIONAL RADIATION PROTECTION (*Article 24*)**

Radiation protection requirements and dose limits are established in Brazil in the standard for radiation protection [12]. This regulation requires that doses to the public and to the workers be kept below established limits and as low as reasonably achievable (ALARA).

Implementation of this regulation is performed by developing the basic plant design in accordance with the ALARA principle and by establishing a Health Physics Program at each installation. The plant design is assessed by the regulator at the time of the licensing review by evaluating the dose records during normal operation.

#### **The Role of CNEN**

Regulation CNEN-NN-3.01 - Basic Standards of Radiation Protection [12], of July 2005, is the primary regulatory standard with which all practices have to comply. The main aspects regarding radiation protection and discharge requirements are as follows:

- Controls are established in terms of effective dose for all nuclear facilities on an annual basis, considering 12 consecutive months;
- The primary annual dose limit to members of the public is 1 mSv effective dose applied to all practices during all their life stages, i.e., past, present and future;
- For each single justified practice, the discharges should not reach activity concentrations that exceed the maximum authorized annual limit of 0.3 mSv to the critical group, taking into account all exposures pathways and all radionuclides present in the effluents. The assessment shall consider

conservative hypotheses. This limit is intended to be applied during the licensing stage and used as a ceiling in the optimization process;

- Under normal operation conditions, the demonstration of optimization may be exempt provided that the following criteria are met:
  - an effective dose to workers less than 1 mSv/y;
  - an effective dose to public less than 10  $\mu$ Sv/y;
  - a collective effective dose less than 1 man.Sv/y.

The dose constraint is used to establish upper operational levels of activity concentration for effluent discharges to the environment. There are two ways of establishing such levels:

- The operator proposes the upper levels, based on environmental modelling during the licensing. The whole process is verified and approved by the regulatory body.
- In cases where the procedure is not presented or is not accepted, the regulatory body establishes these levels.

In both cases, CNEN performs an independent assessment to establish or approve upper levels for effluent discharges to the environment. The procedure used is based on the critical group approach and follows the model proposed by IAEA as described in Safety Series 57, adapted to the local conditions and the uses of the environment. The definition of the critical group follows the recommendations of ICRP Publication 43.

To the extent possible, local data are used in the model. These data are assessed from licensing documentation provided by the operator, including those from the Environmental Impact Report (RIMA) provided to IBAMA.

Basic controls for effluent releases required by the regulation CNEN-NN 3.01 - Basic Standards of Radiation Protection [12] include:

- Nuclear installations that release radioactive effluents into the environment should make use of internal and external monitoring and control systems;
- All radioactive material discharged to the environment should be analyzed, accounted for and registered;
- Periodic inspections are carried out by the regulatory authority, in order to verify compliance with the standards;

CNEN regulation NE-1.04 - Licensing of Nuclear Installations [3] also requires the establishment of basic controls such as:

- The installation must provide systems to control and limit radioactive releases into air and water;
- Technical specifications related to the release limits and monitoring of radioactive effluents must be approved by CNEN;
- The operator must establish and carry out appropriate monitoring programs;
- Documented management systems are required to ensure compliance with authorization conditions;

- Effluents release accounting, dose calculation, environmental monitoring and the amount of disposed waste shall be registered and made available for further inspections;
- Operational reports that shall be provided by the operator according to regulation CNEN-NE 1.14 [5] include:
  - Monthly historical operation report;
  - Semi-annual Effluents Release Report;
  - Dose Assessments to the Critical Group;
  - Annual Environmental Monitoring Program Report – Impact Evaluation;
  - Unusual Events Report.

Since 2007 the Institute for Radiation Protection and Dosimetry (IRD/CNEN) does not belong to DRS's structure and, consequently, no longer performs regulatory inspections on the Brazilian radioactive and nuclear installations. Although, as mentioned in **E.3.1**, IRD performs independent assessment of the radiological protection aspects, including assessment of licensing documents, such as safety analysis reports, and operational documents such as radiation protection plans, monitoring programs and operational procedures; working as a technical support organization (TSO) to the Directorate for Radiation Protection and Nuclear Safety (DRS).

#### **F.4.1 - NUCLEAR POWER PLANTS**

The Health Physics Program of Angra-1 and Angra-2, included in Chapter 12 of the Final Safety Analysis Reports, sets forth the philosophy and basic policy for radiation protection during operation. The general policy is to maintain radiation exposure of the workers below the limits established by CNEN and to keep exposures as low as reasonably achievable (ALARA), taking into account technical and economical considerations.

The annual dose limits to workers are 20 mSv for effective dose in a single year, 15 mSv averaged over five years, and 500 mSv for dose equivalent for individual organs and tissues, except in the case of the eye lens, for which the limit is 150 mSv. For pregnant women, the limit is reduced to 1 mSv for the entire pregnancy period. Pregnant women shall not work inside controlled areas.

The actual personnel radiation doses for workers at Angra Nuclear Power Plants are much lower than the established limits. The dose distribution for workers at the Angra site demonstrates an adequate radiological protection program, with almost all averaged annual accumulated individual doses below 5 mSv and no one with radiation dose above the annual administrative dose limit (20 mSv). Dose distributions for the year 2010 are presented in Figures F.1 and F.2. The collective doses over the past recent years are shown in Figures F.3 and F.4.




Figure F.1 - Individual Dose in Angra-1






Figure F.2 - Individual Dose in Angra-2



**Figure F.3** - Collective Dose in Angra-1



**Figure F.4** - Collective Dose in Angra-2

The release of radioactive material to the environment is controlled by administrative procedures and is kept below the limits established by CNEN. Additionally, the amount of radioactive waste and the radioactive effluents discharged to the environment also follow the ALARA principle.

The effluent limits are in accordance with the limits fixed in the Offsite Dose Calculation Manual (ODCM), approved by CNEN. In this manual, the dose for the hypothetical critical individual is calculated.

According to CNEN regulation [5], a report of solid waste and effluents is issued every semester, documenting the liquid and gaseous effluents (reporting the present



radionuclides and concentration) and solid waste quantity sent to the on-site storage facility. Also, the effective dose for the critical individual is presented. In 2010, this dose reached a value of  $2.14 \times 10^{-3}$  mSv for Angra-2 operation and a value of  $6.36 \times 10^{-4}$  mSv for Angra-1 operation, which are much lower than the 1.0 mSv/year value established in regulation CNEN-NN-3.01 [12].

An ALARA Commission for the plant, composed of different groups (Operation, Maintenance, Chemistry, System Engineering and Radiation Protection), is in charge of implementing and monitoring the ALARA Program that describes procedures, methodologies, processes, tools and steps to be used in planning the work. The ALARA Program is continuously being revised and represents the best effort to minimize occupational doses.

A Radiological Environmental Monitoring Program, based on CNEN requirements, is conducted by ETN to evaluate the possible impacts caused by plant operation. This program defines the frequency, places, types of samples and types of analyses for the survey of exposure rates. The evaluation of exposure rates is also made by direct measurement using thermoluminescent dosimeters distributed in special sectors around the Angra site, and at points located in the nearest villages and cities. The results of the monitoring programme are compared with the pre-operational measurements taken, in order to evaluate any possible environmental impact. Annual reports are presented to CNEN. To the present date, no impact has been detected.

IBAMA also monitors the impact of the plants on the environment through a system of inspections in which the Rio de Janeiro State Institute for Environment (INEA), previously called State Foundation for Environmental Engineering (FEEMA), and the City Administration of Angra dos Reis also participate.

Typical results of the monitoring program are presented in Figure F.5.




Figure F.5 - Environmental Monitoring Program Results for 2003-2010

#### F.4.2 - INB FACILITIES

The primary purpose of the Radiation Protection Program is to keep the radiation exposure of the workers as low as reasonably achievable (ALARA).

All occupationally exposed individuals in the supervised and controlled areas are monitored by means of individual dosimeters (TLD badges). The dosimeters are supplied by a laboratory duly certified by CNEN and are changed on a monthly basis. Individuals not exposed occupationally are monitored with prompt reading dosimeters when they access the supervised and controlled areas.

All occupationally exposed individuals (OEI) attend radiation protection, emergency preparedness, first aid, and industrial safety training sessions on a yearly basis.

For occupational exposure, the legal primary dose limits for occupational exposures are an effective dose of 20 mSv per year averaged over five consecutive years and an effective dose of 50 mSv in any single year. For public exposures, the dose limit is an effective dose of 1 mSv in a year.

The main monitoring method used for internal dose calculation is the determination of uranium concentration in urine and in feces of the occupationally exposed individuals. The uranium excretion fractions are those published by International Commission on Radiological Protection (ICRP) - Individual Monitoring for Internal Exposure of Workers - ICRP 78 (1997) and the uranium dose conversion factors are extracted from the CNEN-NN-3.01 Standard [12].

The secondary monitoring method, used to confirm the internal dose calculation is the indirect determination of uranium intake by individual aerosol sample.

At FCN the dose constraint values are established at 16 mSv per year.

In order to achieve effectiveness in the radiological control, all the radiometric data is classified according to pre-established reference levels which determine the actions to be performed according to their magnitude.

Thus, FCN presents values that show a suitable Radiological Protection Program, for which 100% of OEI have received for the last 5 years, the external doses classified as recording level.

Also for the last 5 years, the aerosol monitoring presents 100% of the obtained values as a recording level at FCN - Components and Assembling and 97% at the conversion and UO<sub>2</sub> pellets facilities.

From the accumulated operational experience since the beginning of FCN operation, there is an estimation that the average effective equivalent dose resulting from occupational activities performed in the plant is below 5.0 mSv/yr for OEI.

Figure F.6 shows the distribution of individual doses obtained in 2010, and Figure F.7 shows collective dose values for the past 8 years.




Figure F.6 - Individual Dose 2010 - FCN





Figure F.7 - Collective dose for the past 8 years - FCN

Regarding the URA facility, the mean effective annual doses resulting from occupational activities performed in the plant are shown in Figure F.8, for the past 10 years.



**Figure F.8** - Mean Annual Effective Dose from Occupational Exposures – URA

## F.5 - EMERGENCY PREPAREDNESS (*Article 25*)

As mentioned in **E.1.3**, Brazil has established an extensive structure for emergency preparedness under the so-called System for Protection of the Brazilian Nuclear Program (SIPRON). This includes organizations at the federal, state and municipal level involved with licensing and control activities as well as those involved with public safety and civil defense. Operators of nuclear installations and facilities and supporting organizations are also part of SIPRON.

SIPRON was established by Law 1809 of 7 October 1980. In May 2003, a governmental restructuring (through Law 10683) designated the Ministry for Science and Technology (MCT) as the state department with competence for nuclear energy policy. A National Center for the Management of Nuclear Emergency (CNAGEN) has been created in Brasilia in the MCT to coordinate SIPRON's actions and in 2009 it was moved on to the Institutional Security Cabinet of the Presidency of the Republic (GSI/PR).

The Decree 2210 of 22 April 1997 established a Coordination Commission for the Protection of the Brazilian Nuclear Program (COPRON), composed of representatives of the agencies involved. Besides ETN, as the nuclear power plant operator, and CNEN, as the nuclear regulatory body, other agencies are involved as support organizations of SIPRON, such as the municipal civil defense, the state civil defense, the Angra Municipality, the IBAMA, the National Road Authority, the Army, the Navy, the Air Force, and the Ministries for Health, Foreign Relations, Justice, Finance, Planning and Budget, Transportation and Communications.

The approach to emergency preparedness is based in a “municipalization” of the response action to an emergency situation, using mainly the resources available at the municipality. The state and federal governments complement the local resources as

necessary. In this way, SIPRON works at the operational level with the municipal government and the state government, and at the political level through the Federal Government, which provides the necessary material and financial resources.

The National Center for Management of Nuclear Emergency Situation (CNAGEN), in the Institutional Security Cabinet of the Presidency of the Republic (GSI/PR), is responsible to coordinate the actions related to SIPRON. A State Center for Management of Nuclear Emergency Situations (CESTGEN) has been established in Rio de Janeiro. A Center for Coordination and Control of Nuclear Emergency Situation (CCCEN) and a Center for Information in Nuclear Emergency (CIEN) have been established in the city of Angra dos Reis. These centers' activities during an emergency have been established in SIPRON General Norms [13] and [14].

Corresponding plans have been prepared for CNEN, for its support Institute for Radiation Protection and Dosimetry (IRD) and for other agencies involved, and detailed procedures have been developed and are periodically revised. CNEN Plan for Emergency Situation in Nuclear Power Reactors is currently being revised.

#### **F.5.1 - NUCLEAR POWER PLANTS**

##### **➤ Legislation**

With respect to emergency preparedness, as mentioned bellow, additional requirements have been established by the creation of the Brazilian System for Protection of the Brazilian Nuclear Program (SIPRON).

Since 2009, a Governmental restructuring has designated the Institutional Security Cabinet of the Presidency of the Republic (GSI/PR) as the Central Organization for SIPRON.

At the off-site level, a National Center for the Management of Nuclear Emergency (CNAGEN) has been created in Brasilia, which now is also in the Institutional Security Cabinet of the Presidency of the Republic (GSI/PR).

The Decree 2210 also establishes the Coordination Commission for the Protection of the Brazilian Nuclear Program (COPRON) composed of representatives of the agencies involved.

SIPRON guidelines, issued by COPRON, require that ETN, the Municipal and State Civil Defenses prepare, update and practice a plan for nuclear emergency situations. The guidelines also require that all organizations and agencies involved have their complementary emergency plans.

##### **➤ Emergency Preparedness**

The planning basis for on- and off-site emergency preparedness in case of an accident with radiological consequences in the Angra Nuclear Power Station is based on the Emergency Planning Zone (EPZ) concept.

The Emergency Planning Zones encompass the area within a circle with radius of 15 km centered on the Unit 1 reactor building at the nuclear power plants. This EPZ is

further subdivided in 4 smaller zones with borders at approximately 3; 5; 10 and 15 km from the power plants.

➤ **On Site Emergency Preparedness**

The On-site Emergency Plan covers the area of property of ETN, and comprises the first zone. For this area, the planning and all actions and protection countermeasures for control and mitigation of the consequences of a nuclear accident are responsibilities of ETN.

Specific Emergency Groups (Power Plants - Units 1 and 2, Support Services, Head Office and Medical) under the coordination of the Site Manager are responsible for the implementation of the actions of the On-site Emergency Plan. Emergency Centers for coordination of the Emergency Plan activities, equipped with redundant communication systems and emergency equipment and supplies are established in different locations inside this area.

A redundant meteorological data acquisition and processing system composed of 4 meteorological towers, provides continuous data on wind temperature, speed and direction, as well as air temperature gradient, to a computerized system in the Technical Support Center / Control Room of Units 1 and 2, through which is made the follow up and calculation of the spreading of the radioactive cloud.

The On-site Emergency Plan involves several levels of activation, from Facility Emergencies, Alert, Emergency Area, to General Emergency.

The initial notification for activation of the On-site Emergency Plan is done by the Shift Supervisor from the Control Room, which notifies the Plant Manager, as Emergency Group coordinator, which alerts the coordinators of the other Emergency Groups, the Site Manager and the Regulatory Body (resident inspector and Headquarter). The plant personnel are warned by means of the internal communication system, sirens and loudspeakers.

Twenty-four-hour/ 7-day-a-week on-call personnel, under the responsibility of the Site Manager, ensure the prompt actuation of the Emergency Groups.

Training and exercises (5 per plant) are performed yearly.

➤ **Off Site Emergency Preparedness**

Brazil has established an extensive structure for emergency preparedness under the System for Protection of the Brazilian Nuclear Program.

SIPRON issued a set of General Norms for Emergency Response Planning, consolidating all requirements of related national laws and regulations. These norms establishes the planning, the responsibilities of each of the involved organizations and the procedures for the emergency centers, communications, intelligence and information to the public.

COPRON has established a Committee (COPREN/AR) for planning and preparedness of the response to a nuclear emergency at Angra Nuclear Power Plant. This committee conducts an off-site emergency plan practice every year. In even years, the practice is a partial exercise with only the communication system and the emergency

centers activated. In odd years, a general exercise includes sirens actuation, evacuation and sheltering of part of population, external monitoring, road and air and sea navigation control.

At the off-site level, a National Center for Management of Nuclear Emergency Situation (CNAGEN) has been created in Brasilia (capital of Brazil). A Regional Center for Management of Nuclear Emergency Situations (CESTGEN) has been established in Rio de Janeiro city. A Center for Coordination and Control of Nuclear Emergency Situation (CCCEN) and a Public Information Center (CIEN) have been established in the city of Angra dos Reis. The activities of these centers during an emergency have been established in SIPRON General Norms and were approved by the state governor in the revised Rio de Janeiro State Plan for External Emergency.

Corresponding plans for CNEN, its support Institute for Radiation Protection and Dosimetry (IRD) and other involved agencies have been prepared, and detailed procedures have been developed.

#### **F.5.2 - OTHER FACILITIES (RESEARCH REACTORS)**

The safety analysis performed for other installations such as research reactors indicates that only "on-site emergency is required". The on-site emergency plan covers the area within the operator's property, and comprises the reactor building and surroundings. It involves several levels of activation, from single alert status, to reactor building evacuation and isolation.

Specific Emergency Groups, under the coordination of the COGEPE (General Coordination for Emergency Plan), are responsible for the implementation of the actions of the on-site emergency plan. COGEPE is also responsible for plant personnel emergency training and exercises planning.

IPEN also maintains a Nuclear and Radiological Emergency Response Team. Training activities in nuclear and radiological emergency for fire brigade companies, professionals of medical area, safety officers and employees are carried out systematically, with the participation of qualified observers.

At CDTN, a radiological emergency service is also available around the clock, including weekends and holidays. The emergency team is made up of trained people who are able to deal with situations arising from radioactive source losses, en route accidents with vehicles transporting radioactive sources, or source mishandling at the user's premises. The most common tasks carried out by the CDTN response group so far have been the investigation of possible site contamination in airports, stealing of lightning rods, possible presence of orphan radiation sources in junkyards and industrial areas and the disappearance of medical sources from hospitals. The response group members also give lectures on emergency response, radiation protection and radiation source handling to specific groups, e.g. firefighters and Army special battalions.

### **F.5.3 – INB FACILITIES**

The Nuclear Fuel Factory (FCN) located in the Resende municipality established a Local Emergency Plan mainly focused on the possible accident occurrences within its facilities. There is no possibility of these accidents reaching the surrounding areas.

The Local Emergency Plan can be activated by a wide variety of possible incidents, such as fire, radiological accidents, and intrusion scenarios into the facilities. There is an organizational emergency structure establishing the responsibilities, as well procedures for each emergency group formed by the plant technical personnel.

Although it is very unlikely that accidents in that facility reach the surrounding areas, an emergency general coordination was established with supporting groups such as the municipal civil defense, the fire brigade, the police, and CNEN emergency group. The Emergency Response Planning Committee in Resende - COPREN/RES, has been coordinating this task besides supporting SIPRON.

The effectiveness of the Local Emergency Plan is verified through simulated emergency exercises. The plan coordinator prepares a scheduled program on an annual basis with various scenarios of possible accidents. Emergency exercises are performed on monthly basis. After accomplishing this simulation, a meeting takes place in order to evaluate the performance of the group as a whole and a report with recommendations is prepared. Besides that, a meeting with all the participants of the program is held every three months, in order to discuss problems that may have some implications in the plant facility, such as the alarm system operation, specialized personnel hiring and communication system operation during an emergency situation.

In the Uranium Concentrate Unit (URA), The Emergency Plan aims to establish preventive measures to minimize effects of accidents that may disturb the normal operation of the unit and establish procedures for the routine returns to normality after the response to a possible accident. The risk analysis and identification of possible types of accidents are supported by operational experience of mining and other industrial facilities, also considering the constructive characteristics of the regiment of URA and rules of CNEN, considering the possibility of fires, landslides or radiological incidents.

The unit has an organizational structure, multidisciplinary teams, equipment and a scheduling of theoretical and practical training. The effectiveness of Local Emergency Plan is verified through simulated emergency exercises. Moreover, evaluations are made by internal and external auditors belonging to the regulatory body.

### **F.5.4 - EMERGENCY PREPAREDNESS AT NAVY INSTALLATIONS**

As previously mentioned in A.2.4, at CTMSP headquarters, which is situated in the city of São Paulo, there is only a small nuclear laboratory, whose inventory of nuclear material is actually very small. Therefore, as required by CNEN, this facility has only a radiological Emergency Response Plan.

The safety analysis studies, performed for all the nuclear facilities located within



the site of CEA, demonstrated that no off-site emergency actions are required.

The Local Emergency Plan for CEA (PEL-CEA) was conceived to ensure the integrated planning and the coordinated response, required in an emergency situation, that aim to protect the activities, the facilities, the environment, and guarantee the safety and health of the workers and the public.

The PEL-CEA is applicable to all the operational facilities located, or to be located, within the site of CEA. However, for planning purposes, the PEL-CEA must be complemented by specific local emergency plans, conceived for all those facilities, both conventional or nuclear, situated within the site of CEA, that may need emergency response. These facilities are called emergency planning units (UPE), and their specific local emergency plans should be considered as being part and parcel of the PEL-CEA.

During an emergency, an emergency organization will be activated to monitor and, if necessary, implement precautionary and/or protective measures for possible hazards. Decisions will be taken by the General Coordinator of the Emergency Plan (COGEPE), assisted by the Coordinator of the Emergency Plan for CEA (COPE-CEA), the Coordinator of Local Emergency (CEL-UPE) and the Coordinator of Support Actions (CAAp). Specific Emergency Groups, under the coordination of the COGEPE, will be responsible for implementing precautionary and protective actions as directed. Control will be exercised from the Emergency General Coordination Centre (CCGE) through the Emergency Local Coordination Centre located in each UPE, where the response to an emergency in the UPE will be coordinated.

The COPE-CEA is responsible for preparing an annual schedule of on-site emergency exercises, which must be submitted to and approved by the COGEPE. The COPE-CEA is responsible also for implementing these exercises and writing a report evaluating them.

The Nuclear Quality and Safety Superintendent is responsible for planning and implementing independent and formal emergency exercises in each UPE, with, at least, a biennial frequency.

## **F.6 - DECOMMISSIONING (*Article 26*)**

Brazil is taking steps to establish a national regulation that sets the guidelines for the composition of funds for facility decommissioning, spent fuel management and radioactive waste management and disposal.

### **F.6.1 - NUCLEAR POWER PLANTS**

A study made by Eletrobras Eletronuclear (ETN) has established the alternatives for the future decommissioning of Angra-1 and Angra-2 Nuclear Power Plants, analyzing the financial resources, based on 17 American Nuclear Power Plants, 10 European Nuclear Power Plants and the specific study elaborated by Krsko Nuclear Power Plant, similar to Angra-1.

ETN considers as the best alternative the SAFSTOR (Safe Storage), which consists of the confinement of the Plant for a period of 10 up to 30 years, to reduce the amount of contaminated material, and radiation exposure.

The financial resources for decommissioning Angra-1 and Angra-2 would be subsidized through electrical energy taxes from those plants, with governmental authorization.

The national approach on waste from the above mentioned decommissioning is on a latent status, to be analyzed and defined later, after the definition and conclusion of the final disposal site for the Low Level Waste-LLW and Intermediate Level Waste-ILW from Angra Nuclear Power Plants.

### **F.6.2 - RESEARCH REACTORS**

No decommissioning policy has been adopted. However, at CDTN a group is preparing a preliminary decommissioning plan for IPR-R1.

### **F.6.3 - NUCLEAR INSTALLATIONS**

#### **F.6.3.1 - Decommissioning of Santo Amaro Processing Plant (USAM)**

The decommissioning of Santo Amaro monazite sand treatment facility (USAM) was the first activity of this kind executed in Brazil, providing knowledge in many areas, for the safe, successful conduct of the work to be done. USAM operated since the 1950's in an area far from the city center of São Paulo, separating rare-earth materials from monazite sand coming from the Buena Beach in Espírito Santo State. The growth of urban areas around the site led to the decision to decommission the facility.

In 1992, the Santo Amaro Processing Plant (USAM) was deactivated. USAM used to process monazite sand for the separation of rare-earth elements. Works were developed in this area to subsidize the decision-making process aiming to the remediation of the area, with the objective of releasing the areas for unrestricted use. Mathematical models were applied for the dose calculation, considering different scenarios of area occupation. The dose criterion used was of 1 mSv/year in the critical group for the more conservative occupation scenario, in agreement with the possibilities of occupation of the area, located in an urban environment.

The facility went through a complete decommissioning process. After segregation and the following transfer of the radioactive waste to another site, the buildings were demolished and the site decontaminated. The radioactive waste generated by the decommissioning process led to the choice of the Interlagos Processing Plant (USIN), also in São Paulo State, as the interim storage facility to these waste (see **H.2.2.2**).

A detailed radiation monitoring program was conducted and the site was declared free for unrestricted use. The formal decommissioning process was formalized through a

resolution of the Deliberative Commission of CNEN in January 1999. A view of the area before decommissioning is shown in Figure F.9.

Before decommissioning, the monitoring program proposed by the operator and approved by CNEN fulfilled the need for following up the environmental behavior of the site soil contamination and for assessing the radiological impact on the environment that resulted from the pre-existing site contamination and due to the radiation emitted by the stored radioactive materials in USAM Warehouse. A program for occupational exposure assessment was also implemented by the operator.

The monitoring program performed by the operator analyzed the concentrations of soluble  $^{226}\text{Ra}$  and  $^{228}\text{Ra}$  in water from wells around the site, wells inside Warehouse A and a creek close to the site area. External doses were measured by a TLD net around the site and around USAM Warehouse.



**Figure F.9** - Area occupied by USAM in Santo Amaro, SP.

The control performed by IRD included the assessment of reports provided by the operator and regulatory inspections, where the access control for restricted areas was verified, and measurements of dose rates inside and surrounding USAM Warehouse were performed.

In December 1997, INB submitted a comprehensive plan for demolishing USAM buildings and some soil samples were sent for laboratory analysis, especially for determining existing radionuclides and total alpha and beta/gamma activities.

CNEN also required that INB submitted: (i) a detailed decommissioning plan, including waste management and radiological procedures for demolishing the buildings (floors, walls, sanitary system, water distribution system etc); (ii) procedures that would be adopted for the radiological characterization of the site (depth of soil samples, sampling frequency etc.) and frequency of reports to be submitted to CNEN; (iii) the radiological criteria to be used for clearance; (iv) a radioactive waste management plan,

including the adequate description of packages; (v) description of the scenarios that would be used for the determination of soil clearance values (cutoff limits) due to the goal of releasing the area for unconditional use; (vi) radiological procedures for the workers involved in the clean up; and (vii) procedures to control and guarantee that the doses on the neighbouring population would not exceed 1 mSv/y.

In 1997, an environmental monitoring control program was implemented by IRD for the USIN site, including the assessment of documents provided by the operator, auditing records related to the environmental monitoring program and a joint sampling procedure for well and underground water.

The duplicate sampling program has shown that the results obtained by INB were compatible with those obtained by the regulatory body and that the area was adequately controlled.

In March 1998, CNEN authorized the demolition of the area occupied by the monazite physical treatment unit, with the exception of some compartments in the area of thorium crystallization, since the contamination levels detected were above the established clearance levels. Some soil contamination was also detected. In June 1998, CNEN authorized the complete demolition of these compartments. In July 1998, another room from the monazite chemical treatment unit was demolished, after the procedures proposed by the operator were approved by CNEN. In August 1998, the last room and the administrative building were demolished, also after specific authorization by CNEN.

The radioactive waste generated from these decommissioning steps were placed in metallic boxes, metallic containers and plastic drums, transported to another INB installation, USIN, and stored in a shed. All the conditioning and transport of the waste were inspected by CNEN.

The scenario calculations performed by the Institute of Radiological Protection and Dosimetry (IRD), based on unconditional use of the area (soil), led to a clearance value of 600 Bq/kg of  $^{226}\text{Ra}$  for soil.

All the clean-up work of the soil was inspected and audited by CNEN during the months of January through December 1998.

In December of 1998, experts from IRD conducted a complete radiometric survey of the soil within the plant, concluding that the clean-up performed at the soil surface was sufficient to reduce the surface contamination of the area to the same levels of the natural background of the region. Figure F.10 shows the site after the end of the decommissioning activities of the USAM monazite processing plant.

A total of 13,000 m<sup>2</sup> of constructed area has been demolished and an area of 16,503 m<sup>2</sup> of soil has been removed (at an average of 50 cm of soil depth, resulting in a waste volume of the order of 8,250 m<sup>3</sup>). The waste that was slightly contaminated and classified as radioactive, occupying a volume of 372 m<sup>3</sup>, is stored in a shed of INB in São Paulo.



**Figure F.10** - Clean area after USAM decommissioning work

One hundred and thirty four workers from INB were involved in the decommissioning work and their recorded doses can be seen on Table F.7, which shows that all of them received radiation doses far below of the Brazilian dose limit that was adopted at that time of 50 mSv/year. These dose values are also below the new limit of 20 mSv/year adopted by Brazil

**Table F.7** - Radiation doses to workers involved in decommissioning USAM

| Dose                  | Number of workers |
|-----------------------|-------------------|
| > 10 mSv              | 0                 |
| > 5 mSv and ≤ 10 mSv  | 8                 |
| > 1 mSv and ≤ 5 mSv   | 46                |
| > 0.1 mSv and ≤ 1 mSv | 30                |
| Undetectable          | 50                |

INB has successfully decommissioned a monazite processing plant in Brazil, over a period of approximately 5 years, under close surveillance of CNEN, as depicted in Figures F.9 and F.10.

After decommissioning USAM, INB sold the land to a construction company, which has designed and built six 26-floor residential buildings. The project includes apartments with private areas of 120, 170 and 220 m<sup>2</sup>, whose the target public was the upper middle-class. Figure F.11 shows the area of the former USAM, now occupied by new construction: six buildings, recreational area with swimming pools, sport courts and playground.



**Figure F.11** - New residential buildings built in USAM decommissioned area

#### **F.6.3.2** - Decommissioning of the Ore Treatment Unit at Poços de Caldas (UTM)

Parts of the old Ore Treatment Unit (UTM) at Poços de Caldas mining and milling complex are currently being decommissioned by INB. In September 2009, was hired a company specialized in the Preparation of the Remediation Plan - PRAD (Degraded Areas Reclamation Plan), which will be completed in September 2011 and includes all areas of the UTM.

#### **F.6.3.3** - Decommissioning of the Interlagos Processing Plant (USIN)

During the operation of USAM, big amounts of mineral fractions with no commercial value (Silica) containing a heavy minerals fraction that included percentages of Monazite were transferred to USIN and disposed in the land.

Moreover, radioactive minerals from mineral research activities conducted during the 1960's to 1980's were stored in USIN sheds, in sufficient quantities for the execution of development tests of physical and chemical processes for uranium recovery. The storage was made in sheds (named B and C) that did not receive suitable maintenance and lacked a suitable floor, and such minerals gradually got dispersed.

The monazite contaminated packages were also stored in these sheds. As such packages got deteriorated; the floor was contaminated with small quantities of products containing thorium and uranium. By that time, any environmental law or procedures had been established in the country related to contaminated land.

The terrain underwent a few radiometric evaluations in the 1990's, and the first investigations determined the extent of the anomalies by means of a scintillometer. The measurements allowed generating radiometric maps of the area and locating contaminated points.

New scintillometric surveys performed after remediation procedures demonstrated the existence of 14 anomalous points that remained from the remediation carried out early in the 1990s. Additionally, anomalous points were detected in the entire floor area of sheds B and C.

After the remediation done at the end of the 1990's, a test bore of the terrain was planned, and four different areas were defined: A, B, C, D. In Area A were made 213 test bores using an irregular spacing guide. For the other areas, the spacing format was a regular one, 6 x 6 meters, with 264 points in Area B, 208 points in area C and 302 points in area D. Soil sampling was made at 30 cm and 100 cm depths. Alpha and total beta emissions were determined on the samples collected.

Then, the remediation process was suspended. Notwithstanding, in compliance with the requirement of CNEN and the São Paulo State Institute for Environment (CETESB), concerning the execution of a hydrogeological study of the site, two new test boring campaigns were carried out. The first one, with 28 holes up to 6 meters deep, and installation of an equal number of underground water monitoring wells.

On the samples were analyzed the radionuclides of radiological interest ( $^{238}\text{U}$ ,  $^{232}\text{Th}$ ,  $^{228}\text{Ra}$ ,  $^{226}\text{Ra}$  and  $^{210}\text{Pb}$ ) and geochemical parameters (pH, CE, T<sup>a</sup>, Eh) metals. During the second test boring phase, nine supplemental test bores were made.

Then, the contamination evaluation was executed in three occasions and 1,000 points in the area were analyzed. In the last hydrogeological characterization (2006) 07 contaminated points in the site were identified.

The site environmental radiological monitoring was revised in accordance with this final characterization and the quarterly monitoring results showed there was not any contamination migration going out of the site limits.

The remediation procedure estimates that 680 m<sup>3</sup> of soil will be moved by the decontamination work, of which approximately 80 m<sup>3</sup> will be segregated as low-level radioactive waste and temporarily stored in USIN's Shed A.

Soil whose analysis results for specific radionuclides are below the limits established by CNEN of 0.5 Bq/g  $^{226}\text{Ra}$  and 0.5 Bq/g of  $^{228}\text{Ra}$  will be used for land restoration.

Soil with specific total activity calculated in the following manner:  $\text{TSA} = 8 \times ^{226}\text{Ra Bq/g} + 9 \times ^{228}\text{Ra Bq/g}$ , whose result is equal to or below 30 Bq/g, according to the limits established by CNEN, will be disposed of in a sanitary landfill.

Soil with specific activity above 30 Bq/g will be packed and stored as radioactive waste.

INB started decontamination work in 2010. This activity has not been completed because the activity can only be performed during the period when it is not raining.

INB is expecting the definition of the position of CNEN on the national repository for low- and intermediate-level radioactive wastes so that studies and plans can be

developed for transferring the waste stored at USIN. From the establishment of that position, a new radiological assessment of Shed A and of the local soil will be done, along with the decontamination plan and the subsequent total decommissioning of the facility.



## **SECTION G - SAFETY OF SPENT FUEL MANAGEMENT**

### **G.1 - GENERAL SAFETY REQUIREMENTS (*Article 4*)**

Since the current situation is the storage of spent fuel in the plant pools, the general safety requirements for the management of spent fuel are contained in the safety requirement for siting, design and operation of the nuclear reactors. Regulation CNEN-NE-1.04 [3] applies to the fuel stored in the nuclear power plant. Additional requirements are established in Regulation CNEN-NE-1.26 [8], for the operational phase, and Regulation CNEN-NE-1.14 [5] establishes the necessary reporting requirements.

### **G.2 - EXISTING FACILITIES (*Article 5*)**

#### **G.2.1 - NUCLEAR POWER PLANTS**

The design of the fuel pools and associated cooling systems and fuel handling systems assure adequate safety under authorized operation and under postulated accident conditions.

Both units are provided with facilities that enable safe handling, storage and use of nuclear fuel. The facilities are designed, arranged and shielded such as to rule out inadmissible radiation exposure to the staff and the environment, release of radioactive substances to the environment, and criticality accidents.

In Angra-1 the new fuel dry storage room and the spent fuel pool are located in the Fuel Handling Building, having connections with the reactor via the fuel transfer system and the refueling machine. The path of the nuclear fuel inside the plant up to the reactor is: the entrance gate, the cask opening area inside the fuel building, the new fuel storage area, the transfer canal (or temporarily in the spent fuel pool), the fuel transfer system, the refueling machine and the reactor core.

In Angra-2 the dry new fuel storage room and the spent fuel pool are located inside the Reactor Building. The path of the nuclear fuel inside the plant up to the reactor is: the entrance gate, the auxiliary portico, the equipment lock, the cask opening area, the new fuel storage area, the refueling machine, the spent fuel pool, and the reactor core.

In both Units the Spent Fuel Pools are equipped with fuel storage racks of two different designs. The first group, named Region 1, or compact racks, is designed to receive fresh and irradiated fuel assemblies at maximum reactivity for the specified core design, without taking credit for burnup. The second group, named Region 2 or supercompact racks, is designed to receive fuel assemblies that have reached a certain minimum burnup.

The compact and supercompact racks, made of stainless steel, have boron coupons between the storage cells in Angra-1. In Angra-2 the compact and supercompact racks use borated steel plates as the construction material of the cells. The technical specifications have curves of discharge burnup versus initial enrichment to direct the storage of fuel assemblies in region 2 because the smaller center-to-center distance of the cells.

Structures, components, and systems are designed and located such that appropriate periodic inspection and testing are performed.

In both units, all storage places are supported by criticality safety studies. Criticality in new and spent fuel storage areas is prevented both by physical separation of fuel assemblies, by boron shields and by borated water as appropriate.

The evaluated multiplication factors of the fuel storage configurations include all uncertainties arising from the applied calculation procedure and from manufacturing tolerances. The factors are less than or equal to the adequate upper bound margin of subcriticality (1-deltaK) under normal operation and all anticipated abnormal or accident conditions.

The criticality evaluation codes used by the ETN are all codes accepted by the international industry and also licensed by CNEN.

The storage capacity is shown on table G.1 below:

**Table G.1** - Spent fuel storage capacity at Angra – Number of fuel assemblies

|                          | Angra-1 | Angra-2 |
|--------------------------|---------|---------|
| New Fuel Storage Room    | 45      | 75      |
| Region 1 Spent Fuel Pool | 252     | 264     |
| Region 2 Spent Fuel Pool | 1,000   | 820     |
| Reactor Core             | 121     | 193     |

Assuming a regular lifetime of 32 operating cycles for each unit and that in each cycle 1/3 of the core is replaced, then Angra-1 has enough storage capacity for its entire lifetime and Angra-2 has storage capacity for about 14 cycles.

In Angra-1, the Spent Fuel Pit Cooling system is able to remove the amount of decay heat by a circuit with two pumps and one heat exchanger. In the case of maintenance or malfunction of the main pump, a redundant spare pump is operated. This spare pump is supplied by the emergency bus control and, in the case of loss of offsite power, can be supplied by the diesel generator.

In Angra-2, the Fuel Pool Cooling system consists of two trains which are integrated into the Residual Heat Removal (RHR) system and a third independent train. In each integrated train a fuel cooling pump is connected in parallel with the RHR pump.

These two trains are equipped with connections to the fuel pool via the RHR system. The independent fuel pool cooling train consists of a fuel pool cooling pump which is connected in parallel with the fuel pool purification pump, the fuel pool cooler and separate connections to the fuel pool. The redundancy of the power supply of the Fuel Pool Cooling system is ensured by connection to the normal power supply system and to the emergency power supply systems.

Each unit is designed for a regular lifetime of 32 operating cycles. According to the national electric power demand, the refuelling policy is to operate with 11 equivalent full power monthly cycles, with an one-month refuelling outage. Studies are being carried out to increase the cycle lengths gradually up to 18 months, since longer cycles reduce waste generation and doses during refuelling outages. Shutdowns, refuelling and startups of the plants are conducted in such a way to reduce the amount of radioactive waste generated (see also items D.1.1.1 and D.1.2.1).

The role of the Eletrobras Eletronuclear (ETN) on the nuclear fuel management can be summarized as follows:

- Definition of operating strategy
- Definition of core composition
- Procurement of fuel manufacturing together with manufacturers
- Follow up of fuel manufacturing
- Transport of new fuel from the factory to the site
- New fuel reception on site
- Fuel storage on site
- Fuel operation
- Refueling Operations

The supply of the fuel for nuclear power plants is planned several years in advance. In-core fuel management provides the basic data for this long-term planning. For this purpose, several burnup cycles have to be calculated in advance. The corresponding core loading schemes, or loading patterns, have to be determined considering safety-related and operational requirements as well as economic aspects. The main results of long-term fuel management are the required numbers of fuel assembly reloads and their enrichments for future cycles.

Of special interest in the long-term fuel management are the equilibrium cycles. To calculate the equilibrium cycles, the same loading pattern is used for several successive cycles. The equilibrium cycle is reached when the characteristic parameters do not change significantly from cycle to cycle. The most important characteristic parameters are:

- Type of loading strategy
- Number and enrichment of the fuel assembly reload
- Natural length of the cycle
- Average discharge burnup for the fuel assemblies

- Availability of storage places. In this sense, the interdependence of spent fuel (non-returnable to the reactor core) management is to be defined with CNEN.

### **G.2.2 - RESEARCH REACTORS**

See item **D.2**.

### **G.3 - SITING OF PROPOSED FACILITIES (*Article 6*)**

Siting requirements for the existing spent fuel storage facilities at reactor sites are the same for siting the nuclear power plants or research reactors, respectively.

If the decision is taken to store fuel in “dry storage” on site, new detailed requirements will have to be established by CNEN.

### **G.4 - DESIGN AND CONSTRUCTION OF FACILITIES (*Article 7*)**

Design and construction requirements for the existing spent fuel storage facilities at reactor sites are the same for design and construction of the nuclear power plants or research reactors.

The spent fuel storage racks are easily installed and removed. They are manufactured from stainless steel. Their purpose is to receive and store fresh and spent fuel assemblies as well as any core inserts, like control rods, primary and secondary sources and flow restrictors to be inserted into fuel assemblies.

The storage racks consist of load bearing structure supporting non-load bearing absorber cells. The load bearing structures comprise:

- The lower support structure (base plate)
- Rack foot
- Centering grid
- Steel channels

The non-load bearing structures are provided with features to assure safe subcriticality, each fuel assembly position is provided with one absorber cell. The absorber cells are made of neutron absorbing sheets with grooved edges. The absorber sheets are manufactured from a boron-alloyed austenitic stainless steel.

The absorber cells are fixed in the rack structure by means of welded clamps. To facilitate the insertion of the fuel assembly into the absorber cell, the upper part of the cell is provided with lead-in slopes, or chamfers and, where applicable, with guide for the refueling machine centering device.

Only about 40% of the volume of a fuel assembly consists of fuel rods; the remaining volume is filled by water.

For Angra-1, 2 and future unit 3 an additional wet storage facility for spent nuclear fuel is being foreseen, in order to complement the current on-site storage capacity of the Plants. This facility will be under ETN responsibility as a complementary and initial storage facility of the plant. The design basis will be the same as used for Angra-2 and 3 spent fuel pools.

## **G.5 - ASSESSMENT OF SAFETY OF FACILITIES (*Article 8*)**

A comprehensive safety assessment is a requirement established by the licensing regulation in Brazil [3].

### **G.5.1 - NUCLEAR POWER PLANTS**

For the Angra-1 and Angra-2 plants, both a Final safety Analysis Report (FSAR) were prepared. For the Angra-3 plant, a Preliminary Safety Analysis Report (PSAR) was also prepared. The FSARs and PSAR followed the requirements of US NRC Regulatory Guide 1.70 - Standard Format and Contents for Safety Analysis Report of LWRs.

Chapter 9 of the FSAR contains the information related to spent fuel storage on site, including cooling requirements, subcriticality requirements, and radiation protection aspects.

These reports were reviewed and assessed by CNEN, and extensive use was made of the US NRC - Standard Review Plan (NUREG - 0800).

### **G.5.2 - RESEARCH REACTORS**

The design and additional modifications of the Brazilian Research Reactors have been made in accordance with IAEA Safety Standards, Safety Guides and Safety Practices of IAEA Safety Series, in particular Safety Guide 35-G2 (Safety in the Utilization and Modification of Research Reactors), Safety Guide 35-S2 (Code on the Safety of Nuclear Research Reactors: Operation), Safety Series 116 (Design of Spent Fuel Storage Facilities), and Safety Guide 117 (Operation of Spent Fuel Storage Facilities). Such documents present the fundamental principles of safety for research reactors and associated facilities for handling, storage and retrieving of spent fuel before it is reprocessed or disposed of as radioactive waste. The adoption of these principles assures that the spent fuel represents no hazard to health or to the environment, and the maintenance of the following conditions for the spent fuel:

- Subcriticality
- Capacity for spent fuel decay heat removal
- Provision for radiation protection
- Isolation of radioactive material

### G.5.3 – INB FACILITIES

INB has the following manufacturing units:

- Uranium Concentrate Unit - URA, located in the municipality of Caetité, state of Bahia;
- Ore Treatment Unit - UTM, located in the municipality of Caldas, State of Minas Gerais;
- Nuclear Fuel Factory - FCN, located in the municipality of Resende, state of Rio de Janeiro, consisting of the following units:
  - FCN 1 - Reconversion (UF<sub>6</sub> to UO<sub>2</sub> Conversion) and Pellets
  - FCN 2 - Components and Assembly
  - FCN 3 - Enrichment
- Heavy Minerals Processing Unit - UMP, located in Buena, state of Rio de Janeiro.
- Interlagos (USIN) and Botuxim Plants, located in the state of São Paulo.

To ensure building and operation of facilities in accordance with the safety principles required by national and international authorities, all facilities owned by INB are subject to nuclear licensing procedures required by CNEN. To this effect, a Preliminary Safety Analysis Report and a Final Safety Analysis Report are prepared and submitted in accordance with regulatory guide CNEN-NE-1.04 – "Licensing of Nuclear Installations" [3], which is further supplemented by regulatory guide CNEN-NE-1.13 - "Licensing of Uranium and/or Thorium Mining and Milling Facilities" [20], in the case of uranium ore mining and milling operations.

Additionally, all such facilities go through an environmental licensing process, including an Environmental Impact Study in which the safety conditions relating to the environment and the population are discussed.

For nuclear facilities, this process is conducted by IBAMA; in the case of the UMP, this is the responsibility of the Rio de Janeiro State environmental body INEA (Institute for Environment); and in the case of USIN and Botuxim sites, by the São Paulo State Institute for Environment (CETESB).

### G.6 - OPERATION OF FACILITIES (*Article 9*)

Operational requirements for the existing spent fuel storage facilities at reactor sites are the same for operating the nuclear power plants or research reactors.

Detailed limits and conditions for operations (LCOs) are established for the nuclear power plant spent fuel pools, including the related surveillance requirements and the actions to be taken in case of deviations.

## **G.7 - DISPOSAL OF SPENT FUEL (Article 10)**

### **G.7.1 - FUEL FROM NUCLEAR POWER PLANTS**

The technical solution regarding reprocessing or disposal of spent fuel has not been taken in Brazil. This solution may take some time, until international consensus is achieved. Meanwhile, Brazil continues to monitor the international situation.

For Angra-1 and 2, as well as for Angra-3, in the future, an additional wet storage facility for spent nuclear fuel is being foreseen, in order to complement the current on-site storage capacity of the plants. This facility will be under ETN responsibility as a complementary and initial storage facility of the plant.

Regarding the long term storage of Spent Nuclear Fuel, CNEN, in partnership with ETN, is considering the technical solution of a safety dry storage away from reactor. Actually, the solution envisaged considers to envelop the SNF in a welded canister and emplace it in an interim long-term under surface storage facility. The technical viability of this SNF conditioning is supposed to be tested in a demonstration plant to be erected by CNEN and ETN still in this decade.

### **G.7.2 - FUEL FROM NUCLEAR REACTORS**

The situation of research reactors was discussed in item **D.2.1**.

On November, 2007, 33 spent fuel elements stored in the pool of the IEA-R1 reactor and containing uranium of US origin were shipped back to Savannah River Laboratory, South Carolina, USA. This operation, which was very similar to the one concluded in 1999, when 127 spent fuel elements were shipped back to the USA, used a different transport cask (LWT) supplied by the US company NAC.

## SECTION H - SAFETY OF RADIOACTIVE WASTE MANAGEMENT

### H.1 - GENERAL SAFETY REQUIREMENTS (*Article 11*)

General safety requirements for the management of radioactive waste are established in regulation CNEN-NE-1.04 Licensing of Nuclear Installations [3] and CNEN-NE-6.05. Management of Radioactive Waste in Radioactive Installations [6]. Additional requirements for safety in nuclear facilities are established in regulation CNEN -NE- 1.26, Operational Safety in Nuclear Power Plants [8].

### H.2 - EXISTING FACILITIES AND PAST PRACTICES (*Article 12*)

#### H.2.1 - NUCLEAR POWER PLANTS

##### H.2.1.1 - Gaseous Waste

To minimize the radiation released to the environment and to prevent the formation of explosive mixtures due to high hydrogen concentration, the gases are continuously removed from the primary systems and processed in the Gaseous Waste Processing System, before being discharged to the environment.

In Angra-1, the Gaseous Waste Treatment System removes the fission gases and stores them in the gas decay tanks. The safety criteria are the assumption of 1% of fuel failures being released to the Reactor Coolant System.

In Angra-2, in order to avoid a release of radioactive gases to the building atmosphere and subsequently to the environment, or the formation of explosive mixtures due to any high concentration of hydrogen that could arise inside the tanks in the auxiliary systems, the Gaseous Waste Disposal System removes such gases by continuous purging with nitrogen and processes the dissolved gases released from the reactor coolant. To fulfill the required functions, the gaseous system has the following tasks:

- To retain radioactive gases until they have largely decayed before discharging then to the exhaust air stack.
- To prevent any release of radioactive gases from the components into the building atmosphere.
- To limit the hydrogen and the oxygen concentrations in the connected components in order to prevent the formation of explosive mixtures and to reduce the presence of oxygen in the reactor coolant, which would lead to corrosion in the reactor coolant system.
- To operate with the Hydrogen Reducing System, following a loss of coolant accident.



In Angra-2, the gaseous effluents are released continuously through the vent stack, depending on the ventilation system pressure.

#### H.2.1.2 - Liquid Waste

The Liquid Waste Processing and Storing Systems in Angra-1 and in Angra-2 are designed to collect the active and inactive liquid waste produced in the controlled area, treating them when necessary. After that, they may be discharged from the power plants in accordance to the safety rules established by nuclear and environmental authorities (CNEN, IBAMA and state regulators).

According to the activity and the chemical characteristics of the liquid waste, the following processes are provided for treatment:

- Evaporation
- Mechanical filtration (Angra-2 only)
- Ion exchange deionization using mixed-bed filters
- Chemical precipitation (Angra-2 only)
- The Liquid Waste Processing and Storing Systems are designed to collect the liquid waste arising from the controlled area to specific storage tanks, and to separate different types of liquid waste for further processing

The systems are sufficiently automatic to minimize the human intervention, consequently reducing the occupational doses. The capacity is determined by the amount of liquid waste arising from the controlled area during normal plant operation and outages.

The liquid waste is collected separately in three groups of storage tanks, in accordance with its chemical and radiochemical composition (waste holdup tank, floor drain tank and laundry tank in Angra-1 and high activity group tanks, low activity group tanks and laundry tank belong of this group in Angra-2).

In Angra-2 the Liquid Waste Processing and Storing Systems are designed to process approximately 20,000 m<sup>3</sup> of liquid waste per year.

To assure the protection of the workers, of the population and of the environment against the effect of the ionizing radiation, the treated liquid waste intended for discharge is collected in monitoring tanks. Recirculation and discharge pumps are connected to the monitoring tanks to mix the liquid waste or to return it to the storage tanks.

Before discharge from the monitoring tanks, samples are taken for analysis in the laboratory. Based on the results of the analysis the radiation protection supervisor decides whether the discharge may be made. The discharge, as function of the gamma spectrometry (in Angra-1) or the activity concentration (total gamma as equivalent Cs-137) and gamma spectrometry monitoring weekly mixed samples (in Angra-2), is

performed in accordance with the technical specification for the plants, based on CNEN and IBAMA regulations and on the environmental legislation.

The released activity is monitored on-line. If the maximum allowable value of activity concentration for undiluted discharge water is exceeded an alarm is triggered and the discharge is automatically interrupted.

To optimize doses to Public Individuals, CNEN sets an authorized limit of 0,25 mSv/year for each plant.

### **H.2.1.3 - Solid Waste**

To reduce the potential of migration and dispersion of radionuclides and to minimize the dose to the environment, both plants are equipped with Solid Waste Treatment Systems. These systems process the spent resins, the concentrated liquid waste and the solid waste produced in the operation and maintenance of the plants, and confine them in special packages.

In Angra-1, the concentrates, spent resins and contaminated filters from the purification systems are immobilized in cement and conditioned in liners and special 200-liter metallic drums, within the prescribed requirements for transportation and storage. The non-compacted wastes are conditioned in special metallic boxes. In Angra-2, these wastes are immobilized in bitumen and conditioned in special 200-liter metallic drums.

In both plants, the compressible solid waste is compacted by a hydraulic press, and conditioned in special 200-liter metallic drums.

All the waste forms must fulfill the requirements for final disposal established by CNEN regulations.


To minimize the accumulation of solid radioactive waste, the entrance of materials in the controlled area is limited and controlled. Also, all the material collected in the controlled area is monitored and segregated, according to its physical and radiological features. Whenever possible, such material is decontaminated and reused or released as non-radioactive waste.

The solid radioactive waste produced in Angra-1 is stored in an on-site initial storage facility. This facility, denominated Radioactive Waste Management Center (CGR), is composed of three installations, called Storage Facility 1, Storage Facility 2 (modules 2A and 2B), and Storage Facility 3, all them in operation, see Figures H.1.

In Angra-2, all the produced waste is stored in a compartment inside the plant, called in-plant storage facility (UKA Building) with a total capacity of 1,644 two hundred liters drums.

All packed radioactive waste is monitored to assure that the surface dose rates for transportation do not exceed the established values in regulation CNEN-NE-5.01 [15] and

the resulting occupational exposures are in accordance with the values established in regulation CNEN-NN-3.01 [12].



**Figures H.1** - On site initial waste storage facilities – location and schematic

Up to 1998, the radioactive concentrate produced in the evaporator unit and the spent resins of Angra-1 were packed in 200-liter drums. As the mixture was not homogeneous, the immobilization process was considered improper, because the matrix was not in accordance with the established standard of the regulatory body.

The present Solid Waste Processing System for Angra-1, encapsulates the concentrates and spent resins in cement, inside 1 m<sup>3</sup> shielded liners. The present system, besides generating a more homogeneous product, reduces the occupational dose during the operational process, due to improved shielding.

Storage Facility 1 was built in 1981, with a design capacity for 2,432 drums, being 1488 of low level activity and 944 of medium level activity.

As the construction of a national repository in Brazil is still in planning, drums are being stored in the inspection and backup areas destined to damaged drums to increase the storage capacity of Storage Facility 1.

Thus, the Storage Facility 1 stores now 6,652 packages. As the medium activity area is totally occupied, the medium activity drums are being stored in the low activity area. This fact contributes to increasing the dose rate at the Storage Facility 1 external walls. Another restriction is the impossibility of visual inspections in all stored drums.

These and other non-conformities were pointed out, with subsequent recommendations, in the IAEA Inspection of May 2000, through the Safety Report of Processing and Storage of Radioactive Waste from the Angra-1 Nuclear Power Plant. To fulfill these recommendations new storage facilities were planned and constructed.

In 1992, Storage Facility 2A was built with the capacity to store 621 liners. The remote operation capability was improved to minimize occupational doses. Currently,

this building is being remodelled (under construction) to increase its storage capacity for 783 liners. The packages that were stored in this building were transferred to the Storage Facility 2B and 3.

In 2008, the Storage Facility 2B was built with the capacity to store 2296 drums and 252 liners. Actually, this building is occupied with the liners from Storage Facility 2A. At that time, was also built the Storage Facility 3, with the capacity to store 5612 drums and 300 metallic boxes. In 2012, the Storage Facility 1 will also be remodelled to increase its storage capacity for 4064 drums. Additionally, inspection lanes will be created. After that, all packages from on-site initial storage facility will be redistributed among the three buildings, in accordance to a rearrangement program to be authorized by CNEN.

The inventory of waste stored at Angra site (March 2011) is presented on Tables H.1 and H.2.

**Table H.1 - Waste Stored at Angra Site - Angra-1**

| <b>Waste</b>      | <b>Packages</b> | <b>Location</b>  |
|-------------------|-----------------|--|
| Concentrate       | 2,926           | Storage Facility 1/ Storage Facility 2                       |
| Primary Resins    | 717             | Storage Facility 1/ Storage Facility 2                       |
| Filters           | 512             | Storage Facility 1   |
| *Non-compressible | 937             | Storage Facility 1/ Storage Facility 3 / SG Storage Facility |
| **Compressible    | 810             | Storage Facility 1   |
| Secondary Resins  | 546             | Storage Facility 1   |
| <b>TOTAL</b>      | <b>6,652</b>    | <i>(Includes 204 Inactive drums)</i>                         |

\* Two Steam Generators are stored at SG Storage Facility.

\*\* In 2006, the NPP supercompacted 1938 waste drums from Angra-1. The pellets (crashed drums) were placed inside special metallic boxes (B-25) with 2500 liters of capacity.

**Table H.2 - Waste Stored at Angra Site - Angra-2**

| <b>Waste</b>   | <b>Quantity (drums)</b> | <b>Location</b>              |
|----------------|-------------------------|------------------------------|
| Concentrate    | 179                     | In Plant Storage             |
| Primary Resins | 72                      | In Plant Storage             |
| Filters        | 6                       | In Plant Storage             |
| *Compressible  | 152                     | In Plant Storage             |
| <b>TOTAL</b>   | <b>409</b>              | <i>(Total Capacity 1644)</i> |

\* In 2006, the NPP supercompacted 89 waste drums from Angra-2. The pellets (crashed drums) were placed inside special metallic boxes (B-25) with 2500 liters of capacity.

## H.2.2 - INB FACILITIES

The INB units store low activity nuclear material. The waste produced is minimized due to the high value in the nuclear content of the material processed. The recovery of uranium in all phases of the process is a constant objective not only due to the economic value, but also to avoid the presence of hazardous effluents. The material inventory is presented below, although not all this material is "radioactive waste" in the sense of the Convention.

### H.2.2.1 – Nuclear Fuel Factory (FCN)

The waste is packed in 200-liter metal drums with metal cover and rubber seal. Only 183 drums have been produced so far. They contain contaminated material (gloves, shoes, tools, filters) containing UO<sub>2</sub> (with up to 4.0% enrichment) in the powder form.

The drums are stored inside the production facility. A storage facility is under construction within FCN protected area. After it is finished and licensed by CNEN, all the material stored in the production plant will be transferred to this storage area. All the waste is considered low-level solid radioactive waste (SBN - Table 2, CNEN- NE-6.05 [6])

### H.2.2.2 - Interlagos Processing Plant (USIN) and Botuxim Storage Facility

The area of USIN has about 60,000 m<sup>2</sup>. The site located in an urban industrial area was acquired to receive the USAM Facility but unused at that time. In this site there were 3 storage facilities A, B and C. The Storage Facilities B and C have been disassembled in September 2002. Storage Facility A, with 2,060 m<sup>2</sup>, has been renovated to receive the waste originated from the USAM decommissioning. This process initiated in 1993.

Although belonging to the same company as USAM, the USIN site was not under regulatory control by CNEN, because the process of rare earth separation that used to take place in USIN did not involve significant amounts of radioactive elements, since they were eliminated in previous stages of the process at USAM.

Between 2008 and 2010 was made an inventory of stocks of materials at the plant. This survey has allowed the number of plastic drums and distribution of material that allowed the correction of some previously released values. At a given moment of the operational period of USIN, however, some leakage of the material stored led to the contamination of the area surrounding Storage Facility A and also to radioactive contamination of groundwater. From 1998 to 2002, the area was partially decontaminated. This operation generated 170 plastic drums with radioactive material. The other 1,717 plastic drums stored in USIN were generated during decontamination of the USAM facilities.

Besides this occurrence, the USIN site has received large amounts of the light fraction of monazite sand, as landfill to the swampy areas around the storage facilities. As a result of these landfills, activity concentrations up to 33,000 Bq of <sup>228</sup>Ra per kg of soil could be measured. The decision to clean-up the area in order to release it for

unrestricted use has already been taken by CNEN, and the operator has decided to keep that area under regulatory control and to use it as a temporary waste repository for the decommissioning waste coming from USAM.

In addition to the waste storage, Storage Facility A is also used to store radioactive material (Table H.3) that can still be used as a source for nuclear material and other applications, such as the byproducts of the USAM process, mainly a material called Cake II (*Torta II*), composed basically of thorium hydroxide concentrate. The inventory of Cake II awaits development of improved technology to allow its economical use.

**Table H.3** - Types and amounts of material stored in Storage Facility A

| <b>Packages (100-liter plastic drums)</b>              | <b>Amount</b> | <b>Mass (ton)</b> |
|--|---------------|-------------------|
| Cake II  | 3,283         | 590.94            |
| Moseothorium   | 760           | 83,6              |
| Non- Contaminates Trisodium Phosphate                  | 768           | 92.16             |
| Contaminated Trisodium Phosphate                       | 61            | 7.28              |
| Radioactive Waste (clothes, equipment, wood soil)      | 1,769         | 192.08            |
| Radioactive Waste (soil)                               | 203           | 24.29             |
| <b>TOTAL</b>   | <b>6,844</b>  | <b>990.35</b>     |
| <b>Maritime Containers (30 m<sup>3</sup> capacity)</b> |               |                   |
| Contaminated press-filter canvas                       | 3.0           | 32                |
| Contaminated Wood                                      | 1.5           | 53                |
| Contaminated metal parts                               | 6.0           | 82                |
| Other materials  | 2,5           | 9                 |
| <b>TOTAL</b>   | <b>13.0</b>   | <b>176</b>        |
| <b>Metal Boxes (1m<sup>3</sup> capacity)</b>           |               |                   |
|  | <b>6</b>      | <b>6</b>          |

The area of the Botuxim storage facility has about 284,000 m<sup>2</sup>, where there are 7 silos with ca. 3,500 tons of Cake II stored (Table H.4)

**Table H.4** - Amounts of Cake II stored in Botuxim.

| <b>Concrete silo number</b> | <b>Mass (ton)</b> |
|-----------------------------|-------------------|
| Silo 1                      | 321.48            |
| Silo 2                      | 376.93            |
| Silo 3                      | 374.97            |
| Silo 4                      | 504.32            |
| Silo 5                      | 479.33            |
| Silo 6                      | 778.85            |
| Silo 7                      | 664.19            |
| <b>TOTAL</b>                | <b>3,500.07</b>   |

### H.2.2.3 - Ore Treatment Unit of Poços de Caldas (UTM)

The first uranium mine of Brazil, which was called in the past of Poços de Caldas Industrial Complex (CIPC), has finished operation and is under preparation for decommissioning. As the licensing process took place before the present radiological protection criteria were established in Brazil, there was no previous planning for the decommissioning phase. The main areas that will need attention include the open pit mining area, the waste rock piles and the tailings dam. Up to this moment, the whole area is still under control by the operator. Radiological control is maintained at effluent discharge points, including at the waste dam and at the treatment units for the water drained from the mining area and from the waste rock piles. At UTM, the following materials and/or by-products are considered tailings, radioactive waste, or raw material:

1. Mesothorium, stored in different conditions, namely:
  - a. Disposed of in the waste dam during the 1980's: there are around 13,000 fifty-liter drums corresponding to 1,300 tons of this product.
  - b. Stored in five (5) silos excavated in a clay bank at the slope of the UTM waste dam: there are 2,700 fifty-liter drums, corresponding to 280 tons of the material. The silos are lined and covered with a three-meter thick layer of clay and soil. This operation was performed in 1987.
  - c. Placed in a trench at the slope of the waste dam, in 1984: there are 5,750 fifty-liter drums, corresponding to a total of 600 tons of mesothorium. This trench is covered with a two-meter thick layer of clay and soil.
2. Cake II
  - a. Approximately 11,000 tons of Cake II (wet base) are currently stored
  - b. in sheds, packed in 200-liter drums (19,400 units) and 100-litre plastic drums (16,250 units). Other 1,734 tons of bulk Cake II, which were placed in four concrete silos, are now being treated.
  - c. Additionally, there are 1,600 200-liter drums of Goianite Cake II
  - d. resulting from experiments for the extraction of rare earths from Goianite mineral, which presents a low thorium content; as well as 3,560 200-liter drums of Cake II, corresponding to 534 tons, stored in silos close to the CIPC waste dam.
  - e. Finally, there are 824 200-liter drums (124 tons) of Inaremo, named after the process used by Nuclemon for extracting rare earths from Goianite. Inaremo is characterized by a very low thorium content, being a neutralized waste.
3. Thorium
  - a. Approximately 80 tons of ThO<sub>2</sub>, resulting from Cake II processing in two periods: In 1990, 32.9 tons were disposed of in a pond; in 1995/1996, 46.58 tons were stored in 148 concrete containers.

#### H.2.2.4 - Uranium Concentrate Unit (URA)

The Uranium Concentrate Unit (URA) is located at the uraniferous province of Lagoa Real in the Center-South region of Bahia state. The ore bodies have average  $U_3O_8$  concentrations of about 0.3%. Mining activities are developed at an open pit cast and expected to continue for over 16 years. Uranium extraction is made by the Heap Leach method. The efficiency of solubilization of this method is estimated to be about 70%. The exhausted ore is disposed of in piles along with the waste rocks from the mining activities. The leachate is captured in holding tanks that are lined with geo-synthetic membranes (HDPE). The liquor is then pumped to the milling unit where uranium is isolated by means of organic solvent extraction and then precipitated as ammonium di-uranate.

The licensing process was focused only on the aerosol and gamma exposure pathways, because the facility is not supposed to release any liquid effluent to the environment, since all the processed water has to be pumped back to the process. Thus, no major impacts are expected in the local water river that is not perennial. On the other hand, subsequent facts showed that impacts into the aquifers need attention since these water bodies are also the source of water to local communities. Besides the influence of mining activities on groundwater, other pollutant sources have to be assessed like the waste-rock/leached ore piles as well as the leaching tanks. In order to assess any impact into groundwater, a monitoring program is carried out by the mining operator under regulatory surveillance. Groundwater samples are collected monthly from monitoring wells placed close to the area of direct influence of the facility and close to the population groups living at the site surroundings. Runoff samples are also collected close to the main sources to determine the concentrations of dissolved radionuclides, assessing the drainage contribution to groundwater pollution.

Data from the environmental monitoring program carried out by the mining operator, under regulatory surveillance, are collected from around 30 sampling sites and comprise the following media: groundwater; rainwater; aerosol; radon; gamma exposure (TLD); sediments; soils; pasture; corn; bean; milk; manioc and manioc flour.

The objectives of the monitoring control are: 1) to keep under control the radionuclide fluxes from mining and milling activities to atmosphere and groundwater compartments, according to the release limits prescribed in the nuclear licensing, 2) to assess the potential impacts of the pollutant sources by means of mathematical simulation and 3) to establish the overall environmental management strategy for the uranium production.

#### H.2.3 - NAVY FACILITIES

As already mentioned in **D.4**, the amounts of waste that have been generated by the naval program are very small. The solid waste generated in the controlled areas is stored in standardized two hundred-liter metallic drums, which, after being identified, are transferred to a Radioactive Waste Storage Facility, situated on the site of CEA. Liquid waste is treated in thermo-solar evaporators and the sludge is later classified as solid



waste. Handling, storage and accounting of the waste are under responsibility of the Radiation Protection Division. The aforementioned storage facility is a small building measuring 18 m long by 9.2 m wide, with steel frame, concrete brick walls and asbestos tile roof. It has a storage capacity for 256 two hundred-liter drums. The facility is provided with natural ventilation, fire protection and physical protection equipment, and a drainage system to avoid flooding. In November of 2008, as required by CNEN, the facility underwent a renovation, which consisted of internal and external painting and impermeabilization of the floor. The current waste inventory is presented on the table below.

**Table H.5 - Waste Inventory at CEA**

| <b>Type of Waste</b> | <b>Mass (kg)</b> | <b>Number of Drums</b> |
|----------------------|------------------|------------------------|
| Plastic              | 725.5            | 14                     |
| Paper                | 3,536.8          | 33                     |
| Evaporator Sludge    | 3,488.2          | 30                     |
| Other                | 1,229.6          | 32                     |
| Plastic + Paper      | 203.7            | 2                      |
| <b>TOTAL</b>         | <b>9,183.8</b>   | <b>111</b>             |

## H.2.4 - CNEN INSTITUTES

### H.2.4.1 - IPEN

IPEN has been storing the radioactive waste generated in its own installations since the beginning of operations in 1956.

The Radioactive Waste Department (GRR) is responsible for receiving, treating and temporarily storing radioactive waste generated at IPEN, as well as those generated at many other radioactive facilities all over the country. The main features of the GRR include units for: waste reception and segregation; decontamination; liquid waste immobilization and conditioning; in-drum compaction of compressible solids; spent sealed source and lightning rod disassembly; primary and final waste characterization; storage of untreated and treated wastes. The existing facility, an Integrated Plant for Treatment and Storage of Radioactive Waste, has a total built area of 1,450 m<sup>2</sup> and comprises the following units:

- Changing rooms and radiation protection control: To allow controlled access to the working area.
- Reception and segregation unit: To receive, classify and distribute the waste to proper treatment. If necessary, waste segregation is carried out.
- Liquid waste storage and treatment/conditioning unit: Equipped with suitable containers or devices for operational storage and pre-conditioning of liquids,

either for immobilization or for release to the retention tanks for further discharge to the sewage system.

- Cementation unit: Cementation was the process chosen for conditioning and encapsulating some kinds of wastes such as liquids, wet solids, including ion-exchange resins and activated carbon generated in the reactor operation, sludge, biological and some non-compressible waste.
- Compaction unit: Equipped with a 10-ton hydraulic press. Compressible solids are collected in 60 liter transparent polyethylene bags and pressed into 200 liter metallic drums. The volume reduction factor is about 4-5.
- Lightning rod dismantling unit: Provided with a three-cell glove-box, where  $^{241}\text{Am}$  sources are removed from the devices and packaged in metallic containers.
- Disused source encapsulation unit: Designed to handle source activities up to about 4 TBq  $^{60}\text{Co}$  equivalent. Sources will be withdrawn from original shielding or device and encapsulated in a retrievable package for interim storage.
- Analytical and radiochemical laboratories: For characterization of primary wastes and waste forms.
- Storage facility. For interim storage of drums containing treated waste (see Figure K.1).

The wastes managed at IPEN are characterized by a wide diversity in nature, forms, radionuclide contents and activities, so that, for some types of waste, specific methods of treatment and conditioning had to be developed.

In general, solid and liquids wastes are treated and packaged in 200 liter steel drums, as follows:

- Compressible solids: segregation at the generator installation, compaction and package.
- Non-compressible solids: dismantling and encapsulation in concrete.
- Wet solids: chemical conditioning and immobilization in cement.
- Liquids: Wastes of short half-lives are discharged to the sewage system as liquid effluents after temporary storage for radioactive decay; releases meet the proper radiation protection standards. Wastes of longer half-life are immobilized in cement matrix.

Lightning rods with  $^{241}\text{Am}$  sources were manufactured in Brazil until 1989. In that year, CNEN issued a resolution lifting the authorization for manufacturing of such devices. Since then, radioactive lightning rods are being replaced by regular lightning rods. The radioactive lightning rods removed are delivered to IPEN or to other installations of CNEN. The estimated amount of lightning rods to be collected is about 80,000 pieces. From this amount, IPEN has already collected about 16,578 and dismantled 15,594 units. Smoke detectors are also dismantled and about 29,228 units have been treated until now.

Disused sealed sources represent for IPEN and CNEN by far the largest waste problem from non-power applications, specially due to the long lived radionuclides such as  $^{226}\text{Ra}$  and  $^{241}\text{Am}$ . Sources with low activity or low exposure rate received until 1993 are already conditioned and immobilized in cement as well as the  $^{226}\text{Ra}$  needles collected up to that date, meaning in the last case about 1,000 needles or 200 GBq. Currently, this process has been replaced by packing the sources in a retrievable package. The spent sealed sources dismantling and conditioning unit is currently under construction. In total, GRR has received about 12,000 sealed sources and treated 36% of them.

The facilities for waste management are located inside IPEN, as part of its several nuclear and radioactive installations, properly certified by CNEN.

#### H.2.4.2 - CDTN

CDTN's waste treatment and storage facilities and its support laboratories are shown on Table H.6. Figures H.2 and H.3 show some CDTN facilities used to treat and to store radioactive waste.

Besides the radioactive waste generated at its own laboratories, CDTN has received disused sealed sources from other users, like industries, hospitals and universities. These sources include radioactive lightning rods, smoke detectors, nuclear gauges and teletherapy units, which are stored at CDTN's intermediate storage facility (DFONTE). The main nuclides are  $^{60}\text{Co}$ ,  $^{137}\text{Cs}$ ,  $^{226}\text{Ra}$ ,  $^{241}\text{Am}$ ,  $^{85}\text{Kr}$  and  $^{90}\text{Sr}$ .

The strategy devised and implemented for the management of radioactive waste at CDTN is based on the standard CNEN-NE-6.05 and takes into account the available infrastructure. The main aspects of the management program are:

- registry of the waste and disused sealed sources inventory using an electronic database;
- waste generation minimization by an adequate segregation and characterization;
- volume reduction by chemical treatment for the aqueous liquid waste and compaction and cutting for solid waste;
- cementation of sludge arising from the chemical treatment and immobilization of the non compactable solid waste in cement/bentonite matrix;
- quality control of the final product in order to guarantee safety during storage and to minimize doses to workers and individuals of the public.

Segregation is carried out taking into account the physical, chemical and radiological characteristics of the waste. The liquid waste is segregated into aqueous or organic and the solid waste into compactable and non-compactable. Besides, waste containing short-lived radionuclides is segregated from the ones with long-lived radionuclides, the former being stored for decay and then released from radiological control. Each waste package is identified according to the origin and type of waste it contains.

**Table H.6 - CDTN Waste Treatment Facilities**

| <b>Facilities</b>   | <b>Characteristics</b>   |
|---|--|
| Chemical treatment  | 200 L batch, main components: tanks, filters, pumps, control panel and sample system   |
| Cementation, out-drum mixture   | 200 L batch, main components: tanks, mixer, pump, automatic weighing system and control panel  |
| Compaction  | 16 t press   |
| Cutting/shredding   | Cutting mill, output 80-130 kg/h   |
| Lightning rod dismantling   | Glove box equipped with unbolting system, electrical scissors and other tools  |
| Nuclear gauge dismantling   | Hot cell with shielded windows, manipulators, pneumatic system, and control panel  |
| Package testing   | Facilities for Type A and Type B package testing   |
| Heater system   | Tank with heater device for about 600 L solution   |
| <b>Supporting laboratories</b>  | <b>Main equipment sets</b>   |
| Chemical treatment  | Lab hood with filtration system, pH meters, analytical scale, pumps, jar-test equipment, magnetic stirrers                           |
| Cementation   | Lab hood, glove box, lab oven and many equipment sets using for physical-chemical and mechanical tests                               |
| Thermodifferential analysis   | Room with the suitable equipment to carry out the analysis.  |
| <b>Storage facility</b>   | <b>Description</b>   |
| DFONTE - Intermediate storage building for treated wastes and disused sources | 450 m <sup>2</sup> surface hall with control system for effluents, fence, natural ventilation, appropriate lighting and alarm system |
| Liquid waste storage  | 90 m <sup>2</sup> surface hall with control system for effluents, shelves, appropriate lighting and ventilation.                     |
| Solid waste store   | 4 m <sup>2</sup> room.   |

After being monitored, the segregated waste is transferred to the treatment facilities. All relevant data, like origin, composition, volume or weight, chemical contaminants are registered in a specific form – GUIARR.



**Figure H.2** - (a) Chemical Treatment, (b) Cementation and (c) Compaction.



**Figure H.3** - Intermediate Storage Facility Building -CDTN

Regarding sealed source, lightning rod and smoke detector management, the guidelines are:

- To provide suitable conditioning of brachitherapy and teletherapy sources. The later ones are stored in their original shields;
- To dismantle the lightning rods, smoke detectors, and nuclear gauges and to remove the source in order to reduce the stored waste volume. The sources from the gauges are assessed for possible further use.

Regarding sealed source, lightning rod and smoke detector management, the guidelines are:

- To provide suitable conditioning of brachitherapy and teletherapy sources. The later ones are stored in their original shields;
- To dismantle the lightning rods, smoke detectors, and nuclear gauges and to remove the source in order to reduce the stored waste volume. The sources from the gauges are assessed for possible further use.

A glove box for dismantling of the  $^{241}\text{Am}$  lightning rods and smoke detectors is operational at CDTN. A hot cell for dismantling nuclear gauges is in operation at Laboratory for Treatment of Sources. The removed sources are checked for leaks and their activity is determined for possible reuse.

Regarding  $^{226}\text{Ra}$  sources, they are conditioned in such a way that retrievability is maintained. The sources are inserted in leak-proof stainless steel capsules, which are placed in lead shields; once loaded, the shields are put inside the cavity of an internally shielded 200-liter drum.

The waste packages are identified, monitored and stored at DFONTE. The relevant packages data are registered in a specific form - GUIART. The information of both forms - GUIARR and GUIART - is used as input into the Waste Database of CDTN, where complex searches can be performed and all information about the stored waste inventory can be easily retrieved. Another database - named SISFONTE - contains data about the sealed sources from other users received and stored at CDTN. Among other features, this database performs an on-line update of the activity stored.

#### **H.2.4.3 - IEN**

IEN is storing the radioactive waste generated in its own installations and at other radioactivity users, such as hospitals, industries and research centers. The existing facility for radioactive waste management at IEN includes a compressive unit for compactable material and a storage place. In 2010, a laboratory for treating liquid waste was implemented, but its full operation demands some specific equipment that will be acquired this year (2011).

All the strategy for the management of radioactive waste at IEN is based on the standard CNEN-NE-6.05 and takes into account the available infrastructure.

There is only a simple waste characterization, TRING, whenever possible, reducing its volume, so it can be packaged in a 200-liter steel drum and storing at the proper unit. Liquid waste is simply identified and stored in a different area expecting a treatment unit to go into operation.

## H.2.5 - RESEARCH INSTITUTIONS

The Waste Management Program in Research Institutions (PROGER) started in 1996 with the objective of controlling the radioactive waste management in research institutions throughout Brazil, and to establish common procedures and standards.

Through partnership, information and training of personnel from these institutions, the main lines of action of PROGER are to establish common procedures and best practices, which improve the workers' safety, protect the environment and prevent radiological hazards. In 1999 PROGER was implemented at the University of Brasilia and, as a result, adequate facilities were constructed and proper working procedures were established to manage and control the waste generated in research activities. The model has also been extended to other research institutions. CNEN also routinely assesses Radiological Protection Plans and Safety Assessment Reports from research institutions, in support of the issuance of the Authorization for Operation of these institutions.

## H.2.6 - WASTE REPOSITORY AT ABADIA DE GOIÁS

For the repository of the waste from Goiânia accident, also the 0.3 mSv/y dose constraint defined by the Regulatory Body based on regulation CNEN-NE-3.01 [12] was used during the design of the installation. As the installation contains two buildings, each one related to different activity concentration of  $^{137}\text{Cs}$  in the waste, as already described in this report. The design basis for the first repository (Waste Group 1) a dose limit of 0.05 mSv/y has been applied to critical members of the public while a level 0.25 mSv/y was used to the main repository, in agreement with the Technical Instruction CNEN IT-01/91 [16].

## H.3 - SITING OF PROPOSED FACILITIES (*Article 13*)

### H.3.1 - NUCLEAR POWER PLANTS

The On-Site Storage facility was built at the north side of the Angra site.

The Storage Facility 1 of the on site storage facility was built in 1981. The Storage Facility 2 is composed by the old Storage Facility 2A constructed in 1992 and a Storage Facility 2B constructed in 2009.

To erect the Storage Facility 2B, IBAMA, the national environmental agency, required an Environmental Impact Study, which was submitted and accepted. The Environmental Operational License was issued in 2007.

Together with the Storage Facility 2B, in 2009, a third storage facility (Storage Facility 3) was constructed.

To improve the waste management facilities, a Monitoring Building is being planned. This building will be constructed between Storage Facilities 1 and 2 and will hold

all the equipments and operations related to the new system of waste packages measurement (Gamma Segmented Counter System) for the waste isotopic inventory determination.

This area is part of the south-eastern part of the Brazilian Platform, Studies made in 1982 had demonstrated that there is no sign of failure occurrence or another tectonic activity in the region of Itaorna beach, since the inferior cretacic period.

The storage facility area was constructed on 13,000 m<sup>2</sup> "plateau", as the result of a rock quarry excavation in the Ponta Fina hill.

Engineering measures were implemented in the vertical rocky slope and top of the hill, based on geological-geotechnical mapping.

In order to improve the safety of the upstream slopes of the storage facilities areas, a contention gabion walls and soil nails with gunite concrete were performed, as well as superficial draining system was implemented.

Given the geologic formation of the region, predominantly crystalline rock, there is little indication of underground waters.

Specifically, the hillside where the storage facility is located was technically certified for stability and safety conditions.

In addition, a Storage Facility for the replaced old steam generators from Angra-1 was constructed close to the site dock and within the site boundary and the replacement was concluded in 2009.

Regarding to the spent fuel storage for Angra-1 and 2, and in the future for Angra-3, an additional wet storage facility is being foreseen in order to complement the current on-site storage capacity of the plants. This facility will be under Eletronuclear Eletronuclear responsibility. The design bases of this building will be the same as used for Angra-2 and 3 spent fuel pools. This complementary storage facility will be located in an area between Angra-2 and 3, and will be a shallow foundation structure on sound rock.

### **H.3.2 - LOW AND INTERMEDIATE LEVEL WASTE REPOSITORY**

The present Brazilian nuclear scenario includes three nuclear power plants (NPPs) - Angra-1 and Angra-2, in operation, and Angra-3, under construction - and the use of radionuclides in the industry, medicine, R&D activities and agriculture. For the next future it is also forecasted the construction of four other NPPs and new installations of fuel cycle, in accordance with the Federal Government's plans. Thus the current situation already justifies a construction of a national repository to dispose of all the radioactive waste produced in Brazilian territory.

As mentioned before, in Brazil, CNEN is responsible for the disposal of the radioactive waste generated in the country, in accordance with Brazilian Law 10308 of



2001, which establishes the responsibilities, and the licensing and funding processes for waste repositories.

In addition, in the Previous License for the construction of Angra-3 NPP, the Brazilian authority on environmental matters (IBAMA) requested that the licensing process for the implantation of the National Repository for low and intermediate level waste must be ongoing before the startup and the operation of Angra-3. In accordance to the current construction schedule of Angra-3 this will occur in 2015.

In November 2008, a Project named Low and Intermediate Level Waste Repository, the "RBMN Project", was launched with the objective to have a licensed and commissioned repository to dispose of the low- and intermediate-level waste. The inventory to be disposed of includes the waste from the NPPs operation, nuclear fuel cycle installations and from the use of radionuclides in medicine, industry and R&D activities. Material classified as NORM is not foreseen to be disposed of in this repository. This Project has the objectives to establish, control and execute all the tasks for the implantation of the Brazilian Repository, since its conceptual design until its construction. The concept to be adopted in the construction will be a near-surface multi-barrier repository constructed in accordance with the waste inventory.

The RBMN Project is part of the Brazilian solution for the disposal of radioactive waste generated by the activities of nuclear energy in Brazil. To manage the RBMN it was established a Work Breakdown Structure (WBS) that consists in the following phases: initiating, project management, waste inventory, conceptual design, site selection, licensing, basic and detailed designs, procurement of equipment and instrument, construction, pre-operation, commissioning and closing. The crucial phases for the project success are: conceptual design, site selection, and licensing.

The site selection process for radioactive waste repositories requires a series of sequential activities as the identification of regions of interest, of preliminary areas, of potential areas and, finally, of candidate-sites. The selection should take into account 4 factors: ecological, geological, physiographic and socio-economical. These selection factors are being applied on the possible areas aiming at identifying the promising areas by excluding, accepting and/or electing criteria. As a consequence, some regions of interest for the repository were identified in Brazil. The site selection process is in progress in accordance with the RBMN Project time schedule. CNEN is in negotiation with international expert companies aiming at obtaining external technical support for developing the most complex tasks of the repository site selection and design.

The licensing of the Repository is composed by two processes: the environmental licensing which is responsibility of IBAMA, and the nuclear one, which is given by CNEN through its Directorate for Radiological Protection and Nuclear Safety (DRS), responsible for the evaluation of the Safety Analysis Report of the installation.

## H.4 - DESIGN AND CONSTRUCTION OF FACILITIES (*Article 14*)

Design criteria and conception of the radioactive waste facilities are based on a comprehensive survey done on the volume and physic-chemical and radiological characteristics of the waste to be received and managed in the life of the facility, and an estimation of the future demand.

### H.4.1 - NUCLEAR POWER PLANTS

Angra waste is mixed with cement or bitumen before transfer to the On-site Storage Facility. This operation is performed under requirements for protection of the workers, the public and the environment, according to approved plant procedures.

All packed radioactive waste are monitored to assure that the surface dose rate, for transportation, does not exceed the established values in regulation CNEN-NE-5.0 [15] and the resultant occupational exposure and contamination are in accordance with the values established in regulations CNEN-NN-3.01 [12] and CNEN-NE- 6.05 [6].

The storage of the waste is done according to a layout established previously, to reduce the dose rate in external areas of the building.

The possibility of the environmental contamination in terms of the storage is remote, since all the waste is in the solid form and is conditioned in certified containers. For additional precaution the units of storage are equipped with ventilation systems to assure negative pressures (including high efficiency filtering system) and internal drains directed to sumps subjected to inspections and release control.

The inventory control of the stored waste is made with the aid of validated managing software. The data bank includes information on the physical, chemical, radiological and mechanical features of the packed waste.

Periodic visual inspections are performed to verify possible alterations in the stored packed waste. Moreover, monthly inspections are performed on the general conditions of the building and the installations.

For Storage Facility 2 and Storage Facility 3, the following systems are installed:

- Remote automatic visual inspection equipment;
- On-line external radiation monitoring system;
- Ventilation system to assure negative pressures, including high efficiency filtering system;
- Internal and external drainage systems.

The storage facility for the old steam generators is equipped with on-line radiation monitoring system, ventilation system and drainage systems.

#### **H.4.2 - INB FACILITIES**

At INB all waste after monitoring go through a selection step in order to be separated in different drums according to their characteristics, solids that can or can not be compacted and liquids. After the selection the waste is packed up in identified drums and they are stored within the facility.

All drum radioactive waste are monitored to assure that the surface dose rate, for transportation, does not exceed the established values in regulation CNEN-NE-5.01 [15] and the resultant occupational exposure and contamination are in accordance with the values established in regulations CNEN-NE-3.01 [12] and CNEN-NE- 6.05 [6].

#### **H.5 - ASSESSMENT OF SAFETY OF FACILITIES (ARTICLE 15)**

A comprehensive safety assessment is a requirement established by the licensing regulation in Brazil [3].

##### **H.5.1 - NUCLEAR POWER PLANTS**

For the Angra-1 and Angra-2 plants, a Final safety Analysis Report (FSAR) were prepared. For the Angra-3 plant, a Preliminary Safety analysis Report (PSAR) was also prepared. The FSARs and PSAR followed the requirements of US NRC Regulatory Guide 1.70 - Standard Format and Contents for Safety Analysis Report of LWRs.

Chapter 11 of the FSAR deals with radioactive waste management issue, including waste generation, treatment, in plant storage and the radiation protection aspects.

These reports were reviewed and assessed by CNEN, and extensive use was made of the US NRC - Standard Review Plan (NUREG - 0800).

##### **H.5.1.1 - Onsite Storage Facility**

Before the startup operation of Angra-1 the documentation for the installation of the Storage Facility 1 of the On-Site Storage Facility, establishing the design, security and radiological protection plans, was submitted and approved by CNEN. The Storage Facility 1 was built in 1981. Later, the Storage Facility 2A module was also approved by CNEN and built in 1992.

To erect the Storage Facility 2B, besides the CNEN license, IBAMA, the National Environmental Agency, required an Environmental Impact Study, which was submitted by Eletrobras Eletronuclear (ETN) and evaluated by IBAMA. The Operational Licence for Storage Facility 2 was issued by IBAMA in December 2007 and in January 2009 by CNEN.

The safety and environmental licensing procedures for the construction of the Storage Facility 3 was concluded in the beginning of 2009. This process included:

- A safety evaluation submitted to the Nuclear Regulatory Commission

- An environmental impact study
- An environmental impact report
- A set of Public Hearings for discussions with the Public and local and state Organized Society Members.

## **H.5.2 - OTHER FACILITIES**

### **H.5.2.1 - Fuel Cycle Facilities**

The management of radioactive waste is considered a part of the Safety Analysis Report of all fuel cycle facilities. The information submitted is evaluated by CNEN during the licensing process.

### **H.5.2.2 - Radioactive Waste Repositories**

As mentioned above, the environmental licensing process of any waste repository in Brazil is responsibility of the Brazilian Institute for Environment and Renewable Natural Resources (IBAMA). When radioactive waste is involved, CNEN acts in accordance with IBAMA, assisting this institution in nuclear matters.

In the implementation phase of the National Repository for Radioactive Waste, the Directorate for Radiological Protection and Nuclear Safety (DRS/CNEN) will be called upon to perform the evaluation of the Safety Analysis Report of the installation.

Two projects were implemented by CNEN, in the field of safety assessment of final disposal facilities. The first project had the assistance of the IAEA. The second was conducted within the Federal University of Rio de Janeiro.

The project with IAEA aimed at improving the national capability for assessing the safety of waste disposal facilities, and for this purpose, a multidisciplinary expert group was created and was trained in safety assessment methods, including the use of the relevant computer codes as well as laboratory and field measurements techniques.

In 2002 the International Atomic Energy Agency (IAEA) launched a co-ordinated research project in the field of safety assessment for near surface radioactive waste disposal facilities (ASAM – Application of Safety Assessment Methodologies for Near Surface Waste Disposal Facilities) with the participation of Brazilian experts. The primary objectives of the project were: to investigate the application of safety assessment methodologies used for post-closure safety assessment, in particular the methodology developed under the IAEA's ISAM project, to a range of near surface disposal facilities; and to develop practical approaches to assist regulators, operators and other specialists in their review of such safety assessment.

The Waste Management Coordination (COREJ), under DRS/CNEN structure, is composed by the above mentioned multidisciplinary expert group with 7 PhDs, 4 M.Sc and 3 graduates which is responsible for the Safety Assessment of waste disposal

facilities. In this sense, COREJ has reviewed a number of safety assessment reports originated from nuclear and radioactive facilities across the country. This Coordination has also developed a publication and training material that covered the principles of safety assessment to regulated agents and research institutions, thus disseminating the safety assessment culture among the operators of nuclear and radioactive facilities, in order to improve the technical quality of the safety assessment reports. COREJ staff has been continuously trained in several IAEA training courses in related areas.

### H.5.2.3 - Safety Assessment of Goiânia Repositories

CNEN conducted two safety assessments of the Goiânia repositories, one in the year 1995 and another one in the year 2002, as described below.

#### ➤ The First Safety Assessment (1995)

A robust model or screening model was developed considering that one of the main scenarios for the prediction of the impact of a near surface repository is related with the water pathway. The following scenarios related with the water pathway were considered:

- (a) water ingestion;
- (b) ingestion of contaminated vegetables due to water irrigation;
- (c) ingestion of contaminated animal;
- (d) inhalation of contaminated soil due to irrigation;
- (e) external irradiation due to contaminated soil.

The dose factor was calculated considering a steady concentration of 1,000 Bq/m<sup>3</sup> in the well water, the scenarios above, resulting in:

- Annual Effective Dose =  $4.19 \times 10^{-5}$  Sv;
- Committed Effective Dose =  $2.93 \times 10^{-3}$  Sv.

Three pathways were also considered for intrusion. The following hypotheses were considered for the geosphere:

- The establishment of an Institutional Control Period;
- The continuous linear degradation of the cap, after construction of the repository allowing a higher infiltration rate each year (after 30 years the cap would completely fail);
- The infiltration rate at the surface of the cap would be only a function of the water balance between water fall and evapotranspiration;
- The unsaturated zone thickness bellow the repository bottom at the beginning of the analysis was neglected;
- The concentration inside the repository in the water phase, each year, was calculated taking into consideration the adsorption coefficient of the waste ( $k_d$ ) and the available quantity of water, which is a function of the water balance and the permeability of the cap.

Two cases were studied:

- Model 1: Neglecting the permeability of the top of the vault due to the concrete thickness and applying Darcy law on the bottom of the repository to calculate the flow to the water table;
- Model 2: Neglecting the permeability of the top and bottom of the vault and considering that all the water infiltrated each year leaches the waste based on the adsorption coefficient and flows to the aquifer.

A plume model was used in the aquifer.

### ➤ **Re-Assessment of the Goiânia Repositories (2002)**

The source term considered on this model was conservative: an annual leaching fraction of the waste considers that all the water that enters in the repository leaves the disposal and enters the geosphere (neglects cap and the engineered barriers).

The unsaturated zone thickness below the landfill was considered only at the end of the analysis, based on a transit time.

The model adopted for the saturated zone, to be coupled with the source term, takes into consideration the well-known one dimensional transport equation including dispersion, retardation and decay of the contaminant in the aquifer.

The same data for the geosphere and biosphere used in the 1995 safety assessment was used in the 2002 assessment.

For modelling the biosphere, two kinds of scenarios were considered:

- (a) Intrusion on the site resulting in: (i) direct inhalation of particulate due to contaminated soil, (ii) deposition on vegetables and ingestion by man; (iii) deposition on vegetables, ingestion by animals, meat consumption by man; (iv) deposition of grass, ingestion by the cow, transfer to milk and ingestion by man; (v) ingestion of contaminated soil due to resuspension and (vi) external dose due to the radioactive hazardous materials.
- (b) A residential scenario, that is, the existence of a house near the site (at the border) using water from a well, resulting in: (i) Irrigation, re-suspension and inhalation; (ii) direct consumption of the well water – ingestion; (iii) irrigation of vegetables and consumption by man; (iv) irrigation of vegetables, consumption by animals, consumption of contaminated meat by man; (v) surface water contact, transfer to fish and to man; (vi) irrigation of vegetables, consumption by animals, transfer to milk and ingestion by man; (vii) irrigation and accidental ingestion of contaminated soil; (viii) irrigation and external exposure in the case of radioactive

It should be pointed out that an agriculture scenario can only occur when the engineering barrier is completely destroyed (the concrete is transformed in sand and mixed with the waste). Many countries establish a period between 300 and 500 years for the complete transformation of the concrete barriers, although cracks and modification

on its permeability can occur before this period of time. The results showed that, after approximately 280 years, the doses related to a probable agriculture scenario would be lower than the established limit for intrusion of 1 mSv/y. It should also be pointed out that on the post drilling scenario analysis a limit of 1 mSv/y is used, resulting in the necessity of establishing an institutional control period of 50 years, confirming the results obtained in 1995.

Based on a discovery scenario, a limit dose for intruder of 5 mSv is applied due to a single acute dose and an institutional control period of 40 years would be necessary (in the case of no waste dilution). Under the assumption of 0.25 dilution factor no institutional control period is necessary in this case.

The safety re-assessment of the Goiânia repositories confirmed the results obtained in 1995, as follows:

- The water pathways related to a possible residential scenario near the site is negligible when considered the retention factor (transit time of  $^{137}\text{Cs}$ ) of the unsaturated zone (natural barrier). The maximum concentration below the repository, at any time, would be under the maximum allowed value of 25,000 Bq/m<sup>3</sup> – ( $6.8 \times 10^{-7}$  Ci/m<sup>3</sup>), that could result in a dose for an individual of the critical group of 0.25 mSv/y;
- The consumption habits of the individual of the critical group was over estimated when compared to the real consumption habits of the population nearby the site today;
- Three intrusion scenarios were considered and the most critical one would be the agriculture scenario. If this is assumed to happen only after the complete degradation of concrete (300 to 500 years), it would be of no importance, since after 280 years the doses would be lower than the allowed limit of 1 mSv/y. If in the case of Goiânia the concrete transforms into sand before the usual time of 300 to 500 years, an institutional control period of approximately 280 years would be necessary;
- If one neglects this possibility (degradation of concrete in time lower than 300 years) the most important scenario would be the post drilling scenario and an institutional control period of 50 years would be necessary;
- It should also be pointed out that the results of seven years of Environmental Monitoring Program (PMA) at the site proved that it is very unlikely to find in the future concentrations of  $^{137}\text{Cs}$  in the aquifer which will be dangerous to the population living near the site (Concentrations lower than the detection limit of 200 Bq/m<sup>3</sup> -  $5.4 \times 10^{-9}$  Ci/m<sup>3</sup> were obtained until today).

Finally, it is important that, before the end of the institutional control period of 50 years, a new evaluation of the safety of the Goiânia repositories be conducted by CNEN, based not only on the probably improved local data such as: (i) geosphere information (ii) demographic growth information; (iii) variation of possible consumption habits by the population, but also based on the improving capability and knowledge of CNEN.

As mentioned in **A.2.6**, a new long-term safety assessment must be performed and presented in 2012.

### **H.5.3 - INB FACILITIES**

The solid and liquid waste generated at INB-Resende is placed in proper drums, which are duly identified and transferred to the low activity initial waste storage facility. Such facility is located within the old material storeroom building of the Conversion and Pellets Factories. It was designed in two modules. The Module I has been already built with an area of 325 m<sup>2</sup>, subdivided in two areas: area 1 and area 2. The access to both areas is done through different gates.

In the area 1, drums of solid wastes will be stored in proper positions with maximum design capacity of 444 drums. In the area 2, drums of liquid waste will be stored with maximum design capacity is 120 drums.

For the second Module it is foreseen an area of approximately 238 m<sup>2</sup>, suitable for future modular expansion. The design capacity will be 336 and 96 drums of solid and liquid waste, respectively.

The access to Module I is mandatorily done through an access control point when the drum storage process is being carried out. Such control point comprises a cloakroom and a shower room, which are supposed to be used in case of accidents with contamination of the skin and body of occupationally exposed individuals.

In URA, it was built an unit, which is in licensing process, for the descontamination of materials from the controlled areas. It is a masonry building, with appropriate facilities for the appropriate monitoring activities, separation, washing and decontamination facilities for these materials. This building is also prepared to storage of items not decontaminated, which will be cataloged and arranged according to specific procedures. A future expansion of the installation is possible due to how the unit was built. However, it is emphasized that the work of skilled professionals who implement simple and effective techniques, which are aimed at producing a minimum of materials to be stored. All wastewater will be directed to the wastewater treatment system unit.

### **H.6 - OPERATION OF FACILITIES (*Article 16*)**

The responsible for the safety of the radioactive waste facilities is the operator. Information on the conduct of operation is submitted to CNEN in the corresponding Safety Analysis Report, and is reviewed during the licensing process. The operation is subject to CNEN regulatory inspection program, and periodical reports have to be submitted according to regulation CNEN-NE-1.14 [5] and specific licensing conditions.



## H.7 - INSTITUTIONAL CONTROL AFTER CLOSURE (*Article 17*)

### H.7.1 - ABADIA DE GOIÁS REPOSITORY

In 1988, the IRD/CNEN, through its Department of Environmental Radiological Protection began the implementation of the Environmental Monitoring Program (PMA) around the interim storage facility for the radioactive waste from the decontamination of the areas affected by the radiological accident of Goiânia.

Due to the need of characterizing the area that would site the repository, the results obtained in that Program for the period between 1988 and 1992 were used as a pre-operational Program for the repositories.

IRD/CNEN continued with the environmental monitoring program until 1996, when the responsibility for the program was transferred to the Midwest Regional Center for Nuclear Sciences (CRCN-CO) of the District of Goiânia.

The program includes a TLD net around the site, and analyses of samples of surface and groundwater, soil, sediments, pasture and milk to determine the quantity of  $^{137}\text{Cs}$ .

IRD/CNEN implemented a monitoring control program in 1998, including auditing records related to site monitoring and the duplicate sampling program, that includes all environmental media included in the monitoring program performed by CRCN-CO. Results of this program control program attest the good performance of the laboratory in charge of the monitoring program and the integrity of the repository.

Although not required by regulation, the laboratory of CRCN-CO participates from the National Intercomparison Program sponsored by IRD/CNEN. The results are presented regularly at the annual environmental monitoring report and indicate a good performance.

The repository structures are not supposed to have any release of radioactive material. Therefore, no operational level on activity concentration was defined for the installation. Any increase of the background levels shall be considered as a violation of the integrity of the repository and will demand further investigation of the situation.

According to an agreement formalized between CNEN and the Goiás State, the institutional control, started in 1998, will be maintained over 50 years with the possibility of being extended for another 50 years.

## **SECTION I - TRANSBOUNDARY MOVEMENT**

### **I.1 - TRANSBOUNDARY MOVEMENT (*Article 27*)**

The Brazilian policy related to transboundary movements of spent fuel and radioactive waste follows international practices. According to this policy, no radioactive waste shall be imported into the country.

The following section describes a case of shipment of spent nuclear fuel from a research reactor to the original supplier country.

#### **I.1.1 - SHIPMENT OF IPEN SPENT FUEL TO THE ORIGINAL SUPPLIER COUNTRY**

After 40 years of the IEA R-1 reactor operation, 127 Spent Fuel Assemblies (SFA's) had been stored at the facility, being 40 in a dry storage and the other 87 in the reactor storage pool. In 1996, CNEN started negotiation with US-DOE to return the SFA's of IEA-R1 to USA. Finally, in 1998, an agreement was achieved between CNEN and US-DOE and in November 1999 the shipment was successfully performed. This section describes the operational and logistic experience of the SFA's transport.

##### **I.1.1.1 - Companies Contracted for the Transport Operation**

The contract between CNEN and DOE was signed in 1998. Edlow International Co. and the German Consortium formed by Nuclear Cargo & Services (NCS) and Gesellschaft fur Nuklear-Service (GNS) were hired to perform the transport. Tec Radion Comercial Ltda (TRION) was subcontracted by Edlow to provide the necessary infrastructure for loading, transporting within Brazilian territory, and customs documents.

The German Consortium provided 4 transport casks (two GNS-11 and two GNS-16), one transfer cask, equipment and experts to handling their equipment. IPEN performed the necessary tasks to fulfill the Brazilian legislation requirements, such as: the export license, a detailed Transport and Security Plan, safeguards documents, as well as operational and radiological protection support for the entire operation.

##### **I.1.1.2 -Transport Equipment Description**

The transport casks were designed in a "sandwich" construction. The cylindrical cask consisted of the following components: inner liner with inner liner bottom, lead filling, wall with bottom plate, side wall cover sheet with spacer wire, head ring, primary lid and protective plate. The maximum weight of the cask was 13,230 kg. The capacity of each cask was 33 spent fuel assemblies.

### **I.1.1.3 - Fuel Cutting Equipment**

Before the beginning of the loading operation, 19 control fuel assemblies were cut 1.27 cm from the cut line to the interior fuel plates. The cutting operation of the five control fuel assemblies stored in the dry-storage was performed in the first floor of the reactor building. For cutting the 14 control fuel assemblies stored in the reactor pool, an underwater saw was used. This tool was specially designed and constructed in Brazil under supervision of Edlow/Trion.

### **I.1.1.4 - Loading and Transportation**

On September 16, 1999, four containers, two with the GNS-11 casks and two with equipment, arrived at IPEN. The two GNS-16 casks arrived on October 7. German experts, supported by IPEN technicians and the transportation company staff hired by Edlow/Trion, removed the equipment from the containers and placed it on a truck, which were transported to the reactor building.

On September 21, the rotary lid was positioned on top of the first transport cask to be loaded, and some cold tests, with a dummy element, were performed. A transfer cask, 4-ton weight was used to transfer the assemblies from the wet storage to the transport cask. The SFAs were lifted from the storage racks inside the reactor pool with a special tool and positioned inside a plastic tube located on a metallic platform located at 2 meters from the pool surface. The transfer cask was submerged inside the reactor pool over the assembly to be removed. The assembly was guided to one of the 33 positions of the cask. After the cask loading, a water tank was positioned above the cask and filled with 4,000 liters of water. Finally, the cask was closed and the water was drained from it and from the water tank. This operation was repeated for the 87 assemblies stored in the wet storage. For the other 40 SFAs stored in the dry storage, the transfer cask was not used.

On October 15 the four GNS casks had been loaded with a total of 127 Brazilian spent fuel assemblies. Then, decontamination procedures were performed. On October 20 all the equipment and cask were removed from the reactor building to the containers. The casks were sealed and controlled by safeguards inspectors from ABACC (Brazilian-Argentine Agency for Accounting and Control of Nuclear Materials) supervised by IAEA.

On November 3, the transport operation was initiated after approval from the Brazilian regulatory bodies (Nuclear and Environmental). The licenses were issued by CNEN and IBAMA (Environmental Brazilian Agency), which required documents relative to transport, radiation, physical protection, and an environmental impact evaluation. Also the GNS 11 and GNS 16 certificates issued by American and German authorities had to be revalidated in Brazil. Opposition from environmental organizations, local politicians and harbor union demanded a comprehensive public information work, including debates and press briefing, to overcome this opposition and avoid legal action against the operation.

On November 4 at dawn, a huge convoy consisting of 5 trucks (one spare) escorted by Federal, State and County Police arrived in the harbour of Santos. It is also worthy to note that the highway and the main avenues and streets in São Paulo and Santos were closed for traffic during the operation. Loading trucks were available at strategic places, to be used in case of need. Loading of the containers in the ship was concluded in 42 min. Before and during all shipment operation, the workers were monitored by the CNEN radiation protection personnel. At 4:50 am, the ship left the harbour escorted by boats of the federal police. At the exit of the harbour, these boats were replaced by a frigate of the Brazilian Navy, which followed the ship until a distance of 200 miles away from the Brazilian coast. At this point the Brazilian responsibilities over the fuel were terminated.

#### I.1.1.5 - New Shipment of Fuel to USA

On November 2007, 33 spent fuel elements stored in the IEA-R1 reactor pool and containing uranium of US origin were shipped back to Savannah River Laboratory, South Carolina, USA. This operation, which was very similar to the one of 1999, when 127 spent fuel elements were shipped back to the USA, used a different transport cask LWT supplied by American company NAC.

#### I.1.2 - PACKING AND REPATRIATION OF US-ORIGINATED SOURCES

In addition to the operation carried out in 2007 (described in the National Report of Brazil 2008), a joint team of Los Alamos National Laboratory Off-Site Source Recovery Project (LANL-OSRP) and CDTN carried out a disused sources conditioning operation in preparation for repatriation to the USA, in September 2010. This time a total of 800 cesium and cobalt sources from old industrial gauges and cesium brachytherapy sources were conditioned in packages licensed for transportation. As of May 2011, these packages are temporarily stored inside the CDTN waste storage building awaiting shipping to the USA (see Figures I.1).



**Figures I.1** – (a) B-25 box loaded with disused industrial gauges, (b) transport shields with brachytherapy and industrial sources removed from original gauges

## Section J – DISUSED SEALED SOURCES

### J.1 - DISUSED SEALED SOURCES (*Article 28*)

All the disused sealed sources that are not returned to the manufacturer have been or will be dismantled from its device or shielding for further disposal. Meanwhile, disused sources are stored in interim storage facilities at CNEN Institutes.

#### J.1.1 - DISUSED SOURCE STORAGE

The inventory of disused sources stored at CNEN institutes in March 2011 is presented on Table J.1. The occupational rate of the storage facility is also presented.

**Table J.1** - Disused sources in storage

| Institute    | Number of Sources | Total Volume (m <sup>3</sup> ) | Total Activity (Bq) | Occupation Rate (%) |
|--------------|-------------------|--------------------------------|---------------------|---------------------|
| IPEN         | 170,310*          | 247                            | 4.73E+14            | ~99                 |
| CDTN         | 16,888**          | 101                            | 1.83E+14            | ~21                 |
| IEN          | 11,071            | 114                            | 2.68E+14            | ~99                 |
| <b>TOTAL</b> | <b>198,269</b>    | <b>462</b>                     | <b>9.24E+14</b>     |                     |

\* This includes 158,386 <sup>241</sup>Am and <sup>226</sup>Ra sources from lightning rods and smoke detectors

\*\*This includes 15,092 <sup>241</sup>Am and <sup>226</sup>Ra sources from lightning rods and smoke detectors

Nuclear medicine installations have usually just weak calibration sources. Disused sources are stored in the installation but the main concerns are towards the quality of those sources still in use.

#### J.1.2 - PROGRAM FOR COLLECTING OF DISUSED SOURCES AND RADIOACTIVE WASTE

After the large radiological accident in Goiânia with a disused <sup>137</sup>Cs source in 1987, CNEN contacted all users of radioactive material in the country to participate in the effort to solve the problem of the disposal of disused radioactive sources.

Periodically, CNEN conducts regional operations to collect radioactive waste from several radioactive installations. This waste includes disused sources from medical, industrial and agricultural applications.

Two big campaigns were conducted, one in 1998 in the South Region and another in 1989 for the Northeast to collect disused radioactive sources. For this operation, an especial truck and Type A containers were purchased. Since then, smaller campaigns have been conducted in all national territory. In 2001 a campaign was conducted in the Central-West region and in 2002, two campaigns, one for the Northeast and another for the South regions, were carried out.

The types of sources collected include small radium needles, lightning rods, and large sources used in radiotherapy. The sources are later transferred to the storage facilities existing at CNEN institutes (see Figure J.1).

In the last three years, experts from the CNEN recovered thousands of spent sources, as shown on detail on Tables J.2, J.3 and J.4.



**Figure J.1** - Disused source storage at CDTN

**Table J.2** - Number of Recovered Spent Sources Collected at IEN - 2008/2011

| <b>RAD</b>   | <b>Type of source</b> | <b>Quant</b> | <b>Total activity (Bq)</b> | <b>Date of storage</b> |
|--------------|-----------------------|--------------|----------------------------|------------------------|
| Am-241       | Lightning rod         | 38           | 8.02E+8                    | 16/01/08               |
| Am-241       | Smoke detector        | 3,050        | 5.64E+8                    | 16/01/2008             |
| Am-Be        | Sealed source         | 03           | 1.17E+11                   | 21/05/2008             |
| Tritium      | Sealed source         | 163          | 3.62E+10                   | 17/06/09               |
| Ni-63        | Sealed source         | 7            | 1.11E+9                    | 14/05/08               |
| Ir-192       | Sealed source         | 14           | 3.34E+12                   | 12/06/08               |
| Se-75        | Sealed source         | 3            | 2.7E+11                    | 29/10/08               |
| Sr-90        | Sealed source         | 4            | 1.52E+9                    | 06/08/08               |
| Kr-85        | Sealed source         | 51           | 7.4E+9                     | 01/04/09               |
| Ra-226       | Sealed source         | 1            | 740E+3                     | 23/06/10               |
| Co-60        | Sealed source         | 24           | 2.08E+14                   | 14/05/08               |
| Cs-137       | Sealed source         | 146          | 4.05E+11                   | 14/05/08               |
| <b>TOTAL</b> |                       | <b>3,504</b> | <b>2.12E+14</b>            |                        |

**Table J.3** - Number of Recovered Spent Sources Collected at CDTN - 2008/2011

| <b>RAD</b> | <b>Type of Source</b> | <b>Quant</b> | <b>Total Activity (Bq)</b> | <b>Date of Storage</b> |
|------------|-----------------------|--------------|----------------------------|------------------------|
| Cs-137     | Density Gauge         | 1            | 2.60E+08                   | 20-02-08               |
| Cf-52      | Process Analyzer      | 4            | 3.7E+06                    | 20-02-08               |
| Cs-137     | Density Gauge         | 6            | 4.42E+09                   | 26-02-08               |
| Co-60      | Teletherapy           | 1            | 2.48E+13                   | 04-04-08               |
| Cs-137     | Density Gauge         | 2            | 4.61E+09                   | 04-04-08               |
| Cs-137     | Brachytherapy Source  | 22           | 1.63E+10                   | 08-04-08               |
| Am-241     | Level Gauge           | 1            | 3.62E+09                   | 30-04-08               |
| Kr-85      | Thickness Gauge       | 1            | 2.68E+09                   | 15-05-08               |
| Co-60      | Density Gauge         | 9            | 2.18E+08                   | 30-11-07               |
| Am-241Be   | Moisture Gauge        | 1            | 3.60E+08                   | 02-07-08               |
| Cs-137     | Calibration source    | 2            | 1.0E+06                    | 02-07-08               |
| Kr-85      | Thickness Gauge       | 1            | 1.31E+09                   | 11-09-08               |
| Cs-137     | Density Gauge         | 12           | 1.68E+10                   | 22-10-08               |
| Cs-137     | Density Gauge         | 1            | 4.68E+09                   | 21-11-08               |
| Cs-137     | Calibration source    | 1            | 1.00E+05                   | 27-11-08               |
| Cs-137     | Density Gauge         | 15           | 8.17E+10                   | 19-12-08               |
| H-3        | Neutron Generator     | 1            | 7.86E+10                   | 23-12-08               |
| Cs-137     | Density Gauge         | 6            | 4.95E+10                   | 06-02-09               |
| Cs-137     | Density Gauge         | 2            | 1.32E+09                   | 09-04-09               |
| Cs-137     | Density Gauge         | 6            | 2.88E+10                   | 15-04-09               |
| Cf-252     | Process Analyzer      | 2            | 7.3E+07                    | 15-04-09               |
| Cs-137     | Density Gauge         | 9            | 9.99E+10                   | 16-04-09               |
| Cs-137     | Brachytherapy Source  | 24           | 1.01E+10                   | 14-05-09               |
| Co-60      | Teletherapy           | 1            | 2.66E+13                   | 14-05-09               |
| Co-60      | Brachytherapy Source  | 15           | 5.03E+06                   | 15-05-09               |
| Ni-63      | Process Analyzer      | 1            | 5.16E+08                   | 16-06-09               |
| Am-241     | Thickness Gauge       | 1            | 1.06E+10                   | 08-07-09               |
| Cs-137     | Brachytherapy Source  | 18           | 1.86E+10                   | 20-08-09               |
| Cs-137     | Density Gauge         | 2            | 3.99E+09                   | 04-09-09               |
| Cs-137     | Density Gauge         | 19           | 2.48E+11                   | 24-09-09               |

Table J.3 - Cont.

| <b>RAD</b>   | <b>Type of Source</b> | <b>Quant</b> | <b>Total Activity (Bq)</b> | <b>Date of Storage</b> |
|--------------|-----------------------|--------------|----------------------------|------------------------|
| Cs-137       | Calibration source    | 1            | 2.00E+05                   | 07-10-09               |
| Cs-137       | Density Gauge         | 13           | 3.71E+09                   | 09-10-09               |
| Cs-137       | Density Gauge         | 8            | 3.43E+10                   | 03-02-10               |
| Kr-85        | Thickness Gauge       | 8            | 8.39E+10                   | 25-05-10               |
| Am-241       | Thickness Gauge       | 2            | 1.81E+09                   | 25-05-10               |
| Co-60        | Thickness Gauge       | 1            | 7.60E+06                   | 12-09-10               |
| H-3          | Process Analyser      | 1            | 2.08E+07                   | 05-10-10               |
| Cs-137       | Brachytherapy Source  | 20           | 2.36E+10                   | 25-11-10               |
| Cs-137       | Density Gauge         | 3            | 8.73E+09                   | 09-12-10               |
| Co-60        | Thickness Gauge       | 5            | 3.78E+07                   | 09-12-10               |
| Cs-137       | Density Gauge         | 6            | 1.04E+10                   | 14-12-10               |
| Cf-252       | Process Analyzer      | 2            | 6.72E+07                   | 15-12-10               |
| Am-241       | Thickness Gauge       | 1            | 3.60E+09                   | 28-12-10               |
| Cs-137       | Calibration Source    | 1            | 3.00E+05                   | 28-12-10               |
| C-14         | Standard Source       | 1            | 4.00E-03                   | 08-02-11               |
| H-3          | Process Analyser      | 7            | 8.00E-04                   | 08-02-11               |
| Cs-137       | Density Gauge         | 18           | 1.06E+10                   | 25-03-11               |
| <b>TOTAL</b> |                       | <b>285</b>   | <b>5.23E+13</b>            |                        |



**Table J.4** - Number of Recovered Spent Sources Collected at IPEN - 2008/2011

| <b>RAD</b>   | <b>Type of Source</b> | <b>Quant</b> | <b>Total Activity (Bq)</b> | <b>Date of Storage</b>   |
|--------------|-----------------------|--------------|----------------------------|--------------------------|
| Am-241       | Sealed Source         | 24           | 1.82E+11                   | 17/03/2008 to 24/02/2011 |
| Am-241B      | Sealed Source         | 6            | 4.21E+10                   | 30/09/2008 to 28/12/2010 |
| Ba-133       | Sealed Source         | 1            | 3.10E+05                   | 01/10/08                 |
| Cd-109       | Sealed Source         | 2            | 3.49E+03                   | 11/12/2008 to 02/12/2010 |
| Cl-36        | Sealed Source         | 1            | 8.13E-08                   | 02/12/10                 |
| Cm-244       | Sealed Source         | 2            | 5.15E+09                   | 17/03/2008 to 18/03/2010 |
| Co-57        | Sealed Source         | 2            | 2.95E+06                   | 02/12/2010 to 02/02/2011 |
| Co-60        | Sealed Source         | 59           | 1.19E+14                   | 19/06/2008 to 25/03/2011 |
| Cs-134       | Sealed Source         | 1            | 4.71E-07                   | 02/12/10                 |
| Cs-137       | Sealed Source         | 250          | 2.48E+11                   | 19/06/2008 to 03/03/2011 |
| Fe-55        | Sealed Source         | 3            | 1.01E+08                   | 11/12/2008 to 24/02/2010 |
| H-3          | Sealed Source         | 17           | 0.00E+00                   | 07/11/08                 |
| I-125        | Sealed Source         | 1            | 6.94E+02                   | 15/07/08                 |
| Ir-192       | Sealed Source         | 1,879        | 3.71E+12                   | 07/07/2008 to 15/12/2010 |
| Kr-85        | Sealed Source         | 13           | 6.10E+10                   | 15/05/2008 to 07/02/2011 |
| Na-22        | Sealed Source         | 1            | 1.24E-04                   | 02/12/10                 |
| Ni-63        | Sealed Source         | 11           | 3.21E+09                   | 02/09/2008 to 11/11/2010 |
| Pm-147       | Sealed Source         | 19           | 1.49E+10                   | 09/06/2008 to 02/12/2010 |
| Pu-238       | Sealed Source         | 1            | 3.67E+04                   | 02/12/10                 |
| Ra-226       | Sealed Source         | 1            | 3.70E+05                   | 27/01/11                 |
| Se-75        | Sealed Source         | 8            | 1.48E+12                   | 10/09/2008 to 04/10/2010 |
| Sr-90        | Sealed Source         | 10           | 1.03E+10                   | 09/06/2008 to 02/12/2010 |
| Tl-204       | Sealed Source         | 3            | 1.77E+05                   | 09/06/08                 |
| Am-241       | Lightning rod         | 746          | 7.46E+10                   | Mar/2008 to Mar/2011     |
| Ra-226       | Lightning rod         | 11           | 4.07E+08                   | Mar/2008 to Mar/2011     |
| Am-241       | Smoke detector        | 5,374        | 1.77E+08                   | Mar/2008 to Mar/2011     |
| <b>TOTAL</b> |                       | <b>8,446</b> | <b>1.25E+14</b>            |                          |

## SECTION K - PLANNED ACTIVITIES TO IMPROVE SAFETY

Safety culture requires a questioning attitude and a search for excellence. Therefore, notwithstanding the good safety record, nuclear operators and regulators in Brazil are constantly working on safety improvements.

In the area of legislation, at present a bill of law is under discussion establishing administrative and monetary penalties to all nuclear facilities and services in cases of non-compliance. This is expected to strengthen the enforcement powers of CNEN.

### K.1 - IMPROVEMENTS IN THE NUCLEAR POWER PLANTS

An Isotopic Waste Characterization Program is underway in order to determine the isotopic inventory, aiming the final disposal.

The replacement of the two steam generators of Angra-1, in the beginning of 2009, has improved the plant safety margins and, as a byproduct, has provided a revised safety analysis, with newer methods and codes.

### K.2 - IMPROVEMENTS IN THE RADIOACTIVE WASTE AREA

CNEN has developed a systematic approach for radioactive waste management in Brazil, aimed at harmonizing waste management approaches across the country. Still, some potential improvements have been identified, namely:

- The site selection process to the national repository is in progress. After identification of the regions of interest, it was applied the exclusionary criteria in order to eliminate those areas not acceptable. In sequence, those areas were analysed under the point of view of the avoidance criteria. Its application would be made, in a first approach, with rigorous restriction. In case remains a very small area, those criteria would be in somehow relaxed. Finally, in a third step the suitability criteria shall be applied. The remaining area will be considered the candidate sites. Then, to the suitability criteria shall be applied weights in order to recognize a priority order and therefore the preferred sites.
- CNEN is in contact with international expert companies for contracting technical support and socio-political consultancy for site selection.
- The continued development of public acceptance and democratic participation programs for waste repositories. In this sense, in 2008 CNEN established the CIS Project - *Communication and Interaction with the Society*, with the aim of developing policies and strategies relate to public acceptance for the national repository for low and intermediate level waste. A network of people associated to many different areas in nuclear field, including representatives from Eletrobras Eletronuclear (ETN) and Brazilian Nuclear Industries (INB), was created to discuss, to study and disseminate best practices of communications with stakeholders in the nuclear area. A document was prepared presenting aspects related to risk and risk perception; possible strategies to be used, their

strengths and limitations; interaction with stakeholders and communication problems. This document is currently printing.

- The development of a unified and standardized database that records the national radioactive waste inventory.
- Increasing of the capacity of CNEN institutes to treat and store radioactive waste.
- Training, recruiting and retention of human resources, in light of the forecasted resurgence of nuclear activities in the country and of the foreseen reduction of the labour force in the field, due to retirements and lack of retention.
- The need to review the regulatory approach for the research installations, performing a closer surveillance of their waste management activities.
- The development of a regulatory body which is independent of all its regulated agents. As mentioned in item **E.3**, the Brazilian Government, through CNEN, has assured the independency of regulatory activities in the nuclear area. In the case of regulation activities applied to Eletrobras Eletronuclear – ETN (the organization concerned with the promotion and utilization of nuclear energy for electricity generation) the independence can be seen from a governmental structure point of view. While CNEN is under the Ministry for Science and Technology (MCT), ETN is under the Ministry for Mines and Energy (MME), as shown in Figure E.1. Within the framework of CNEN, the Directorate of Radiation Protection and Nuclear Safety (DRS) is in charge of CNEN's regulatory body functions and does not operate any nuclear or radioactive installation. As can be noted in Figure E.4, this allows effective separation from the production and promotion activities performed by the Directorate for Research and Development (DPD), whose institutes are considered by DRS as any other licensee, subjected to the same rules and regulations. Although, CNEN has assured a functional independency between nuclear regulatory activities and the others as promoting and research and development activities, the Federal Government took the political decision to create an administratively and legally independent regulatory body. It will be a federal agency independent of CNEN. The new agency will be created by a federal law. A Working Group is in charge to propose the necessary changes in legislation and in the creation of this agency.

The main challenge is certainly the establishment of a National Repository for Radioactive Waste. The Project involves several specialties in different professional fields. In each one of them CNEN and other Brazilian institutions have different degrees of accomplishment. A coordinated effort is being carried out to make possible to have the repository still operational in the second decade of 21<sup>st</sup> century.

### **K.3 - NEW WASTE STORAGE FACILITY AT IPEN**

The existing storage for treated waste is being restructured to receive 850 m<sup>2</sup> of extra area, divided into two sheds. The first shed was concluded in 2010 and treated

waste was transferred from the old building to the new one. The second shed will be concluded by July, 2011 to receive untreated wastes.



**Figure k.1** -New radioactive waste storage (outside and inside view) at IPEN

#### **K.4 - PLANS FOR DECOMMISSIONING USIN**

The decommissioning of the plant is described in Section **F.6.3.3** and is scheduled to be executed in three phases: (i) decontaminate the area without buildings and store contaminants segregated in the warehouse, (ii) transfer the radioactive waste stored in the shed, including the radioactive waste generated in the decontamination of the land for a interim storage facility or a final disposal facility (iii) decontaminate and demolish the shed, clean up the soil in the area of the shed and transfer the radioactive waste generated in the decontamination of the shed for an intermediate storage facility or to the national repository.

INB decided that the area will be decontaminated for unrestricted use. The Decontamination Plan was approved by CNEN and by the São Paulo State environmental agency (CETESB). The decontamination work is being performed in the free area (not built) around of the shed A, but depends on weather conditions.

The second and third stages of decommissioning depend on the construction of an intermediate storage facility or a national repository to transfer the waste that will be generated in the decommissioning processes and the currently waste stored at the plant. Situation still undefined. However, as mentioned in item **H.3.7**, in November 2008, a Project named Low and Intermediate Level Waste Repository, the “RBMN Project”, was launched with the objective to have a licensed and commissioned repository to dispose of the low- and intermediate-level waste. This Project has the objectives to establish, control and execute all the tasks for the implantation of the Brazilian Repository. The RBMN Project is underway and is part of the Brazilian solution for the disposal of radioactive waste generated by the activities of nuclear energy in Brazil.

## **K.5 - PLANS FOR A BRAZILIAN RADIOACTIVE WASTE ENTERPRISE**

The Brazilian law establishes that the responsibility for the final disposal of the radioactive waste shall be of the Federal Government and it will be carried out by the National Commission for Nuclear Energy (CNEN).

The radioactive waste generated by nuclear and radiological activities has been stored in on-site initial storage facilities or in intermediate storage facilities in the Research Institutes of CNEN, always under the control and supervision of the Directorate for Radiological Protection and Nuclear Safety (DRS) of CNEN.

The Brazilian long-term government program establishes the implementation of a Radioactive Waste Management Policy. One of its tasks is the implementation of the Brazilian Enterprise for Radioactive Waste Management (EBRR), an entity which shall focus its activities on waste management and final disposal. The legal acts for EBRR implementation were prepared by CNEN and submitted for analysis and approval by the legislative authority.

It is recognized that an autarchy like CNEN does not have the necessary flexibility, dynamism and budgetary freedom for being efficient in managing this scope of activities.

Also, aiming at giving financial support for operating the EBRR, the Brazilian Law 10308 of 2001 specifies provisions for applying the "polluter pays" principle by allowing CNEN to charge the facility generating radioactive waste with corresponding taxes.

It is proposed to gather these resources in a fund to be created, in order to provide the means for operating the EBRR. The financial resources so obtained shall be applied at market interest to assure the maintenance of the repositories during their operational lives.

The EBRR would be a stock company having the Government the majority of the votes. In the company capitalization phase the Government shall provide the majority of the capital resources. It is expected that this phase shall last up to the beginning of operation of the first repository for low and intermediate level wastes.

A feasibility study was carried out on the implementation of EBRR based on the following scenarios.

- In the initial phase, the company shall be only responsible for the management of the low and intermediate level wastes. The high level wastes are not the initial scope of the EBRR.
- The minimum EBRR capital would be sufficient for the construction of the first repository of low and intermediate level waste and corresponding expenses with EBRR during that initial phase.
- The capital provider would be the Federal Government. A set of different possibilities for providing that support is analyzed in the feasibility study of EBRR. Among those, it is also considered that the resources could come through the tariff of the energy generated by Nuclear Power Plants.

- The capacity of the first module of the repository is evaluated for 30 years of activity of the sector.
- The time of construction of the first module of the repository, after being licensed, is estimated in 5 years. It is not considered in that time the site selection and approval. The impact in the energy tariff in that case is not significant.

The strategy to create the EBRR comprises in an initial operation using CNEN installations and personnel. Gradually, according with its expansion, EBRR shall become independent of CNEN. These plans are currently under Federal Government review.

## **K.6 - FINAL REMARKS**

Brazil has demonstrated that the Brazilian nuclear power programme and the related nuclear installations have met the objectives of the Convention.

Based on the safety performance of nuclear installations in Brazil, and considering the information provided in this National Report, the Brazilian nuclear organizations consider that their nuclear programs have:

- achieved and maintained a high level of safety in the area of spent fuel and waste management on its nuclear and radiological installations;
- established and maintained effective defenses against potential radiological hazards in order to protect individuals, the society and the environment from harmful effects of ionizing radiation;
- prevented accidents with radiological consequences and are prepared to mitigate such consequences should they occur;
- assured a self-sustainable development and the adoption of good practices on radioactive waste and spent fuel management.

Therefore, Brazil considers that its nuclear programme has met and continues to meet the objectives of the Joint Convention on the Safety of Spent Fuel Management and on the Safety of Radioactive Waste Management.

## REFERENCES

- [1] Joint Convention on the Safety of Spent Fuel Management and on the Safety of Radioactive Waste Management - INFCIRC/546 - International Atomic Energy Agency - Vienna – 24.12.1997.
- [2] Guidelines Regarding the Form and Structure of National Reports - INFCIRC/604 - International Atomic Energy Agency - Vienna – 1.07.2002.
- [3] Licensing of Nuclear Installations - CNEN-NE-1.04 - July 1984.
- [4] Siting of Nuclear Power Plants - Resolution CNEN 09/69.
- [5] Operational Reporting for Nuclear Power Plants - CNEN-NN-1.14 - January 2002.
- [6] Management of Radioactive Waste in Radioactive Installations - CNEN-NE-6.05 - December 1985.
- [7] Site Selection for Radioactive Waste Storage Facilities - CNEN-NE-6.06 - December 1989.
- [8] Operational Safety in Nuclear Power Plants - CNEN-NE-1.26 - October 1997.
- [9] Certification of Qualification of Radiation Protection Supervisors - CNEN-NN-3.03 - October 1997.
- [10] Quality Assurance for Safety in Nuclear Power Plants and other installations - CNEN-NN-1.16 - September 1999.
- [11] Qualification of Independent Technical Supervisory Organizations in Nuclear Power Plants and Other Installations - CNEN-NE-1.28 - September 1999.
- [12] Basic Radiation Protection Directives - CNEN-NN-3.01 - August 2005.
- [13] General Norm for Planning of Response to Emergency Situations - SIPRON-NG-02 - 1996.
- [14] Directive for the Preparation of Emergency Plans related to the Unit 1 of Almirante Alvaro Alberto Nuclear Power Plant - SIPRON Directiva Angra - 1997.
- [15] Transport of Radioactive Materials - CNEN-NE-5.01 - August 1988.
- [16] Radiation Protection and Safety for the Final Disposal of Radioactive Waste at Abadia de Goias – CNEN – IT – 01 – December 1993.
- [17] Safety Policy of CNEN - Directive n.295 of 23 December 1996.
- [18] Quality Assurance Policy of CNEN - Directive n.296 of 23 December 1996.
- [19] Nuclear Material Control - CNEN-NN-2.02 - September 1999.
- [20] Licensing of Uranium and/or Thorium Mining and Milling Facilities - CNEN-NE-1.13 - August 1989.
- [21] INTERNATIONAL ATOMIC ENERGY AGENCY, Classification of Radioactive Waste, Safety Series No. 111-G-1.1, IAEA, Vienna (1994).
- [22] INTERNATIONAL ATOMIC ENERGY AGENCY, Classification of Radioactive Waste,

General Safety Guide No. GSG-1, IAEA, Vienna (2009).

[23] Acceptance Criteria for Disposal of Low and Intermediate Level Radioactive Wastes  
- CNEN-NN-6.09 - September 2002.

[24] Operational Safety of Nuclear Power Plants - CNEN-NE-1.26 - October 1997.



## **SECTION L - ANNEXES**

### **L.1 - ANNEX 1 - Present Inventory**

The following table presents the inventory of radioactive waste in Brazil as of the end of March 2008.

| Source/ Type            | Present Situation   | Inventory as of March 2011   | Treatment   | Interim Storage     | Final Disposal (proposal) |
|-------------------------|---|--|---|---------------------|---------------------------|
| <b>ANGRA-1 NPP</b>      |   |  |   |                     |                           |
| Spent Fuel              | Storage inside reactor pool (Spent fuel pool)   | 734 fuel assemblies  | Waiting for decision concerning reprocessing. Under Brazilian regulation is not considered waste. | Inside reactor pool | Deep geological disposal  |
| Filters                 | Stored in 200 L drums at plant site   | 512 packages / 106,5 m <sup>3</sup> / 3.6E+13 Bq   | Cementation and encapsulation in steel drums  | At plant site       | Brazilian repository      |
| Evaporator concentrates | Stored in 200 L drums and 1,000 L liners at plant site  | 2,926 packages / 949,2 m <sup>3</sup> / 6.5E+12Bq  | Cementation and encapsulation in steel drums/shielded liners                                      | At plant site       | Brazilian repository      |
| Non-compressibles       | Stored in 200 L drums and 1,000 L metallic boxes at plant site  | 937 packages / 644,2 m <sup>3</sup> / 1.4E+13 Bq   | Cementation and encapsulation in steel drums/metallic boxes                                       | At plant site       | Brazilian repository      |
| Resins                  | Stored in 200 L drums and 1,000 L liners at plant site  | 1,263 packages / 408,5 m <sup>3</sup> / 2.3E+14 Bq   | Cementation and encapsulation in steel drums/shielded liners                                      | At plant site       | Brazilian repository      |
| Compressibles           | Stored in 200 L drums at plant site and compacted drums stored in 2,500 L metallic boxes (B-25) at plant site | 682 drums / 141,9 m <sup>3</sup> and 128 metallic boxes (B-25) 320 m <sup>3</sup> / 2.9E+12 Bq | Compaction and encapsulation in steel drums   | At plant site       | Brazilian repository      |

| Source/ Type   | Present Situation  | Inventory as of March 2011  | Treatment   | Interim Storage     | Final Disposal (proposal) |
|--|--|---|---|---------------------|---------------------------|
| <b>ANGRA-2 NPP</b>   |  |   |   |                     |                           |
| Spent fuel   | Storage inside reactor pool (Spent fuel pool)                    | 440 fuel assemblies   | Waiting for decision concerning reprocessing (under Brazilian regulation is not considered waste) | Inside reactor pool | Deep geological disposal  |
| Filters  | Stored in 200 L drums at plant site                              | 6 drums / 1.2 m <sup>3</sup>  | Betuminization and encapsulation in steel drums   | At plant site       | Brazilian repository      |
| Evaporator concentrates  | Stored in 200 L drums at plant site                              | 179 drums / 35,8 m <sup>3</sup> / 2.0E+10 Bq  | Betuminization and encapsulation in steel drums   | At plant site       | Brazilian repository      |
| Resins   | Stored in 200 L drums at plant site                              | 72 drums / 14.4 m <sup>3</sup> / 9.5E+12 Bq   | Betuminization and encapsulation in steel drums   | At plant site       | Brazilian repository      |
| Compressibles  | Stored in 200 L drums at plant site                              | 152 drums / 30.4 m <sup>3</sup> / 4.5E+11 Bq  | Compaction and encapsulation in steel drums   | At plant site       | Brazilian repository      |
| <b>RADIONUCLIDE APPLICATIONS IN MEDICINE, INDUSTRY AND RESEARCH</b>  |  |   |   |                     |                           |
| Waste generated by radioactive installations, research institutes (including those belonging to CNEN) and lightning rods | Stored in the institutes of CNEN: IPEN(SP), CDTN(MG) and IEN(RJ) | IPEN: 583m <sup>3</sup> / 5.07E+14Bq<br>CDTN: 101m <sup>3</sup> / 1.83E+14Bq<br>IEN: 114m <sup>3</sup> / 2.68E+14Bq | According to type of waste  | Institutes of CNEN  | Brazilian repository      |

| Source/ Type   | Present Situation                | Inventory as of March 2011  | Treatment | Interim Storage          | Final Disposal (proposal) |
|--|----------------------------------|---|-----------|--------------------------|---------------------------|
| <b>FUEL CYCLE INSTALLATIONS</b>  |                                  |   |           |                          |                           |
| Operation of the rare-earth production line of Usina de Santo Amaro (Santo Amaro Mill - USAM) – Uranium and Thorium concentrates (Cake II) | Stored in shed and trenches      | 11,334 tons / 7,250 m <sup>3</sup><br>119,288 GBq (3,224 Ci)<br>(Low level waste) | -         | Ore Treatment Unit (UTM) | Ore Treatment Unit (UTM)  |
| Ore Treatment Unit (UTM) – Mesothorium   | Talings dam                      | 1,500 ton (Low level waste)   | -         | Ore Treatment Unit (UTM) | Ore Treatment Unit (UTM)  |
| Ore Treatment Unit (UTM) – Mesothorium   | Trenches                         | 880 tons (Low level waste)  |           | Ore Treatment Unit (UTM) | Ore Treatment Unit (UTM)  |
| Ore Treatment Unit (UTM) – Waste Generated in the Process  | Tailings dam                     | 2,111,920 tons<br>(Low level waste)   |           | Ore Treatment Unit (UTM) | Ore Treatment Unit (UTM)  |
| Ore Treatment Unit (UTM) – Calcium Diuranate (DUCA)  | Tailings dam and Mine Pit        | 120,000 tons<br>(197 tons of U <sub>3</sub> O <sub>8</sub> )                      |           | Ore Treatment Unit (UTM) | Ore Treatment Unit (UTM)  |
| Ore Treatment Unit (UTM) – Contaminated Filters and Other Materials  | Isolated areas on the site       | Approximately 50 tons<br>(Low level waste)  |           | Ore Treatment Unit (UTM) | Ore Treatment Unit (UTM)  |
| Ore Treatment Unit (UTM) – Thorium (ThO <sub>2</sub> )   | Pond and 148 concrete containers | 159 tons<br>(Low level waste)   |           | Ore Treatment Unit (UTM) | Ore Treatment Unit (UTM)  |

| Source/ Type  | Present Situation  | Inventory as of March 2011                     | Treatment | Interim Storage            | Final Disposal (proposal) |
|---|--|--|-----------|----------------------------|---------------------------|
| Nuclear Fuel Factory (FCN)<br>- filters of the ventilation system, filters of the air conditioned system, and filters of portable dust vacuum cleaners) | Stored in 200-liter drums, temporarily inside the reconversion plant | 57 drums / 3,169 kg<br>(Low-level solid waste) |           | Nuclear Fuel Factory (FCN) |                           |
| Nuclear Fuel Factory (FCN)<br>- non compactable waste (metal pieces, wood, glass, plastic pieces, and others)   | Stored in 200-liter drums, temporarily inside the reconversion plant | 64 drums / 4,033 kg<br>(Low-level solid waste) |           | Nuclear Fuel Factory (FCN) |                           |
| Nuclear Fuel Factory (FCN)<br>- compactable solids (plastic sheets, gloves, clothes, and others)  | Stored in 200-liter drums, temporarily inside the reconversion plant | 94 drums / 7,071 kg<br>(Low level solid waste) |           | Nuclear Fuel Factory (FCN) |                           |
| Nuclear Fuel Factory (FCN)<br>- refractory material (bricks)  | Stored in 200-liter drums, temporarily inside the Reconversion plant | 15 drums / 2,559 kg<br>(Low level solid waste) |           | Nuclear Fuel Factory (FCN) |                           |
| Nuclear Fuel Factory (FCN)<br>- dried lime cake   | Stored in 200-liter drums, temporarily inside the reconversion plant | 19 drums / 3,399 kg<br>(Low level solid waste) |           | Nuclear Fuel Factory (FCN) |                           |
| Nuclear Fuel Factory (FCN)<br>- dried ammonium fluoride cake  | Stored in 200-liter drums, temporarily inside the reconversion plant | 2 drums / 449 kg<br>(Low level solid waste)    |           | Nuclear Fuel Factory (FCN) |                           |
| Nuclear Fuel Factory (FCN)<br>- pieces of molybdenum  | Stored in 100 L drums, temporarily inside the reconversion plant     | 2 drums / 113 kg<br>(Low level solid waste)    |           | Nuclear Fuel Factory (FCN) |                           |

| Source/ Type  | Present Situation                       | Inventory as of March 2011 | Treatment | Interim Storage                | Final Disposal (proposal)      |
|---|---|----------------------------|-----------|--------------------------------|--------------------------------|
| Uranium Concentrate Unit (URA) - leached ore                          | Unpackage solid                         | 1,469,503 tons             |           | Uranium Concentrate Unit (URA) | Uranium Concentrate Unit (URA) |
| Uranium Concentrate Unit (URA) - pulp wastewater treaty               | Solid dense impermeable basin           | 79,837 tons                |           | Uranium Concentrate Unit (URA) | Uranium Concentrate Unit (URA) |
| Uranium Concentrate Unit (URA) - small materials from several sources | Stored in 200-liter drums at plant site | 129 drums                  |           | Uranium Concentrate Unit (URA) | Uranium Concentrate Unit (URA) |
| Uranium Concentrate Unit (URA) - metal pipes and HDPE                 | Unpackaged solid                        | 450 kg                     |           | Uranium Concentrate Unit (URA) |                                |
| Uranium Concentrate Unit (URA) - parts of hydrocodone                 | Unpackaged solid                        | 3,500 kg                   |           | Uranium Concentrate Unit (URA) |                                |
| Uranium Concentrate Unit (URA) - scrap metal                          | Unpackaged solid                        | 6,500 kg                   |           | Uranium Concentrate Unit (URA) |                                |
| Uranium Concentrate Unit (URA) - parts of crushing                    | Unpackaged solid                        | 1,500 kg                   |           | Uranium Concentrate Unit (URA) |                                |
| Uranium Concentrate Unit (URA) - mixer                                | Unpackaged solid                        | 5,000 kg                   |           | Uranium Concentrate Unit (URA) |                                |
| Uranium Concentrate Unit (URA) – wool coating reactor                 | Stored in drums at plant site           | 7 drums                    |           | Uranium Concentrate Unit (URA) |                                |
| Uranium Concentrate Unit (URA) - waste treatment emulsion             | Solid stored in 200-liter drums         | 30 drums                   |           | Uranium Concentrate Unit (URA) |                                |

| Source/ Type  | Present Situation  | Inventory as of March 2011                                  | Treatment | Interim Storage                    | Final Disposal (proposal) |
|---|--|---|-----------|------------------------------------|---------------------------|
| <b>MONAZITE SAND PROCESSING INSTALLATIONS</b>   |  |   |           |                                    |                           |
| Operation of the rare-earth production line of Usina de Santo Amaro (Santo Amaro Mill - USAM)<br>- Uranium and Thorium concentrates (Cake II) | Stored in plastic drums                                      | 590,94 ton / 328 m <sup>3</sup> /<br>5,069 GBq (137Ci)      |           | Interlagos Processing Plant (USIN) |                           |
| Operation of the rare-earth production line of Santo Amaro Processing Plant (USAM)<br>- Mesothorium   | Stored in plastic drums                                      | 83,6 ton / 38 m <sup>3</sup> /<br>222 GBq (6 Ci)            |           | Interlagos Processing Plant (USIN) |                           |
| Operation of the rare-earth production line of Santo Amaro Processing Plant (USAM)<br>- Other contaminated material                           | Stored in plastic drums, maritime containers and metal boxes | 405,72 tons / 599 m <sup>3</sup>                            |           | Interlagos Processing Plant (USIN) |                           |
| Operation of the rare-earth production line of Santo Amaro Processing Plant (USAM)<br>- Uranium and Thorium concentrates                      | Stored in concrete silos                                     | 3,500.07 ton / 1,943 m <sup>3</sup> /<br>32,856 GBq (888Ci) |           | Botuxim Depository (São Paulo)     |                           |

| Source/ Type  | Present Situation        | Inventory as of March 2011     | Treatment                                 | Interim Storage             | Final Disposal (proposal)      |
|---|--------------------------|--------------------------------|---|-----------------------------|--------------------------------|
| <b>RADIOLOGICAL ACCIDENT IN GOIÂNIA</b>                     |                          |                                |   |                             |                                |
| Low level wastes ( <sup>137</sup> Cs) below exemption level | Final disposal concluded | 1,525 m <sup>3</sup> / 2 Ci    | Encapsulation in steel and concrete drums | Open air at Abadia de Goiás | Great Capacity Container (CGP) |
| Low level waste ( <sup>137</sup> Cs) above exemption level  | Final disposal concluded | 1,975 m <sup>3</sup> / 1338 Ci | Encapsulation in steel and concrete drums | Open air at Abadia de Goiás | Goiânia Repository             |



## L.2 - ANNEX 2 – List of Relevant Conventions, Laws and Regulations

### L.2.1 - RELEVANT INTERNATIONAL CONVENTIONS OF WHICH BRAZIL IS A PARTY

Convention on Civil Liability for Nuclear Damage (Vienna Convention). Signature: 23/12/1993. Entry into force: 26/06/1993.

Convention on the Physical Protection of Nuclear Material. Signature: 15/05/1981. Entry into force: 8/02/1987.

Convention on Early Notification of a Nuclear Accident Signature: 26/09/1986. Entry into force: 4/01/1991.

Convention on Assistance in Case of Nuclear Accident or Radiological Emergency. Signature: 26/09/1986. Entry into force: 4/01/1991.

Convention on Nuclear Safety. Signature: 20/09/1994. Entry into force: 24/04/1997.

Convention n. 115 of the International Labor Organization. Signature: 7/04/1964.

Join Convention on the Safety of Spent Fuel Management and on the Safety of Radioactive Waste Management. Ratification: 14/11/2005.

### L.2.2 - RELEVANT NATIONAL LAWS

**Decree 40110 of 1956.10.10** - Creates the National Commission for Nuclear Energy - CNEN.

**Law 4118/62 of 1962.07.27** - Establishes the Nuclear Energy National Policy and reorganizes CNEN.

**Law 6189/74 of 1974.12.16** - Creates Nuclebras as a company responsible for nuclear fuel cycle facilities, equipment manufacturing, nuclear power plant construction, and research and development activities.

**Law 6453 of 1977.10.17** - Defines the civil liability for nuclear damages and criminal responsibilities for actions related to nuclear activities

**Decree 1809 of 1980.10.07** - Establishes the System for Protection of the Brazilian Nuclear Programme (SIPRON).

**Law 6938 of 1981.08.31** - Establishes the National Policy for the Environment (PNMA), creates the National System for the Environment (SISNAMA) and the Council for the Environment (CONAMA).

**Law 7735 of 1989.02.23** - Creates the Brazilian Institute for Environment and Renewable Natural Resources - IBAMA

**Law 7781/89 of 1989.06.27** - Reorganizes the nuclear sectors.

**Decree 99274 of 1990.06.06** - Regulates application of law 6938, establishing the environmental licensing process in 3 steps: pre-license, installation license and operation license.

**Decree 2210 of 1997.04.22** - Regulates SIPRON, defines the Secretary for Strategic Affairs (SAE) as the central organization of SIPRON and creates the Coordination of the Protection of the Brazilian Nuclear Programme (COPRON).

**Law 9605 of 1998.02.12** - Defines environmental crimes and establishes a system of enforcement and punishment.

**Decree 3719 of 1999.09.21** - Regulates the Law 9605 and establishes the penalties for environmental crimes.

**Law 9765 of 1998.12.17** - Establishes tax and fees for licensing, control and regulatory inspection of nuclear and radioactive materials and installations.

**Decree 3833 of 2001.06.05** - Establishes the new structure and staff of the Brazilian Institute for the Environment (IBAMA).

**Law 10308 of 2001.11.20** – Establishes rules for the site selection, construction, operation, licensing and control, financing, civil liability and guaranties related to the storage of radioactive waste.

### L.2.3 - CNEN REGULATIONS

NE 1.04 - Licenciamento de Instalações Nucleares - Resol. CNEN 11/84 - ***(Licensing of nuclear facilities)***.

NN 1.14 - Relatórios de operação de usinas nucleoeletricas - ***(Nuclear power plant operation reports)***.

NE 1.16 - Garantia da qualidade para a segurança de usinas nucleoeletricas e outras instalações - Resol. 15/99 - ***(Quality assurance and safety in nuclear power plants and other facilities)***.

NE 1.17 - Qualificação de pessoal e certificação para ensaios não destrutivos em itens de instalações nucleares - ***(Personnel qualification and certification for non-destructive testing in nuclear power plants components )***.

NE 1.18 - Conservação preventiva em usinas nucleoeletricas - ***(Nuclear power plant preventive maintenance)***.

NE 1.19 - Qualificação de programas de cálculos para análise de acidentes de perda de refrigerante em reatores a água pressurizada - Resol. CNEN 11/85 - ***(Qualification of***

**programs for coolant loss accident analysis in pressurized water reactors).**

NE 1.20 - Aceitação de sistemas de resfriamento de emergência do núcleo de reatores a água leve - **(Acceptance criteria for emergency core cooling system of light water reactors).**

NE 1.21 - Manutenção de usinas nucleoeletricas - **(Maintenance of nuclear power plants).**

NE 1.22 - Programas de meteorologia de apoio de usinas nucleoeletricas - **(Meteorological programme for nuclear power plant support).**

NE 1.25 - Inspeção em serviço de usinas nucleoeletricas - **(In service inspection of nuclear power plants).**

NE 1.26 - Segurança na operação de usinas nucleoeletricas - **(Operational safety of nuclear power plants).**

NE 1.28 - Qualificação e atuação de órgãos de supervisão técnica independente em usinas nucleoeletricas e outras instalações - Resol. CNEN-CD N<sup>o</sup>.15/99 de 16/09/1999- - **(Qualification and actuation of independent technical supervisory organizations in nuclear power plants and other installations)**

NN 1.01 - Licenciamento de operadores de reatores nucleares - Resol. CNEN 12/79 - **(Licensing of nuclear reactor operators).**

NN 1.06 - Requisitos de saúde para operadores de reatores nucleares - Resol. CNEN 03/80 - **(Health requirements for nuclear reactor operators).**

NN 1.12 - Qualificação de órgãos de supervisão técnica independente em instalações nucleares - Resol. CNEN 16/85 - Revisada em 21/09/1999 - **(Qualification of independent technical supervisory organizations for nuclear installations).**

NN 1.15 - Supervisão técnica independente em atividades de garantia da qualidade em usinas nucleoeletricas - **(Independent technical supervision in quality assurance activities in nuclear power plants).**

NE 2.01 - Proteção física de unidades operacionais da área nuclear - Resol. CNEN 07/81 – revised by Resol. 06/96 **(Physical Protection in nuclear facilities).**

NN 2.02 – Controle de materiais nucleares - Resol. CNEN 11/99 **(Nuclear material control).**

NE 2.03 - Proteção contra incêndio em usinas nucleoeletricas - Resol. CNEN 08/88 - **(Fire protection in nuclear power plants).**

NN 3.01 - Diretrizes básicas de proteção radiológica - Resol. CNEN 48/2005 - **(Radiation protection basic directives). January 2005**

NE 3.02 - Serviços de proteção radiológica - **(Radiation protection services). August 1988**

NE 3.03 - Certificação da qualificação de supervisores de radioproteção - Resol. CNEN 09/88 – Revisada em 01/09/95, Modificada em 16/10/97 e 21/09/99 - ***(Certification of the qualification of radiation protection supervisors). September 1999***

NE 5.01 - Transportes de materiais radioativos - Resol. CNEN 13/88 - ***(Transport of radioactive materials). August 1988***

NE 5.02 - Transporte, recebimento, armazenamento e manuseio de elementos combustíveis de usinas nucleoeletricas - ***(Transport, receiving, storage and handling of fuel elements in nuclear power plants). February 2003***

NE 5.03 - Transporte, recebimento, armazenagem e manuseio de itens de usinas nucleoeletricas - ***(Transport, receipt, storage and handling of materials in nuclear power plants). February 1989.***

NE 6.02 Licenciamento de instalações radiativas – ***(Licensing of radioactive installations). July 1998***

NE 6.05 - Gerência de rejeitos radioativos em instalações radiativas - ***(Radioactive waste management in radioactive facilities). December 1985. (Currently under review)***

NE 6.06 – Seleção e escolha de locais para depósitos de rejeitos radioativos. - ***(Site Selection for radioactive waste storage facilities).- December 1989***

NN 6.09 – Critérios de aceitação para deposição de rejeitos radioativos de baixo e médio níveis de radiação - ***(Acceptance criteria for disposal of low and intermediate level radioactive wastes). – September 2002***

**IN-DRS 010** – Rev. 03 -- Requisitos de segurança para depósitos finais de rejeitos radioativos de baixo e médio níveis de radiação ***(Safety requirements for low and intermediate level radioactive waste disposal facilities) – May 2007***

#### **L.2.4 - CONAMA REGULATIONS**

CONAMA – 01/86 - Estabelece requisitos para execução do Estudo de Impacto Ambiental (EIA) e do Relatório de Impacto Ambiental (RIMA) - ***(Establishes requirements for conducting the environmental study (EIA) and the preparation of the report on environmental impact (RIMA)) - (23/01/1986).***

CONAMA-28/86 - Determina a FURNAS a elaboração de EIA/RIMA para as usinas nucleares de Angra-2 e 3 - ***(Directs FURNAS to prepare an EIA/RIMA for the Angra-2 and 3 nuclear power plants) - (03/12/1986)***

CONAMA-09/86 - Regulamenta a questão de audiências públicas - ***(Regulates the matters related to public hearings) - (03/12/1987).***

CONAMA-06/86 – Institui e aprova modelos para publicação de pedidos de licenciamento - **(Establishes and approves models for licensing application)** - (24/01/1986).

CONAMA-06/87 – Dispõe sobre licenciamento ambiental de obras de grande porte e especialmente do setor de geração de energia elétrica - **(Regulates environmental licensing of large enterprises, specially in the area of electric energy generation)** - (16/09/1987).

CONAMA-237/97 – Dispõe sobre os procedimentos a serem adotados no licenciamento ambiental de empreendimentos diversos - **(Establishes procedures for environmental licensing of several types of enterprises)** - (19/12/1997).

#### L.2.5 - SIPRON REGULATIONS

NG-01 - Norma Geral para o funcionamento da Comissão de Coordenação da Proteção do Programa Nuclear Brasileiro (COPRON) - **(General norm for the Coordination Commission for the Protection of the Brazilian Nuclear Programme)**. Port. SAE Nr. 99 of 13.06.1996.

NG-02 - Norma Geral para planejamento de resposta a situações de emergência. - **(General norm for planning of response to emergency situations)**. Resol. SAE/COPRON Nr.01 of 13.06.1996.

NG-03 - Norma Geral sobre a integridade física e situações de emergência nas instalações nucleares - **(General norm for physical integrity and emergency situations in nuclear installations)**. Resol. SAE/COPRON Nr. 01 of 19.07.1996.

NG-04 - Norma Geral para situações de emergência nas unidades de transporte - **(General norm for emergency situations in the transport units)**. Resol. SAE/COPRON Nr. 01 of 19.07.1996

NG-05 - Norma Geral para estabelecimento de campanhas de esclarecimento prévio e de informações ao público para situações de emergência - **(General norm for establishing public information campaigns about emergency situations)**. Port. SAE Nr. 150 of 11.12.1992.

NG-06 - Norma Geral para instalação e funcionamento dos centros de resposta a situações de emergência nuclear - **(General norm for installation and functioning of response center for nuclear emergency situations)**. Port. SAE Nr. 27 of 27.03.1997.

NG-07 - Norma Geral para planejamento das comunicações do SIPRON **(General norm for SIPRON communication planning)**. Port. SAE Nr. 37 of 22.04.1997.

NG-08 – Norma Geral para o planejamento e a execução da proteção ao conhecimento sigiloso **(General norm for planning and execution of classified knowledge protection)**. Port. SAE Nr. 145 of 7.12.1998.

**NI-01** – Norma Interna que dispõe sobre instalação e funcionamento do Centro para

Gerenciamento de Emergência Nuclear (**Internal norm on the installation and operation of the national Center for Nuclear Emergency Management**). Port. SAE Nr.001 of 21.05.1997.

Diretriz Angra-1 - Diretriz para elaboração dos planos de emergência relativos a unidade 1 da Central Nuclear Almirante Alvaro Alberto - (**Directive for the preparation of emergency plans related to Unit 1 of Almirante Alvaro Alberto Nuclear Power Plant – Angra-1**). Port. SAE Nr.144 of 20.11.1997.

**L.3 - ANNEX 3 - LIST OF ABBREVIATIONS**

|            |   |
|------------|---|
| ABACC      | <i>Agência Brasileiro-Argentina de Contabilidade e Controle de Materiais Nucleares</i> (Brazilian-Argentine Agency for Accounting and Control of Nuclear Materials) |
| ABIN       | <i>Agência Brasileira de Inteligência</i> (Brazilian Intelligence Agency)   |
| ALARA      | As Low As Reasonable Achievable   |
| AOI        | <i>Autorização para Operação Inicial</i> (Authorization for Initial Operation)  |
| AOP        | <i>Autorização para Operação Permanente</i> (Authorization for Permanent Operation)   |
| BSS        | Basic Safety Standards (of IAEA)  |
| CCEN       | <i>Centro de Coordenação e Controle de uma Situação de Emergência Nuclear</i> (Center for Coordination and Control of a Nuclear Emergency Situation)                |
| CDTN       | <i>Centro de Desenvolvimento de Tecnologia Nuclear</i> (Nuclear Technology Development Center)  |
| CEA        | <i>Centro Experimental Aramar</i> (Aramar Experimental Center)  |
| CENA       | <i>Centro de Energia Nuclear na Agricultura da Universidade de São Paulo</i> (University of São Paulo's Center of Nuclear Energy for Agriculture)                   |
| CESTGEN    | <i>Centro Estadual para Gerenciamento de uma Situação de Emergência Nuclear</i> (State Center for Management of a Nuclear Emergency)                                |
| CETESB     | <i>Companhia de Tecnologia de Saneamento Ambiental</i> (São Paulo State Institute for Environment)  |
| CICP       | <i>Complexo Industrial de Poços de Caldas</i> (Poços de Caldas Industrial Complex)  |
| CIEN       | <i>Centro de Informações de Emergência Nuclear</i> (Center for Information in Nuclear Emergency)  |
| CGR        | <i>Centro de Gerenciamento de Rejeitos</i> (Radioactive Waste Management Center)  |
| CGRC       | <i>Coordenação Geral de Reatores e Ciclo do Combustível</i> (General Coordination for Reactors and Fuel Cycle)  |
| CNAAA      | <i>Central Nuclear Almirante Álvaro Alberto</i> (Admiral Álvaro Alberto Nuclear Power Station)  |
| CNAGEN     | <i>Centro Nacional para Gerenciamento de uma Situação de Emergência Nuclear</i> (National Center for the Management of Nuclear Emergency Situation)                 |
| CNEN       | <i>Comissão Nacional de Energia Nuclear</i> (National Commission for Nuclear Energy)  |
| CNPq       | <i>Conselho Nacional de Desenvolvimento Científico e Tecnológico</i> (National Council for Scientific and Technological Development)                                |
| COGEPE     | <i>Coordenação Geral do Plano de Emergência</i> (General Coordinator for Emergency Plan)  |
| COEND      | <i>Coordenação de Geração de Energia Elétrica, Nuclear e Oleodutos</i> (Coordination for Electrical Power, Nuclear Energy and Pipelines)                            |
| CONAMA     | <i>Conselho Nacional do Meio Ambiente</i> (National Council for the Environment)  |
| COPREN/RES | <i>Comitê de Planejamento de Resposta a Emergência Nuclear no Município de Resende</i> (Emergency Response Planning Committee in Resende)                           |
| COPRON     | <i>Comissão de Coordenação da Proteção ao Programa Nuclear Brasileiro</i> (Coordination Commission for the Protection of the Brazilian Nuclear Program)             |
| COREJ      | <i>Coordenação de Rejeitos Radioativos</i> (Radioactive Waste Coordination)   |
| CRCN-CO    | <i>Centro Regional de Ciências Nucleares do Centro Oeste</i> (Midwest Regional Center   |

|         |   |
|---------|---|
|         | for Nuclear Sciences)   |
| CRCN-NE | <i>Centro Regional de Ciências Nucleares do Nordeste (Northeast Regional Center for Nuclear Sciences)</i>                                 |
| CTMSP   | <i>Centro Tecnológico da Marinha em São Paulo (Navy Technology Center in Sao Paulo)</i>   |
| DILIC   | <i>Diretoria de Licenciamento Ambiental (Directorship of Environmental Licensing)</i>   |
| DIRR    | <i>Deposito Inicial de Rejeitos Radioativos (Radioactive Waste Initial Repository)</i>  |
| DPD     | <i>Diretoria de Pesquisa e Desenvolvimento (Directorate for Research and Development)</i>   |
| DRS     | <i>Diretoria de Radioproteção e Segurança Nuclear (Directorate for Radiological Protection and Nuclear Safety)</i>                        |
| EAR     | <i>Estudo de Análise de Risco (Risk Assessment)</i>   |
| EBRR    | <i>Empresa Brasileira de Gerenciamento de Rejeitos Radioativos (Brazilian Enterprise for Radioactive Waste Management)</i>                |
| EIA     | <i>Estudo de Impacto Ambiental (Environmental Impact Study)</i>   |
| ETN     | <i>Eletronuclear S.A. - Eletronuclear (the nuclear power plants operator company)</i>   |
| FAPEMIG | <i>Minas Gerais State Foundation for Research Support (Fundação de Amparo à Pesquisa do Estado de Minas Gerais)</i>                       |
| FCN     | <i>Fábrica de Combustível Nuclear (Nuclear Fuel Factory)</i>  |
| FEEMA   | <i>Fundação Estadual de Engenharia do Meio Ambiente (Rio de Janeiro State Foundation for Environmental Engineering)</i>                   |
| FINEP   | <i>Financiadora de Estudos e Projetos (Research and Projects Financing)</i>   |
| FSAR    | Final Safety Analysis Report  |
| GSI/PR  | <i>Gabinete de Segurança Institucional da Presidência da República (Institutional Security Cabinet of the Presidency of the Republic)</i> |
| IAEA    | International Atomic Energy Agency  |
| IBAMA   | <i>Instituto Brasileiro do Meio Ambiente e Recursos Renováveis (Brazilian Institute for Environment and Renewable Natural Resources)</i>  |
| IBGE    | <i>Instituto Brasileiro de Geografia e Estatística (Brazilian Institute of Geography and Statistics)</i>                                  |
| ICRP    | International Commission on Radiological Protection   |
| IEN     | <i>Instituto de Engenharia Nuclear (Nuclear Engineering Institute)</i>  |
| INB     | <i>Indústrias Nucleares do Brasil (Brazil Nuclear Industries)</i>   |
| INEA    | <i>Instituto Estadual do Ambiente (Rio de Janeiro State Institute for Environment)</i>  |
| IPEN    | <i>Instituto de Pesquisas Energéticas e Nucleares (Nuclear and Energy Research Institute)</i>   |
| IRD     | <i>Instituto de Radioproteção e Dosimetria (Radiation Protection and Dosimetry Institute)</i>   |
| LAPOC   | <i>Laboratório de Poços de Caldas (Poços de Caldas Laboratory)</i>  |
| LI      | <i>Licença de Instalação (Installation License)</i>   |
| LO      | <i>Licença de Operação (Operation License)</i>  |
| LP      | <i>Licença Prévia (Prior License)</i>   |
| MCT     | <i>Ministério de Ciência e Tecnologia (Ministry for Science and Technology)</i>   |



|          |  |
|----------|--|
| MMA      | <i>Ministério do Meio-Ambiente</i> (Ministry for Environment)  |
| NORM     | <i>Ocorrência natural de material Radioativo</i> (natural occurring radioactive material)  |
| NUCLEP   | <i>Nuclebras Equipamentos Pesados</i> (Nuclebras Heavy Equipment Industry)   |
| OSTI     | <i>Organismo de Supervisão Técnica Independente</i> (Independent Technical Supervision Organization)   |
| PCA      | <i>Plano de Controle Ambiental</i> (Environmental Control Plan)  |
| PNAN     | <i>Programa Nacional de Atividade Nucleares</i> (National Nuclear Activities Programme)  |
| PNMA     | <i>Política Nacional de Meio Ambiente</i> (National Policy for the Environment)  |
| PMA      | <i>Programa de Monitoração Ambiental</i> (Environmental Monitoring Program)  |
| PPA      | <i>Plano Plurianual</i> (Pluriannual Plan)   |
| PRAD     | <i>Plano de Recuperação de Áreas Degradadas</i> (Degraded Areas Reclamation Plan)  |
| PROGER   | <i>Programa de Gerenciamento de Rejeitos em instalações de Pesquisa</i> (Program for Waste Management in Research Institutions)  |
| PSAR     | Preliminary Safety Analysis Report   |
| PTCN/MCT | <i>Programa Técnico-Científico Nuclear do Ministério de Ciência e Tecnologia</i> (Nuclear Scientific and Technical Program of the Ministry for Science and Technology)                 |
| RBMN     | <i>Projeto Repositório para Rejeitos de Baixo e Médio Níveis de Radiação</i> (Low and Intermediate Level Waste Repository Project)   |
| RIMA     | <i>Relatório de Impacto Ambiental</i> (Environmental Impact Report)  |
| RR       | Research Reactor   |
| SEPRE    | <i>Secretaria Especial de Políticas Regionais</i> (Special Secretary for Regional Policies)  |
| SAE      | <i>Secretaria de Assuntos Estratégicos</i> (Secretariat for Strategic Affairs)   |
| SFA      | Spent Fuel Assembly  |
| SISNAMA  | <i>Sistema Nacional de Meio Ambiente</i> (National System for the Environment)   |
| SIPRON   | <i>Sistema de Proteção do Programa Nuclear</i> (System for the Protection of the Nuclear Program)  |
| SPE/MME  | <i>Secretaria de Planejamento e Desenvolvimento Energético do Ministério de Minas e Energia</i> (Secretariat for Energy Planning and Development of the Ministry for Mines and Energy) |
| SSSTS    | <i>Serviço de Saúde e Segurança do Trabalho</i> (Secretariat for Worker's Safety and Health)   |
| TSO      | Technical Support Organization   |
| UMP      | <i>Unidade de Minerais Pesados - Buena</i> (Heavy Minerals Processing Unit – located in Buena)   |
| URA      | <i>Unidade de Concentrado de Urânio de Caetité</i> (Uranium Concentrate Unit Of Caetité)   |
| USAM     | <i>Usina de Santo Amaro</i> (Santo Amaro Processing Plant)   |
| USIN     | <i>Usina de Interlagos</i> (Interlagos Processing Plant)   |
| USNRC    | United States Nuclear Regulatory Commission  |
| UTM      | <i>Unidade de Tratamento de Minérios de Poços de caldas</i> (Ore Treatment Unit of Poços de Caldas)  |

---

*This report was prepared by a task force composed of representatives of the following organizations:*

*Comissão Nacional de Energia Nuclear (CNEN)*

*Indústrias Nucleares do Brasil S.A. (INB)*

*Eletronuclear S.A. (ETN)*

*Instituto Brasileiro do Meio Ambiente e dos Recursos Naturais Renováveis (IBAMA)*

*Centro Tecnológico da Marinha em São Paulo (CTMSP)*

*Ministério da Ciência e Tecnologia (MCT)*

*Ministério de Relações Exteriores (MRE)*

***Rio de Janeiro - Brazil  
October 2011***

*This page intentionally left blank*



Ministério da  
**Ciência, Tecnologia  
e Inovação**

Ministério do  
**Meio Ambiente**

Ministério de  
**Minas e Energia**

Ministério das  
**Relações Exteriores**

