

Fifth regular session

## SMALL POWER REACTOR PROJECTS OF THE UNITED STATES ATOMIC ENERGY COMMISSION

### Information gathered as a result of the United States offer inviting the Agency's participation

#### TABLE OF CONTENTS

<u>Section</u>	<u>Paragraphs</u>	<u>Pages</u>
List of abbreviations		4 - 5
I. INTRODUCTION	1 - 8	7 - 8
II. INFORMATION CONCERNING THE PROJECTS AS A WHOLE	9 - 53	9 - 16
A. General	9 - 17	9 - 10
B. Management of the projects	18 - 36	10 - 13
C. Interest of the utilities in the projects	37 - 39	13
D. Operating staff and training	40 - 46	13 - 15
E. Nuclear superheat	47 - 53	15 - 16
III. THE ELK RIVER POWER REACTOR	54 - 143	17 - 31
A. General	54 - 56	17
B. Important design features	57 - 71	17 - 19
C. Safety	72 - 87	19 - 21
D. Fuel cycle	88 - 106	21 - 23
E. Construction experience	107 - 120	24 - 26
F. Cost data	121 - 129	26 - 28
G. Operating personnel and training	130 - 137	28 - 30
H. Integration of the reactor in the utility system	138 - 142	30
I. Selected references	143	31

<u>Section</u>	<u>Paragraphs</u>	<u>Pages</u>
IV. THE PIQUA NUCLEAR POWER FACILITY	144 - 237	32 - 46
A. General	144 - 145	32
B. Important design features	146 - 175	32 - 36
C. Safety	176 - 199	36 - 39
D. Operating personnel and training	200 - 208	40 - 41
E. Construction experience	209 - 212	41 - 42
F. Fuel cycle	213 - 221	42 - 43
G. Cost data	222 - 227	43 - 44
H. Integration of the reactor in the utility system	228 - 236	44 - 45
I. Selected references	237	46
V. THE BONUS POWER REACTOR	238 - 288	47 - 57
A. General	238 - 239	47
B. Important design features	240 - 258	47 - 50
C. Safety	259 - 274	50 - 52
D. Operating personnel and training	275 - 278	53
E. Construction experience	279 - 280	53 - 54
F. Fuel cycle	281 - 286	54 - 55
G. Cost data	287	55 - 56
H. Selected references	288	56 - 57
VI. THE PATHFINDER POWER REACTOR	289 - 342	58 - 66
A. General	289 - 293	58 - 59
B. Important design features	294 - 303	59 - 60
C. Safety	304 - 314	60 - 62
D. Fuel cycle	315 - 329	62 - 63
E. Cost data	330 - 331	63 - 64
F. Operating personnel and training	332 - 341	64 - 65
G. Selected references	342	66
VII. THE SMALL-SIZE PRESSURIZED WATER POWER REACTOR	343 - 361	67 - 70
A. General	343	67
B. Selection of the size and type of reactor	344 - 349	67 - 68
C. Important design features	350 - 352	68
D. Difficulties in the selection of the site	353 - 357	68 - 69
E. Present position	358 - 360	69
F. Selected references	361	69 - 70

<u>Section</u>	<u>Paragraphs</u>	<u>Pages</u>
VIII. THE EXPERIMENTAL LOW-POWER PROCESS HEAT REACTOR	362 - 368	71
A. General	362 - 363	71
B. Summary of technical aspects	364 - 368	71

ANNEXES

ANNEX I	Important design features of the Elk River power reactor
ANNEX II	Important design features of the Piqua nuclear power facility
ANNEX III	Important design features of the BONUS power reactor
ANNEX IV	Important design features of the Pathfinder power reactor

FIGURES

FIGURE 1	Schematic flow diagram of the Elk River power reactor
FIGURE 2	Schematic flow diagram of the Piqua nuclear power facility
FIGURE 3	Simplified schematic diagram of the BONUS power reactor
FIGURE 4	Schematic diagram of the Pathfinder power reactor

List of abbreviations

Al	Aluminum
ACRS	Advisory Committee on Reactor Safeguards (of USAEC)
ASME	American Society of Mechanical Engineers
BONUS	boiling-water nuclear superheat reactor
Borax	boiling-water reactor experiment
BTU	British thermal unit
BWR	boiling-water reactor
cc	cubic centimeters
CNEN	Comitato Nazionale per le Ricerche Nucleari
CP-5	Chicago pile, number 5
cu ft/mt	cubic feet per minute
CVNPA	Carolinas Virginia Nuclear Power Associates, Inc.
CVTR	Carolinas Virginia tube reactor
EBWR	experimental boiling-water reactor
EGCR	experimental gas-cooled reactor
ELPHR	experimental low-temperature process heat reactor
EOCR	experimental organic-cooled reactor
F	Fahrenheit
ft	feet
g	grams
gpm	gallons per minute
H	hydrogen
HNPF	Hallam nuclear power facility
hr	hours
HTGR	high temperature gas-cooled reactor
ICBWR	improved cycle boiling-water reactor
ICRP	International Commission on Radiological Protection
in.	inches
kg	kilograms
kw	kilowatt
kw-yr	kilowatt-year
l	liter
lb	pounds
mil	a thousandth of an inch
mill	a thousandth of a dollar
Mo	molybdenum
mph	miles per hour
mrem/hr	milliroentgen equivalent man/hour

mt	minute
MTU	metric ton uranium
Mwd	Megawatt day
Mwe	Megawatt electrical
Mwth	Megawatt thermal
NSPC	Northern States Power Company
OMR	organic-moderated reactor
OMRE	organic-moderated reactor experiment
PNPF	Piqua nuclear power facility
PRWRA	Puerto Rico Water Resources Authority
psia	pound per square inch absolute
psig	pound per square inch gauge
PWR	pressurized water reactor
r	roentgen
RCPA	Rural Cooperative Power Association
rem	roentgen equivalent man
rep	roentgen equivalent physical
sec	second
SGR	sodium graphite reactor
Si	silicon
SL-1	stationary low power reactor, number 1
sq	square
SRE	sodium reactor experiment
SS	stainless steel
SSPWR	small-size pressurized water reactor
t	ton
Th	thorium
U	uranium
USAEC	United States Atomic Energy Commission
VBWR	Vallecitos boiling-water reactor
VESR	Vallecitos experimental superheat reactor
yr	year
Zr	zirconium

---

NOTE

Except where otherwise stated all sums of money are expressed in United States currency.



## I. INTRODUCTION

1. As part of its activities in connection with the development of nuclear power, and in response to the resolutions adopted by the General Conference [1], the Agency has been undertaking a continuing study of the technology and economics of small and medium sized power reactors, particularly with reference to the needs of the less-developed countries. The information gathered as a result of the opportunity afforded by the United States of America to follow the development of some of the small power reactor projects in that country [2] is summarized in this report.
2. In discussions with officials of USAEC for the purpose of working out a program that would enable the Agency to make the best use of the offer by the United States Government, the Secretariat indicated that it was interested in obtaining essential data on the following:
  - (a) The Elk River 22 Mwe boiling-water reactor with a coal-fired superheater;
  - (b) The Piqua 11.4 Mwe organic-moderated reactor;
  - (c) The BONUS 16.2 Mwe boiling-water reactor with integral superheat;
  - (d) The Pathfinder 62 Mwe boiling-water reactor with integral superheat;
  - (e) The SSPWR 20 Mwe pressurized-water reactor; and
  - (f) The ELPWR 40 Mwe pressurized-water reactor for process heat and desalinization.
3. The Agency also expressed a desire to be kept informed about the progress of certain other projects such as the Hallam nuclear power facility (HNPF), the high temperature gas-cooled reactor (HTGR) at Philadelphia, and the improved cycle boiling-water reactor (ICBWR) at Michigan.
4. On each of the reactor projects listed above, information was requested from USAEC on the following:
  - (a) Basic design features with emphasis on design objectives;
  - (b) Construction experience;
  - (c) Safety of reactors (design, siting, containment, hazard reports);
  - (d) Fuel cycle (fabrication of fuel elements, fuel handling, fuel management and shipping for reprocessing);
  - (e) Training of the operating staff;
  - (f) Start-up;
  - (g) Cost data;
  - (h) Operation and maintenance experience; and
  - (i) Integration of the nuclear plant within the existing power network.
5. It was decided that the Agency's staff would first study all available reports on the projects and then gather further information on matters not covered by the reports but of special interest to Member States. This is being done by two staff members of the Secretariat who visit at appropriate intervals the reactor sites and hold discussions with the officials of USAEC responsible for directing the projects, and with reactor designers and manufacturers, building and construction contractors, and representatives of utility companies.

---

[1] GC(II)/RES/27, GC(III)/RES/57 and GC(IV)/RES/86.

[2] See also document GC(V)/161.

6. It was recognized that because of differences in the time schedules for the completion of individual projects, their execution as a whole would be spread over three to four years and at any particular time during that period the Agency would be particularly interested in these projects which were then at an active stage of development.

7. The present report deals mainly with the Elk River, BONUS, Piqua and Pathfinder projects, and briefly with some others. It is mostly concerned with a discussion of basic design features, safety, experience in construction, training of personnel, and the cost, operation and maintenance of the reactors. A list of selected references has been provided in each case.

8. USAEC has extended the fullest co-operation to the Agency's staff; reactor designers and the utility companies concerned have also been most helpful in providing necessary information. In order to carry out the program more effectively USAEC has designated a project officer for the transmittal of technical information and relevant material who is directly in touch with a counterpart in the Secretariat.

II. INFORMATION CONCERNING THE PROJECTS AS A WHOLE

A. General

9. The small power reactor projects in the United States are part of the Civilian Power Reactor Program for the development of nuclear power. A list of nuclear power plants in the range of 1-75 Mwe under construction or planned is given in Table 1 below.

Table 1

Small power reactor projects in the United States

Reactor	Type	Output		Location	Critical in	Owner/Operator
Saxton	PWR	3.3	Mwe	Saxton, Pa.	1961	Saxton Nuclear Experimental Corporation
ELPHR <sup>a/</sup>	PWR, low temperature process heat	40	Mwth	not decided		USAEC/not decided
SSPWR <sup>a/</sup>	PWR	20.5	Mwe	not decided		USAEC/not decided
Elk River <sup>a/</sup>	BWR, indirect cycle	22	Mwe	Elk River, Minn.	1961	USAEC/RCPA
Pathfinder <sup>a/</sup>	BWR, nuclear superheat	61	Mwe	Sioux Falls, S. Dak.	1962	Northern States Power Co. <sup>b/</sup>
Big Rock Point	BWR	50-75	Mwe	Big Rock Point, Mich.	1962	Consumers Power Co. <sup>b/</sup>
Humboldt Bay	Advanced BWR	48.5	Mwe	Humboldt Bay, Calif.	1962	Pacific Gas and Electric Co.
BONUS <sup>a/</sup>	BWR, nuclear superheat	16.3	Mwe	Punta Higuera, Puerto Rico	1962	USAEC/Puerto Rico Water Resources Authority
ICBWR	Improved cycle BWR	50	Mwe	La Crosse, Wisc.	1964	under consideration <sup>b/</sup>
CVTR	HWR, pressure tube	17	Mwe	Parr, S.C.	1962	Carolinas Virginia Nuclear Power Associates, Inc. <sup>b/</sup>
Piqua OMR <sup>a/</sup>	OMR	11.4	Mwe	Piqua, Ohio	1961	USAEC/City of Piqua <sup>b/</sup>
POPER	OCR	50	Mwe	not decided	1964	under consideration <sup>b/</sup>
EGCR	GCR	22.3	Mwe	Oak Ridge, Tenn.	1962	USAEC/Tennessee Valley Authority
HTGR	GCR	40	Mwe	Peach Bottom, Pa.	1963	Philadelphia Electric Co. <sup>b/</sup>
HNPF	SGR	75	Mwe	Hallam, Neb.	1962	Consumers Public Power District <sup>b/</sup>

<sup>a/</sup> Discussed in this report.

<sup>b/</sup> Research and development support from USAEC.

10. The small power reactor projects have two main objectives. As experimental reactors, the plants provide basic technical data needed for large power plants and, as power producers optimized for small sizes, they furnish information on the extent to which such plants can be competitive with conventional plants in high fuel cost areas in the country.

11. Before constructing a large nuclear power plant, it is preferable to build a small sized prototype or an experimental reactor to obtain the necessary data on design and operating characteristics. Such plants cost much less and yield most of the information needed. For instance, the Dresden reactor was preceded by EBWR, Borax-1 - 4 and VBWR; HNPF by SRE; and PNPf by OMRE. Now, Borax-5, BONUS and Pathfinder are under construction and will lead to large sized nuclear superheat reactors.

12. Small power reactors are not always just a step towards the construction of bigger ones. In some cases such as that of the Elk River plant, where they are to be integrated into a power system, they are built for that purpose and are optimized for commercial power production.

13. In the United States the incentive to achieve competitive power from small nuclear plants stems from the need of a large number of small public utilities some of which are run as rural co-operatives. They enjoy the benefits of very low interest rates and if any of these utilities is in a high-fuel-cost area, then the combination of these factors offers a promising situation for the use of a small nuclear plant. There are some similarities between the situation that is faced by rural co-operatives in the United States and the power companies in some of the less-developed countries in as much as both have systems with small units, low load factors and low capital charges. USAEC feels that the experience gained in the technology and economics of small plants in the United States can be of considerable benefit to these developing countries in which fuel costs are high and where such plants could be of use.

14. Each USAEC power reactor project has specific and well-defined objectives which are determined before a decision is made to go ahead with the construction. For instance the Elk River project is for the purpose of studying thoria-urania fuel; BONUS is for studying nuclear superheat. Sometimes USAEC builds the reactors at one of its research centers - Borax-1 - 5 and EBWR at Argonne, EGCR at Oak Ridge.

15. In certain instances, experimental power reactors are built by private manufacturers under contract with USAEC. An instance is that of SRE (sodium reactor experiment), which was built at Santa Susana, California, by Atomics International. Some power reactors are built in co-operation with utility companies; USAEC pays for the reactor and retains its ownership, while the utility provides among other things the site and turbo-generator, and buys the steam at an agreed rate. In this category fall such projects as the Elk River, Piqua and BONUS.

16. For some other projects USAEC provides the necessary funds for research and development and may even supply the fuel free of charge during a certain period, but the reactor is built and owned by a private utility company. The Pathfinder is such an example. In such cases USAEC has the right to receive all the design and operating information developed through the project.

17. Lastly, there are some privately owned reactors which do not have any financial support from USAEC. These include the Dresden and the Saxton plants.

#### B. Management of the projects

18. The proper management of a reactor project is of special importance. As in the case of any industrial plant it helps to reduce construction time and total cost and ensures adherence to the desired specifications; in the case of nuclear plants, however, additional care is necessary to assure that the installation is safe and the design and construction is according to established regulations. It is not enough, for instance, to select a contractor for a turn-key job and leave the entire responsibility to him.

19. In the United States a typical power reactor project usually involves three parties, namely the reactor supplier, the utility company and USAEC. The reactor designer and manufacturer may also be the prime contractor employing a number of sub-contractors. His organization usually consists of a project engineer in charge of co-ordinating all technical matters including design, engineering and fabrication; an officer in charge of the implementation of contracts and a resident construction engineer who supervises the work at the site.

20. The utility company, which is the customer, has its own separate organization, consisting of the contract officer and a reactor plant manager supported by a group of technical men. The contract officer handles all negotiations for revisions and changes in the contracts and looks after the interests of the customer in the implementation of the agreement with the prime contractor.

21. The reactor plant manager, who is usually selected ahead of time, is assisted by a group of engineers and operators who will ultimately take over the plant and run it. This group must follow all the necessary technical details of the design and construction of the plant and learn the operating techniques. Sometimes it may be desirable to seek outside advice from an architect-engineer or firm of consulting engineers to ensure that the plant meets all the requirements of the utility company. The customer also has to make the necessary arrangements for the training of the operating staff in co-operation with the reactor supplier. Another important responsibility of the utility is to have an effective public relations program to educate and inform the population in the area.

22. USAEC is particularly concerned with the safety of the plant. As the national regulating and licensing authority it approves the site, construction and operation of the plant according to its safety criteria. Where USAEC also owns the plant or provides part of the finances, its responsibilities are proportionately greater. For instance, it handles the Elk River project through its field office known as the Operations Office, which administers and co-ordinates all activities in connection with a USAEC reactor project and works closely with the reactor designer, building and construction contractor, the utility company and local and state authorities. Its job is to ensure that all objectives of the project are fulfilled, specifications met, schedules adhered to, and above all that the plant meets the safety standards established by USAEC. The Operations Office has various divisions which actively participate in the implementation of the project. Usually, a project co-ordinator is designated for each project who is in close touch with all the divisions of the Operations Office, the contractor and the utility and provides guidance and co-ordination for the speedy and satisfactory completion of the project. There is also a site representative from this office who follows the progress of work on the spot and reports to the Operations Office.

23. The Reactor Engineering Division is responsible for the programming of all technical activities (excluding construction) for placing the reactor in operation, and for a continuing technical evaluation of reactor operation and performance. The Contracts Division has primary responsibility for the administration of the prime contracts with the design and operating contractors and for co-ordination of all matters concerning these contracts. The Engineering and Construction Division has primary responsibility for the administration of construction contracts and for the co-ordination of all matters concerning them. The Health and Safety Division develops and recommends safety policies and procedures and undertakes the safety review with which the Operations Office is charged.

24. The safety problems of a reactor project are of paramount importance and a summary of the main tasks carried out, in collaboration with the reactor designer and the utility company, as a part of the safety evaluation of a typical power reactor installation is given in paragraphs 25 to 36 below.

25. Site location and description. To site a reactor, necessary data on hydrology, geology, climatology, meteorology, seismology, topography, ecology, population and industrial density must be collected because of their effect on construction, effluent control, reactor operations and safety. These data are also needed for the preliminary hazards summary report.
26. Public relations and information. The construction of a reactor near a community raises many questions and it is essential to educate and inform the public so that it is not perturbed by rumors about radiation hazards. Through local civic organizations, the population has to be fully informed of all relevant facts concerning the plant and the measures taken to ensure its safe operation.
27. Preliminary hazards summary report. The preparation of this report should start when the conceptual design ends. It has to include in addition to the information mentioned in paragraph 25 above, a description of the reactor, the auxiliary systems, the facilities, the housing, and an analysis of the possible hazards. Although this report has to be prepared by the reactor designer, the Operations Office plays an important advisory role. It gives an outline of the subjects which should be discussed, reviews the draft and suggests revision, wherever necessary. The report is then usually sent to the Reactor Hazards Evaluation Branch of USAEC at Washington through the Division of Reactor Developments, which makes its own comments, and further improves it before presenting it to the Advisory Committee on Reactor Safeguards (ACRS) for approval. The construction of the reactor cannot start unless the site has been favorably reviewed by this Committee.
28. Pre-operational environmental monitoring program. While the reactor is being built, a complete survey of the radiation levels and of the soil and vegetation in the area has to be carried out so that the ambient conditions are fully established, and any departures from these, after the reactor start-up, can be observed. This requires the preparation of a monitoring plan, the fixing of sample points, the collection and analysis of samples, etc. The Operations Office works with the utility to organize this program.
29. Radiological physics. A health physicist has to be hired by the utility well in advance (about two years) of the date on which the reactor is expected to be critical. He sets up the health physics laboratory, prepares the health physics operating manual, and helps to give training in radiation protection. The Operations Office advises in the selection of the man and the organization of the health physics program.
30. Safety and fire protection. The design and construction of the buildings and facilities are reviewed by the Operations Office, in consultation with the contractors, to ensure compliance with the safety and fire codes.
31. Reactor operators training program. This program is initiated about two years before the reactor becomes critical. The reactor designer is responsible for this program but receives much help and advice from the Operations Office, in the selection of personnel, selection of courses to be held, and the training to be imparted. The Operations Office also reviews the operating manual, and makes arrangements for the Division of Licensing and Regulations to hold the operators licensing examination for supervisory and operating personnel.
32. Final hazards summary report. This report contains the final description of the facility emphasis being laid on those features which result from changes in the preliminary design. It also gives details of the administration, the organization, the plans and the procedures concerning the project, and a final estimate of the potential radiation hazard from the maximum credible accident. The final hazards summary report has to be completed at least four months in advance of start-up. As in the case of the preliminary hazards summary report, the Operations Office advises on its contents and reviews it before forwarding it to the Division of Reactor Development for further action. ACRS has to approve the report before permission is granted to make the reactor critical. For certain reactors the review by ACRS is followed by open public hearings.

33. Operating manual and emergency procedures. This is prepared by the designer in consultation with the Operations Office.

34. Initial criticality. The procedures for start-up and fuel management (handling, loading and unloading) are prepared by the designer and reviewed by the Operations Office.

35. Environmental monitoring. The pre-operational environmental monitoring program is reviewed with the assistance of the utility concerned and arrangements are made for a continued monitoring survey to keep a check on any increases in the radiation level in the surrounding area.

36. Continued safety review program. To ensure that the reactor is operated safely and in accordance with the approved procedures, a reactor safety review committee is constituted by the contractor. This committee carries out a pre-operational review and inspection of the reactor and evaluates the operating procedures and the influence of any significant changes in the system. After full power has been achieved, the Operations Office conducts periodic surveys for safety and fire protection, radiological physics, and reactor operational safety.

#### C. Interest of the utilities in the projects

37. Utilities, operating as co-operatives and serving in small municipalities, have evinced great interest in the future of small nuclear power plants. They feel that there is a strong justification for devoting much effort to the development of units in the range of 20 - 75 Mwe capable of producing power at competitive prices. According to them, there are not many utilities in the United States that could use large size power reactors in the 300 Mwe range. On the other hand, there are hundreds of smaller utilities which have a great need for smaller plants.

38. The experience of the utilities now building reactor plants indicates that great importance should be attached to contractual arrangements and negotiations in connection with a power reactor. Because of the far-reaching implications in building such plants, a great deal of legal and administrative work has to be done, the extent of which is not generally recognized in the beginning. Sufficient funds should be earmarked for this purpose.

39. With regard to the integration of the nuclear plant, the utilities tend to treat the reactors in the same way as a conventional station. For instance, in one case, it is planned to use the same operating staff for conventional and nuclear units on the same site. They are receiving training in the handling of nuclear plants, and will then pass the required licensing examination after which they will run the conventional as well as the nuclear units. This approach is based upon a desire on the part of the utilities to reduce the operating expenses to a minimum. In any case, it is necessary for USAEC to approve the staffing plan of the reactor station.

#### D. Operating staff and training

40. After the essential safety requirements have been incorporated in the design of a reactor, the proper and safe operation of the plant is in the hands of the operating personnel. USAEC exercises great care in the selection and training of the reactor staff so as to reduce to a minimum the possibility of an accident because of an operator's error. Although a large number of reactors have already been put into operation in the United States, no standardized training program for operators has been evolved. This is perhaps due to the fact that every reactor system has its special features and requirements which do not lend themselves to a common approach. Moreover, operating experience of the various types is not sufficient to enable the establishment of rules which would be applicable in all cases.

41. The present approach, therefore, is to find individual solutions to the problem of staffing each reactor. For instance, in the case of the Dresden, Yankee and Indian Point reactors, the companies concerned developed special training programs for their personnel in consultation with USAEC. For the projects under direct USAEC control, some operators are recruited from among staff already trained at various sites, while others come from utilities, and are given necessary theoretical and practical training. It may be mentioned that the reactors operations course at Oak Ridge and the operators training schemes at Shippingport have proved to be very useful, although the number of the persons thus trained is not sufficient to meet the requirements of the reactor projects now under way.

42. USAEC insists that for each reactor plant a detailed operating manual be prepared to cover all situations. This manual is a part of the final hazards summary report and has to be duly approved. USAEC representatives also visit the reactor sites unannounced to see if all the rules are being fully observed. Should they notice anything contrary to provisions of the license, the operation of the facility can be suspended until corrective action has been taken.

43. The operating staff for a reactor plant can be divided into three main categories, namely:

- (a) Operators;
- (b) Supervisors; and
- (c) Specialists.

Some of the basic qualifications of each of these, together with their training programs, are discussed in paragraphs 44 to 46 below.

44. Operators. In the case of those reactors the licensing of which is subject to public hearings, operators are required to obtain a license which is granted by USAEC after a thorough theoretical and practical examination given at the reactor site. A power reactor operator must have at least a high school diploma, and in addition it is desirable that he should have several years' operating experience in a conventional or nuclear power plant. He should have an aptitude for physics, mathematics and technology. It is considered preferable not to employ persons with an advanced degree because they may have a tendency to depart from the established operating procedures. Moreover, the job is too much of a routine to hold their interest for long.

45. Supervisors. The supervisors should be senior persons with long experience in running and managing a conventional or nuclear power plant. They should have received advanced theoretical and practical training in all problems relating to operation and safety of the reactor. The plant manager in particular should have training in health physics so that he fully understands the importance of the health and safety regulations which must be observed by all persons working in the plant.

46. Specialists. Finally, specialists are needed to provide the following essential services:

- (a) Health physics services

It is most desirable for the health physicist to have basic training in radiological physics together with practical experience with a reactor health physics group. He should also have a good knowledge of instruments used for measurements and detection of radiation. The health physicist should be assisted by at least one technician to help in radiation surveys and monitoring, and to keep a complete record of the exposures received by the staff. He should be a high school graduate with some training in a reactor plant;

(b) Reactor safety and fuel handling and management

The presence of nuclear fuel, whether inside or outside a reactor, presents many special problems which should be looked after by a well qualified and responsible person. He should be particularly familiar with criticality hazards connected with fuel storage. He can also carry out fuel management and account for the fissionable material going in and out of the plant;

(c) Instrumentation, repairs and maintenance

The recruitment of qualified instrumentation men poses a real problem. There are relatively few people available who are familiar with the use of pulse circuits, counters, detectors and other equipment associated with the electronics and control of a reactor. If an experienced man is not available, a good electronics man can be selected and given at least a year's training in the types of instruments and controls used in the plant; and

(d) Chemical analysis

The control of the quality of water or organic liquid going into the reactor and the analysis of reactor wastes is very important for the safe and proper operation of the plant. This requires an experienced chemical analyst. For general maintenance of the plant, it is preferable to start with a person having experience in similar work in a conventional plant. He should receive on-the-job training at the power reactor, and indoctrination in the principles of radiation protection.

E. Nuclear superheat

47. General. A considerable amount of work is being done in the United States of America, the Union of Soviet Socialist Republics, the Federal Republic of Germany and Japan on the development of nuclear superheat reactors in which there is now a growing interest. These reactors can be of various types such as the graphite or D<sub>2</sub>O moderated pressure tube type; the non-integral boiling-water type having two separate cores, one for boiling and the other for superheating; and the integral type, using only one core with one zone for boiling and the other for superheating.

48. Four nuclear superheat power reactors are currently under construction in the United States, namely the Borax-5 at Argonne, Idaho; the Pathfinder at Sioux Falls, South Dakota; BONUS at Punta Higuera, Puerto Rico; and the Vallecitos experimental superheat reactor (VESR) at San Jose, California.

49. The Borax-5 is a flexible reactor which is expected to be ready by the end of 1961 and will be used to test various nuclear superheat concepts using different core arrangements and to study the stability of boiling reactors at high power densities. VESR which is expected to be in operation by June 1962, is a steam-cooled flexible test-bed capable of testing a large number of superheated fuel elements. It will get its steam supply from a separate conventional boiler or from the Vallecitos boiling-water reactor (VBWR). The Pathfinder and BONUS reactors are full scale integral superheat power plants and are discussed in detail in this report.

50. Besides the above mentioned reactors several conceptional design studies on large sized nuclear superheat reactors are being undertaken. These cover integral and non-integral (steam-cooled) types including mixed spectrum and Zr-H moderated reactors.

51. Incentive for nuclear superheat. The basic incentive for nuclear superheat is economic. Water reactors which produce low temperature saturated steam require, at present, large specially-made turbines which are costly and not very efficient. If reactors can produce superheated steam at high pressures, smaller and more economical turbo-generators of the standard type - which are to be preferred - can be used in the power plants. This will lead to a gain in plant efficiency that could be increased to 40% and could be comparable with that of the most efficient conventional stations. The result will be savings in nuclear fuel, reduction in piping and pumping requirements, and other auxiliary services, and a lowering of the cost of containment. The total savings in generation costs for a large plant may be about 0.5 mill/kwh for future plants, which is equal to about 7 - 10% of the generating costs for water reactors without superheat.

52. Major problems. Although nuclear superheat reactors hold forth the promise of cheaper nuclear power, there are a number of technical problems which must still be solved. All the design problems associated with the boiling-water reactors have to be overcome, in addition to those associated with nuclear superheat itself. An integral superheat reactor, for instance, exhibits the characteristics of a boiling-water reactor (in the boiling region) and a gas-cooled reactor (in the superheater region) and, as such, inherits the problems of both.

53. Some of the basic problems concerning nuclear superheat are:

- (a) Fuel element. The success of nuclear superheat is largely dependent on the development of a satisfactory fuel element having long-term integrity and designed with due regard to neutron economy and net costs. This fuel element must be capable of achieving high burn-ups under the severe temperature and pressure conditions characteristic of a nuclear superheater;
- (b) Radioactivity. Since the superheated steam will be used directly, the amount of radioactive material carried over to the turbine and condenser should be within tolerable limits. The corrosion of highly active stainless steel fuel cladding and of the surfaces is a matter of particular concern. The residue resulting from evaporation of the moisture contained in the steam and its deposition on the fuel elements in the superheat should be kept to a minimum;
- (c) Operational safety.
  - (i) The potential hazards associated with the flooding and unflooding of the superheater section should be avoided;
  - (ii) The proper power distribution between the boiling and superheating regions must be maintained without introducing other problems such as intolerable hot spots and instability; and
  - (iii) Adequate shut-down cooling for the nuclear superheater elements must be guaranteed even if the flow of steam to the turbine is interrupted; and
- (d) Materials. It is essential to develop alloys and materials for fuel cladding and for the superheater section having good mechanical strength at high temperatures and pressures, resistance to radiation damage and corrosion, and good heat transfer properties.

### III. THE ELK RIVER POWER REACTOR

#### A. General

54. The Elk River reactor is a natural circulation, indirect cycle, boiling-water reactor having a thermal output of 58 Mw, supplemented by 14 Mw from a coal-fired superheater, to give a net electrical output of 22 Mwe. This reactor has been built as a part of the power demonstration program of USAEC to gather practical experience on the operation and cost of this type of plant as a source of power for base load operation in a grid.

55. The reactor is located next to an existing steam plant of the Rural Co-operative Power Association of Elk River, Minnesota (RCPA), which is a small utility serving a population of 60 000. The contract between RCPA and USAEC stipulates that RCPA will furnish the turbogenerator facilities and the site, whereas all expenses in connection with the reactor will be borne by USAEC. RCPA will operate the reactor for USAEC and purchase the steam generated from the reactor at a rate which is comparable with the cost of power from its conventional stations. After five years of operation, RCPA has the option to purchase the reactor.

56. The prime contractor for the reactor is Allis-Chalmers Manufacturing Company, which is responsible for the design, engineering, construction, start-up and test operation of the reactor and associated plant, and training of the operating personnel. The work is being performed on a cost type contract with a maximum ceiling and a fixed fee. The formal contract was signed in June 1958 and construction began in August 1958.

#### B. Important design features

57. A summary of important data concerning the reactor is set out in Annex I, and a schematic diagram of the reactor system is shown in Figure 1.

58. Objectives. The object of building this reactor is not to advance boiling-water reactor technology as such, but by keeping the design innovations to a minimum, to construct a plant which will operate with maximum reliability and safety and continuously supply power to a small utility system. Elk River reactor is essentially a modified version of EBWR, with the same basic design features. The essence of its design is simplicity and safety. The distinguishing feature of this reactor is the fuel which, unlike that of EBWR, consists of a mixture of 4.3% enriched UO<sub>2</sub> (Urania) and ThO<sub>2</sub> (Thoria) in the form of pellets contained in stainless steel tubes. It is one of the first commercial nuclear power plants to use a uranium-thoria mixture although samples of this type of fuel have already been tested successfully in EBWR core. The experience gained in this type of fuel cycle will greatly add to the know-how in the use of thorium as a fuel, and several countries which have large deposits of thorium will watch with interest the results obtained.

59. The reactor operates on an indirect cycle using an intermediate heat exchanger so as to eliminate the carry-over of any radioactivity into the turbine. This is a very conservative approach because it has already been demonstrated that the transfer of steam from the reactor directly into the turbine does not pose any significant hazard. Nevertheless, an intermediate heat exchanger has been added, as an extra precaution.

60. A coal-fired superheater is used to improve the quality of the secondary steam to 825°F in order to permit the use of a preferred standard efficiency turbine. The over-all effect of the use of the superheater will be a lowering of generating costs.

61. The stability of the reactor has been assured by having a relatively low average power density of 39.6 kw/l of the coolant, and a high pressure of 936 psia, as opposed to Borax and EBWR, which have proved to be stable at higher power densities and lower pressures. Borax-4 had a power density of 67.5 kw/l and a pressure of 300 psig. The corresponding values for EBWR were 65 kw/l and 600 psig.

62. The plant has been designed for eventual operation at twice the initial power level by using forced circulation. Thus, the containment shell, reactor vessel, shielding, heat transfer equipment, emergency condenser and other permanent fixtures are designed for 116 Mwth. Space has also been provided for the installation of an additional steam generator, sub-coolers and other auxiliary equipment.

63. Core. The reactor core is a cylinder approximately 5 ft. in diameter and 5 ft. high. It contains 148 fuel elements with room for 16 more. It has 13 cruciform-type control rods. Water entering at the bottom at 450°F moves up by natural convection through the reactor core as it becomes heated and leaves the reactor in the form of steam at 536°F.

64. Pressure vessel. The pressure vessel is a 7 ft. diameter cylinder 25 ft. high with a removable elliptical head having four 12 in. nozzles. It is made of 3 in. thick grade B carbon steel as base metal, with a 304 stainless steel internal cladding of 0.109 in. thickness, capable of withstanding a design pressure of 1250 psig with a margin of safety of four. In designing the number of steam outlets and water inlets, provisions have been made for doubling the output of the reactor with forced circulation.

65. Shielding. A combination of a 3.75 in. lead and steel thermal shield with an 8.5 ft. ordinary concrete having a density of 2.4 g/cc is used for biological shield to reduce the activity around the reactor to less than 2.5 mrem/hr at 116 Mwth. Provisions have been made for stacking additional 1 ft. concrete shielding, if necessary, around the reactor. At 58 Mwth operation it is not necessary to shield the primary system piping.

66. Containment shell. The reactor containment shell serves the purpose of containing any release of fissionable material from the reactor in case of an accident. It houses the reactor, steam generator and other auxiliary equipment associated with the nuclear plant. The reactor control room and turbogenerator are located outside the containment shell in an adjoining conventional building. Suitable gas-tight penetrations in the shell have been provided for steam pipes and cables. The cylindrical containment building, with a hemispherical top, is 115 ft. high with an internal diameter of 74 ft. and a total free volume of 287 000 cu ft. It is made of carbon silicon steel plates welded together, which have thicknesses varying from 0.87 in. on the sides to 0.5 in. at the top. It is lined inside with ordinary concrete of thickness varying from 2 ft. on the sides to 4 in. at the top. Outside of the shell is covered with 2 in. of insulation. Important design conditions for the containment vessel are:

- (a) Maximum internal pressure of 21 psig and maximum negative pressure of .5 psig;
- (b) Maximum leakage rate of .1% of free volume per day at an internal pressure of 21 psig; and
- (c) All welds with a joint efficiency of 90%.

Calculations indicate that at 116 Mwth operation pressure build-up after sudden primary system rupture and instantaneous flashing of water will be 20.3 psig which is less than the designed value.

67. Fuel handling and storage. Fuel handling has been greatly simplified in this reactor. The loading of new fuel and unloading of spent elements is done manually under water. There is no need for a special coffin and the operation can be carried out by three persons (including a health physics technician) using simple tools. First the reactor is shut down and after about eight hours for the reactor to cool, the top shield plug is removed. The steel lined cavity, which is linked with the adjoining fuel storage valve, is filled with water, and lights and viewing equipment are lowered for good visibility. The bridge which runs over rails is positioned over the reactor. After proper indexing, the fuel handling tool is lowered into the fuel element to be removed by a steel cable. The tool engages the fuel element securely which is then raised up and transferred via the canal to the storage area. At all times the fuel element remains under a minimum of 8 ft. of water. Fresh fuel elements which are kept around the storage pool are picked up and lowered into the core in a similar manner.

68. Allowing about 12 hours for the reactor water to cool and make preparations for refueling, it would take about 36 hours in all to unload and reload one-third of the core. The resulting dose received by the operators carrying out fuel will not exceed the weekly tolerances. The spent fuel elements are stored on racks in the storage pit and kept under 25 to 32 ft. of water. After 120 days these fuel elements are put into a special cask the tolerance rate around which is not expected to be more than 2.5 mrem/hr. The present indications are that the loaded cask will be transported by a truck to the processing site.

69. Waste disposal system. The design of the Elk River reactor is such that only very small quantities of radioactive waste material should accumulate in the course of operation at full power. Since natural circulation is used instead of pumps in the primary system, there is no pump leakage. In view of this, no facilities are planned at the site for concentration and local disposal of high level radioactive waste materials. All suspect materials will be stored inside the containment vessel for batch disposal later on.

70. Radioactive primary water is not expected to leak from the system at a rate of more than three gallons a day. Two retention tanks, each with a capacity of 3 000 gallons, are provided for collecting and storing all waste water. Active material from this water is removed by passage through the purification system. Water will be discharged to the building drain system and be carried to the river only when prior radio chemical analysis has shown the concentration of radioactivity to be well within tolerances corresponding to one tenth of the maximum permissible concentration. Solid wastes accumulating from primary purification loop and residue filling are placed, after proper cooling, in drums to be filled with concrete. The drums can then be shipped from the site for burial.

71. The building air conditioning system filters 3 000 cu ft/mt of air continuously and after proper monitoring, it is released through an air stack, if the radioactivity is less than the permissible level.

### C. Safety

72. Safety in design. Great emphasis has been placed on making this plant as safe as possible without increasing the costs beyond a reasonable limit. The Elk River reactor, like other boiling-water reactors (Borax, EBWR, VBWR, Dresden, etc.) has a large negative void coefficient (at operating level  $0.19\% \frac{\Delta k}{k}$ ) which assures inherent safety against fairly rapid and reasonably large reactivity additions. However, the use of thorium-uranium-ceramic fuel, with its low conductivity and large time constant, partly reduces the effectiveness of the negative void coefficient because it prevents the prompt formation of such voids. In spite of this, the steam void coefficient alone is sufficient to take care of transients with periods down to 100 milliseconds or reactivity insertions up to  $0.65\% \frac{\Delta k}{k}$ . For rapid reactivity increases, greater than  $0.65\% \frac{\Delta k}{k}$  and up to  $0.9\% \frac{\Delta k}{k}$  and shorter  $k$  periods, reliance has been placed on the large metal temperature coefficient which compensates for the weaker void coefficient.

73. An auxiliary boric acid injection system, that is operated manually, has been provided for use in emergencies. Boric acid solution at 200°F and 2 000 psig capable of giving 2% shut-down margin with all rods out can be inserted into the core in 10 seconds.

74. In designing the reactor pressure vessel piping, primary steam generators and sub-auxiliaries, ASME codes are followed, which give a margin of safety of four between the design pressures and that required for rupture. Similar high factors of safety were used in the design of mechanical equipment in the plant.

75. Control. The control of the reactor is so arranged that all situations which require immediate remedial action to prevent a serious accident will cause an automatic shut-down. Under conditions which can lead to dangerous situations but which are not hazardous in themselves, alarm signals are used. Failure of the operator to take immediate action on these alarm signals will not result in an accident, although the operator should correct the dangerous situation as soon as possible.

76. Reactivity control is obtained by 13 cruciform-type control rods and the use of boron as burnable poison in stainless steel fuel cladding. The maximum excess reactivity in the cold clean core is  $12.7\% \frac{\Delta k}{k}$ , which is controlled by the negative reactivity of 13 control rods having  $18.3\% \frac{\Delta k}{k}$ , and of burnable poison having  $5.8\% \frac{\Delta k}{k}$ , leaving a minimum net negative reactivity of  $11.4\% \frac{\Delta k}{k}$  for safety under all operating conditions. Even if the central control rod should fail to enter the core, the reactor would be sub-critical by at least  $2.6\% \frac{\Delta k}{k}$  at all temperatures. The maximum rate of reactivity insertion due to the withdrawal of the central control rod is  $0.06\% \frac{\Delta k}{k}$ .

77. Use of boron as burnable poison in fuel cladding serves two purposes. In the beginning it helps to control the excess reactivity in the core; later on, as the fuel is used up, it also burns away and partly compensates for the loss of reactivity in the fuel.

78. Also available are removable boron steel pins and spiked fuel elements enriched to 5.2% which may be used for reactivity changes if necessary.

79. Site. The reactor is located on the site of an existing steam plant alongside a river near the village of Elk River (population 1 400), which is a small farm-type community. It is 30 miles from the cities of Saint Paul and Minneapolis (population 1 million). The exclusion area is 240 acres. The population distribution as a function of the distance from the reactor is shown in Table 2 below.

Table 2

Population distribution

Distance in miles	Population density/sq. mile
0.25	0
0.50	60
1.00	200
5.00	2 656
10.00	7 700

80. The site is accessible by road and rail. The surface drainage is from the reactor site towards the river and the nearest water supply intake for the City of Minneapolis is about 21 miles down river.

81. A detailed survey of the geology and hydrology of the site and the vicinity was performed to estimate the time it would take for a large liquid spill at the reactor site to reach the river water, either by surface flow or by percolation through the ground.

82. An exhaustive meteorological analysis of the area, based upon several years of available data, was made to determine how any accidental release of activity might be spread over the surroundings.

83. Analysis of maximum credible accident. The hazards summary report for the Elk River reactor gives the detailed analysis of the possible consequences of a maximum credible accident, based upon the assumption that the 16 in. diameter water inlet pipe suddenly ruptures and the entire core is drained off in 10 seconds. Under the worst circumstances, when there is a delay of 6.83 minutes in initiating the emergency cooling water flow from the 30 000 gallon overhead storage tank, the claddings of 8.62% of the fuel pins might melt and release fission products.

84. As a result of this rupture in the primary system and consequent steam flashing, the pressure build-up in the containment shell would be 20.3 psig for 116 Mwth operation. This is less than the rating of the containment shell, which is 21 psig. Therefore, the leakage rate will not exceed the designed value of .1% of the volume in 24 hours.

85. In Table 3 below is shown the direct radiation dose rate at various distances from the containment shell, which would result if all the volatile fission products and 5% of the strontium contained in the melted fuel pins were to be released.

Table 3

Elk River plant: direct radiation dose rate at various distances

Distance	Total rem/first hour
200 ft.	0.692
$\frac{1}{4}$ mile (exclusion area)	0.037
$\frac{1}{2}$ mile	0.009

86. The resulting radiation effects in the surrounding area, under the worst meteorological conditions, are shown in Table 4.

Table 4

Elk River plant: integrated dose rates

Distance	Whole body gamma dose rem/8 hours	Integrated iodine inhalation (dose) rem/first hour	Strontium inhalation (dose) rem/first hour
200 ft.	0.87		
$\frac{1}{4}$ mile (exclusion area)	0.20	28.3	0.420
$\frac{1}{2}$ mile	0.11	8.5	0.126
1 mile	0.07	2.5	0.030

87. The normally accepted emergency doses are 25 rem for the whole body and 300 rem due to iodine inhalation. The expected doses are well below these values.

#### D. Fuel cycle

88. Objectives. There has been considerable interest in the use of thorium bearing fuels because of the favorable nuclear properties of  $U^{233}$  which is produced from the thorium, and recently a symposium was held on the subject [3]. To provide experience in such use the Elk River reactor is being fueled with a mixture of thorium and uranium with a  $U^{235}$  content of 4.3% of the weight of uranium and thorium. Twenty-two spiked fuel assemblies containing 5.2%  $U^{235}$  have also been fabricated for use as a standby.

[3] Symposium on "Uranium-Thorium Cycle", CNEN, Rome, 13-15 June 1961.

89. The fissile fuel content of the spent fuel can be returned to USAEC for credit. However, since the price and demand for this material must eventually be based upon the cost of its recovery and re-use in a reactor, a study has been made by the Allis-Chalmers Manufacturing Company for CNEN on the construction of a pilot plant (capacity 15 kg of fuel/day) for the processing and fabrication into fuel elements of this and similar fuels, to provide information on the economics of the cycle.

90. Fuel element design. There are 148 standard fuel elements in a core loading of the reactor. Twenty-two spiked fuel elements have also been fabricated for standby, which contain 24 spiked rods and one center standard rod. The fuel elements are 81 5/8 in. long, about 3 1/2 in. square, and weigh 85 lbs. each. Each one consists of 25 stainless steel rods, 61 in. long and 0.452 outer diameter containing about 600 parts per million of boron as a burnable poison. The center pin of a fuel bundle is interchangeable with a borated stainless steel pin. Each fuel rod is filled with 120 ceramic oxide pellets of thorium and uranium. Grid castings at the ends hold the rods in a 5 by 5 array; top and bottom fittings support and position the elements in the core, and clamps maintain the correct spacing between the rods over the length of the assembly.

91. The fuel pellets are solid right cylinders  $0.4075 \pm 0.002$  in. in diameter, with pellet faces perpendicular and parallel to within 0.005 in. The standard fuel pellet contains 95.4% thorium, 4.3%  $U^{235}$  and 0.3%  $U^{238}$  (4.6% of approximately 93% of  $U^{235}$ ). The pellets may contain up to 0.4% of a densifier such as calcium oxide or titanium oxide, replacing an equal weight of thorium oxide. The density of each pellet is a minimum of 9.46 g/cc (94% theoretical).

92. Each rod contains a  $60 \pm \frac{1}{4}$  in. stack of fuel pellets whose total oxide fuel weight is  $1226 \pm 10$  grams, containing  $46.3 \pm 0.5$  grams of  $U^{235}$  ( $1227 \pm 10$  grams containing  $56.06 \pm 0.56$  grams  $U^{235}$  in the case of spiked rods).

93. The seller of the fuel is not liable for the uranium use charge up to 110% of the amount of  $UO_2$  present in the fabricated fuel elements and for non-recoverable  $UO_2$  losses up to 1.5%, but is liable for excesses above these amounts.

94. The contract warranty on the fuel elements provides for 6 700 Mwd/t of thorium and uranium peak exposure. This will result in 4 800 Mwd/t average exposure. The estimated maximum burn-up is 28 200 Mwd/t, and theoretical average batch exposure is 8 600 Mwd/t. The expected average exposure of the fuel discharged is 9 500 Mwd/t (0.22 atom per cent burn-up).

95. Burn-out at high heat fluxes is estimated to occur at 1 million BTU/hr-ft<sup>2</sup> whereas the maximum expected heat flux is 313 000 BTU/hr-ft<sup>2</sup> at 58 Mw of reactor power output.

96. Fuel element fabrication. Very high standards of precision are maintained in fuel fabrication. The fabrication of the fuel elements consists of four stages, namely:

- (a) Fuel rod fabrication;
- (b) Upper-end fitting;
- (c) Lower-end fitting; and
- (d) Fuel element assembly.

97. All fuel rod tubes must conform to tolerances on length, straightness, ovalness and squareness, and an eddy current test which detects irregularities. Ten per cent of the tubes are given a rigorous visual examination to determine intergranular attack of the inside and outside surfaces.

98. A threaded end-plug is automatically fusion-heliarc welded to the bottom of a fuel-rod tube. The weld is radiographed and leak tested at this point or after the top plug is welded to the tube. Each fuel pellet is then visually inspected (any cracks or chips exceeding 5% of the total area is a cause for rejection of the pellet), and then loaded into a tube to a length of  $60 \pm \frac{1}{4}$  in. The tube is evacuated to 500 microns or less and then filled with 99.9% grade helium at one atmosphere. The top threaded end-plug is then automatically fusion-heliarc welded to the fuel rod in a helium atmosphere specified previously. Two radiographs are taken of each fuel rod weld and compared with those taken simultaneously of standard defective end-plug welds (i. e. welds containing two 0.02 in. deep radially drilled holes  $120^\circ$  apart, one hole being filled with lead). For radiographic inspection of the pellets in the rods, 20% of all rods are selected at random and radiographed over their full length.

99. All rods are then leak tested with a mass spectrometer helium leak detector. Any rod or assembly having a leakage of greater than  $1.5 \times 10^{-5}$  cc/sec at  $550 \pm 50^\circ\text{F}$  over its entire length, is rejected.

100. The box for the upper-end fitting is fabricated from 304 stainless steel sheet, all seams being resistance welded. An adaptor for the fuel rods is then welded to the box with an inert-gas shielded arc. The fitting is cleaned by vapor-degreasing and rinsing in hot water followed by methyl alcohol and air-drying.

101. The transition piece, tube, and nose fitting of the lower-end fitting is also resistance welded in an inert gas, the necessary surfaces machined, and welds cleaned as above, after removal of welding scale with a stainless steel brush.

102. For the fuel element assembly, five-rod fuel element sub-assemblies are fabricated by placing five rods in a fixture that holds them in a plane with spacing clips of adjacent rods overlapping. Fuel elements are then assembled from five five-rod sub-assemblies and two 5 x 5 grids. Nuts are placed on the threaded end-plugs to hold the grid plates in place, and then tack welded. The grids of the fuel element and the end-fittings are welded together, and the welds of the final fuel assembly cleaned as previously described.

103. Fuel management. The initial loading of the reactor is 148 standard fuel elements, about 40% of which will contain borated center pins, with 22 spiked fuel elements for standby and start-up versatility. The core can accommodate 164 elements. In normal operation the reactor will be shut down for removal of spent fuel at intervals of approximately one year (12 to 15 months). The fuel handling, both loading and unloading, will be carried out manually under water, as has been described previously.

104. Only a third of the 148 elements having an expected exposure of 9500 Mwd/MTU will be replaced annually. They will be removed from the center of the core, elements in the outer regions will be moved in radially to the center, and new elements placed in the outer perimeter. The reactor is expected to operate about 4750 Mwd/MTU (320 days) before the boron pins must be replaced. After pin replacement the reactor is expected to operate an additional 4750 Mwd/MTU (320 days). The irradiated fuel elements will be stored in the adjacent cooling pond for 120-180 days.

105. Plans have not yet been finalized for the shipment and processing of these elements. However a contract has been negotiated for the design and fabrication of a shipping cask weighing about 30 tons which could accommodate 24 Elk River or 13 Piqua fuel elements. The expected delivery is July 1962 and the estimated cost is \$85 000.

106. Consideration is being given to the processing and re-fabrication of the fuel elements in the pilot plant facility proposed for construction by CNEN. Under equilibrium conditions these elements might achieve an average exposure of 18 500 Mwd/MTU.

E. Construction experience

107. The ground was broken for this plant in August 1958 and it was estimated that construction would be completed in 30 months and that the reactor would be critical by the end of 1960. In November 1960 the construction was virtually complete but the start-up had to be delayed for a number of reasons. In general no major problems were encountered in the actual construction of this plant except for the usual difficulties normally associated with any industrial or conventional power plant. The construction contractor estimates that it took about 300 000 man hours to build the plant. It would normally take 29 to 36 months to complete a reactor of the Elk River type in the United States compared with 24 to 30 months for a conventional plant of the same size. Details concerning the time schedule for the project are given in Table 5.

Table 5

Elk River plant: time schedule for the project

Item	Initial estimate	Actual
Start of construction	August 1958	August 1958
Containment shell erection	January 1959	March 1959
Reactor vessel (fabrication and delivery)	January 1959	July 1959
Control rod drives	February 1959	July 1959
Reactor building	April 1959	August 1959
Completion of construction	November 1960	December 1960
Fuel elements delivery	November 1960	September 1961
Initial criticality	December 1960	October 1961 <sup>a/</sup>
Full power testing	March 1961	December 1961 <sup>a/</sup>

a/ Expected.

108. The original schedule called for plant start-up by the end of 1960. Later the date was revised to March 1961. The latest estimate is that the reactor will become critical in October 1961. It appears, therefore, that the start-up has been put off by about nine months. This delay has been caused by a combination of factors including a steel strike, the redesigning of the fuel elements and their re-fabrication, and re-work on the pressure vessel and control rods. All of these problems are conventional in nature rather than nuclear. It may be pointed out that whenever any changes are made in a component of the reactor plant extensive reviews are required to ensure that the change has not affected the safety of the reactor as a whole. Such reviews or hearings, though necessary, take time and delay the completion or operation of the plant. It appears that as more experience is gained in building and operating nuclear reactors it may be possible to make certain alterations during construction without raising any doubts about their effect on the safety of the system.

109. Some comments on certain important phases in the construction of this project are as follows:

(a) Reactor vessel

110. The delivery of the vessel was delayed by three to four weeks on account of a steel strike. An X-ray examination of the nozzles indicated some cracks in one of them; it had to be sawed off and a new transition piece was welded in its place. Visual examination of the pressure vessel showed a few cracks in a section of the cladding surface. This area

was grounded away to base metal and re-clad with a richer alloy, thus necessitating a review of the ability of the vessel to meet the specifications and code requirements. The review committee has reached the conclusion that the work will not affect the ability of the vessel to meet the design specifications.

111. It may be mentioned that stainless steel clad pressure vessels are also used in several industrial plants but in the case of a nuclear reactor the tolerances are closer and inspection more rigid which can lead to further work in case of doubt.

(b) Fuel elements

112. The original design of the fuel elements involved the use of grid wire for spacing the fuel rods and to ensure the mechanical stability of the assembly. This was considered unsatisfactory and replaced by straps located at between a third and two-thirds of the distance along the length of the fuel assembly. Spot welding of the straps to the fuel rods resulted in leakage under test. The new design provided for pressure clamping of the straps to the fuel rod and welding to each other instead of to the rods. The fuel element redesign, re-fabrication and consequent reviews were factors in delaying the start-up of the plant.

(c) Control rods

113. The original 17-4 PH steel control rod drives were returned for re-heat treatment in the light of experience with such drives on the Dresden reactor.

(d) Skills required

114. In general most of the skills needed for building the plant, excluding the core, were conventional and similar to those needed for an ordinary steam plant. The installation of the core components, which is high precision work, was accomplished by the engineers of the reactor designer and manufacturer.

115. The construction of the carbon steel containment shell required 15 expert welders experienced in carbon arc welding who had passed the required code tests. Five ordinary welders assisted them. The welders worked under the guidance of a superintendent, a foreman and a lead man and finished the job in seven months. All welds were X-rayed and only 10% had to be re-done.

116. Stainless steel pipe welding was carried out by six qualified welders in about six months under the direction of a supervisor and a foreman.

117. All carbon and stainless steel welds were radiographed by an X-ray man and two assistants.

118. With regard to the training of the welders, it is felt that a person with some welding experience can qualify for this work after three months of specialized training under a good instructor.

(e) Concrete pouring

119. All concrete pouring work in the plant, including shielding, containment shell lining, floors, etc., took about eight months using on an average 35 men. Heavy concrete pouring required extra care and some persons were given on-the-job training for this purpose. This work normally takes twice the time needed for ordinary concrete pouring.

(f) Present status

120. The construction of the plant has almost been completed. One hundred and seven fuel element assemblies have already been delivered to the site and the rest are expected by October 1961. Open public hearings in connection with the licensing of the plant may take place in September 1961. Initial loading and criticality tests will be carried out as soon as the hearings are over. Present indications are that the plant may become critical by October 1961 and full power may be reached four to six months later.

F. Cost data

121. Construction. At the time the project was initiated, the estimated design and construction costs for the reactor plant to be borne by USAEC were \$9.4 million. This included the cost of the superheater. As of May 1961, the total estimated project costs were given as \$9.01 million although the actual cost may be somewhat higher. The breakdown of these costs is given in Table 6.

Table 6

Elk River plant: cost breakdown

(In thousands of US dollars)

Item	Cost of materials or equipment	Cost of labor or installation	Total
Reactor plant structures and services	1 216	234	1 450
Reactor equipment (controls, vessel, shielding, etc., excluding fuel)	1 006	36	1 042
Process system (evaporators, pumps, tanks, heat exchangers, etc.)	1 022	37	1 059
Superheater system (superheater, structures and services)	734	73	807
Sub-total	3 978	380	4 358
Engineering and design			1 034
Indirect and general project costs			2 993
Sub-total			8 385
Fuel fabrication (including development)			630
TOTAL			9 015

122. Excluding the fuel and fabrication costs of \$630 000 but including the RCPA cost of \$1.59 million (structure and site improvements, turbogenerator, accessory electrical equipment, and miscellaneous plant transmission) the total cost is about \$10 million. This gives a unit capital cost for the 22 Mwe plant (58.2 and 14.0 Mwth of nuclear and fossil-fuel heat respectively) of \$455 per kilowatt.

123. There is the possibility that the reactor may eventually achieve double the design power, and provision has been made to accommodate the additional equipment which would be needed. The achievement of this power output would significantly reduce the unit capital cost.

124. Fuel. Initially the estimated fuel costs were about \$700 000. However, the present cost incurred and committed for fabrication of the fuel elements is \$470 728, which includes the cost of the 148 standard elements for loading, and of the 22 spiked elements for use as a standby. This gives a fabrication cost of \$2 770 per element containing 26.9 kg U and Th, or a cost of \$101/kg, resulting in 2.3 mills/kwh at the warranty burn-up, or 1.1 mills/kwh at the expected burn-up of 9 500 Mwd/t.

125. The cost data [4] in Table 7 below refer to a third of an equilibrium core (18 500 Mwd/t) where the U and Th content is 1 329 kg containing 4.3% U<sup>235</sup> (1 268 kg Th, and 68 kg of 93% U<sup>235</sup>).

Table 7

Elk River plant: estimated fuel cost data

Item	Cost in \$	\$/kg fuel through the core
<b>Pre-irradiation</b>		
Conversion and pelletizing	31 637	24
Thorium	19 735	15
Fabrication	44 472	33
Reprocessing scrap	2 330	2
Shipping	1 450	1
Use charge, at 4%/yr <sup>a/</sup>	21 568	16
Interest on borrowed capital, 6 months at 4%/yr	2 424	2
Sub-total	123 616	93
<b>Irradiation</b>		
Total burn-up	480 260	
Less U <sup>233</sup> credit at \$15/g	<u>152 588</u>	
Net burn-up <sup>a/</sup>	327 672	247
Use charge, core and spares <sup>a/</sup>	141 814	107
Interest on borrowed capital, 17.5 months at 4%/yr	27 370	20
Sub-total	496 856	374
<b>Post irradiation</b>		
Shipping	16 197	12
Reprocessing and turn-around	91 800	69
Reprocessing losses	11 330	9
Use charge, at 4%/yr <sup>a/</sup>	8 284	6
Interest on borrowed capital, 5 months at 4%/yr	2 127	2
Sub-total	129 738	98
TOTAL	750 210	565

<sup>a/</sup> Recently a reduction in the enriched fuel and an increase in the use charge to 4.75% has been announced by USAEC. This will slightly affect the estimates given.

[4] DICKSON, J.J. and BLACHLY, S.H. "The Elk River Reactor", VIth Nuclear Congress, CNEN, Rome, 13-15 June 1961.

126. Based upon the given nuclear core cost of \$750 210 for 10 080 hours of full power operation, this yields \$74/hr or 3.4 mills/kwh for the nuclear cost. Adding the cost of the coal for the superheater at \$25/hr, or 1.1 mills, gives a total fuel cost of 4.5 mills/kwh.

127. It has been estimated by CNEN that their pilot plant facility would cost about \$4 million, which would have a capacity about twice that required for the Elk River reactor, and that thorium bearing fuel from a reactor could be processed and re-fabricated for about \$200/kg of fuel. For a fuel exposure of 20 000 Mwd/t, which is expected from this type of fuel, the generating cost would be 2 to 3 mills/kwh, which includes costs for chemical conversion, make-up of U<sup>235</sup>, inventory and losses.

128. Operation and maintenance. No definite costs on the operation and maintenance are available although estimates have been made. An annual estimate given by the Allis-Chalmers Manufacturing Company is given in Table 8 below.

Table 8

Elk River plant: operation and maintenance costs

Item	Cost in \$
1 Superintendent	10 800
12 Operators	86 400
Sub-total	97 200
Overhead at 20%	19 440
Material	30 000
TOTAL	146 640

The above cost is the equivalent of \$6.7/kw/yr or 1.0 mills/kwh at 80% plant factor, but does not include the cost of an additional staff of about 14 persons (shift-supervisors, health physicist, maintenance personnel, etc.) which will increase the operating costs to about 2 mills/kwh.

129. The control rods may have to be replaced after one or two core lives (the initial 13 control rods cost about \$90 000). Thus the replacement of the control rods may contribute 0.1 to 0.2 mills/kwh to the cost of electricity generation.

G. Operating personnel and training

130. The staffing plan for the Elk River reactor is shown in Table 9.

Table 9

Elk River plant: staffing plan<sup>a/</sup>

Category	Number of persons
<b>Administration</b>	
Plant manager	1
Assistant plant manager	1
<b>Operation</b>	
Shift instructors	4
Operators	8
Relief operators	3
Health physicist	1
Health physics technicians	2
<b>Maintenance</b>	
Nuclear instrumentation superintendent	1
Instrumentation technician	1
Mechanical technicians	2
Electrical technicians	2
General	1
TOTAL	27

a/ Maintenance staff for the turbogenerator plant, and the general administration or clerical staff are common to the nuclear plant and the existing steam plant and are therefore not shown in this table. The additional staff involved is four to five persons.

The supervisory staff consists of a plant manager, an assistant plant manager and four shift instructors. The plant manager was formerly associated with EBWR for four years and has his AEC reactor operating license for the Elk River plant. In addition to being responsible for the complete operation and administration of the reactor plant he will also look after the problems of nuclear fuel management. The assistant plant manager, who was previously the head of the steam production department at Elk River, spent nine months at Oak Ridge and attended the reactor operations course.

131. The four shift instructors are trained reactor operators having four to eight years of operating experience. In addition, they have each received six months training with the Elk River plant becoming familiar with its operations manual and system. They have also participated in the engineering tests of the plant and received practical experience in the operation of the system. They have already obtained their AEC operator's licenses for the Elk River reactor.

132. There are eight trained operators and four shift and three relief operators. Their backgrounds are similar in the sense that all of them have been drawn from the operating staff of the existing steam plant. They include turbine operators and firemen. The operators were first given three months' academic training in nuclear engineering oriented towards a boiling-water reactor. The lectures were specially prepared and tests were given at the end. This theoretical work was followed by three months of practical training, under a prescribed program, in the operation and maintenance of the CP-5 reactor. Two weeks were spent on an EBWR simulator to gain further understanding of a boiling water system. Later on, three months were devoted to practical training at the Elk River plant to familiarize the operators with its system and controls. All operators have participated in the pre-operational tests, and will take part in start-up and criticality and initial full power testing of the reactor.

133. In the initial stages, the responsibility for the operation of the reactor will be with the prime contractor, who will give further training to the staff for a period of 60 days.

134. Before RCPA takes over the operation of the plant, USAEC will examine each of the 11 operators and assistant plant manager and award licenses to those who qualify.

135. The instrumentation superintendent has had four years experience with reactors at Hanford. He has undergone nine months special study and training to obtain a thorough understanding of the controls of this reactor. He will be assisted by two instrumentation men, one of which also looks after conventional power units at the site.

136. The health physicist for the reactor is a trained radiological physicist who graduated from the University of Rochester under an AEC fellowship. He received additional training on the CP-5 reactor and attended various courses to become familiar with standards and procedures of reactor health physics and radiochemistry. The person acting as assistant health physicist attended a brief course in health physics and received further training at the site. The health physics technician is receiving on-the-job training. Chemical analysis and water quality control will be carried out by the technician connected with the conventional power units at Elk River.

137. The existence of a conventional steam plant at the same location will be of considerable help. This eliminates the need for hiring extra turbine operators and maintenance men to look after the conventional equipment. Similarly, the clerical work will be performed by existing staff of the steam plant.

#### H. Integration of the reactor into the utility system

138. The Elk River plant is a part of the power system operated by RCPA which has an installed capacity of 70 Mw (excluding that of the nuclear plant). The peak demand of the system was 52 Mw in 1960 with a load factor of 42%. The load is growing at the rate of about  $8\frac{1}{2}\%$  per year.

139. The system is not isolated and is interconnected with four adjoining systems run by other utilities, from which it receives power in case of need. The generating costs are greatly influenced by the very low rate of interest (about 2%) which is available to rural co-operatives in the United States. The fuel costs in the area are 39¢ and 33¢ per million BTU respectively for coal and gas. Interrupted gas supplies are available at even lower rates. The average generating cost in the system is 8.4 mills/kwh and dump power is available from the adjoining systems at 4.5 mills/kwh. The average sale price is 15.2 mills/kwh, which compares favorably with that in the surrounding areas.

140. The addition of the nuclear plant will not increase the generating costs for RCPA, who will simply buy the steam from USAEC at a cost comparable to that of producing the steam from their own existing steam plants. The Elk River reactor will operate at base load and will be used to its full availability.

141. RCPA is very enthusiastic about the nuclear plant and is proud of the fact that it is expected to be the first small utility to use such a plant in its system. It feels that if the experience of doing so is satisfactory, the contemplated addition in the near future of 50 Mw to its capacity might be achieved by the installation of a nuclear power plant.

142. The utility company has attached great significance to an active public relations program to inform the community of the implications of installing a nuclear plant. The people in their turn have generally accepted the plant and are proud of it. After the SL-1 accident, no repercussions were noted in the Elk River area. There appears to be a realization that this plant has been designed with great emphasis on safety and every precaution has been taken to protect the people from any hazards.

I. Selected references

143. A list of selected references concerning the Elk River power reactor is given below:

"Project Highlight Report", covering period August 1958 - August 1961, issued monthly by Allis-Chalmers Manufacturing Company, Milwaukee, Wis.

"Preliminary Hazards Report for the RCPA Elk River Reactor at Elk River, Minnesota", Nuclear Products, ERCO, Division of ACF Industries, Inc., Riverdale, Md. (March 1959).

RCPA - Job descriptions ERR, Rural Cooperative Power Association (June 1960).

"Allis-Chalmers Organization for Design, Preoperational Nuclear Testing of the Elk River Reactor", Allis-Chalmers Manufacturing Company, Milwaukee, Wis. (September 1960).

"Operations Manual, Vol. I: Operating Procedures for the RCPA Elk River Reactor", Allis-Chalmers Manufacturing Company, Milwaukee, Wis. (8 July 1960).

"Operations Manual, Vol. II: Plant Specification for the RCPA Elk River Reactor", Allis-Chalmers Manufacturing Company, Milwaukee, Wis. (8 July 1960).

"Fuel Element Report - Elk River Reactor", Allis-Chalmers Manufacturing Company, Milwaukee, Wis. (September 1960).

"Final Safeguards Report - Elk River Reactor", Allis-Chalmers Manufacturing Company, Milwaukee, Wis. (April 1961).

#### IV. THE PIQUA NUCLEAR POWER FACILITY

##### A. General

144. The 11.4 Mwe Piqua organic-moderated reactor is a part of USAEC's Demonstration Power Program. It is intended to extend the knowledge gained from the design, construction and operation of OMRE on the technical and economic feasibility of this type of plant under actual operating conditions of a utility system. This is the first organic-moderated power reactor to be used commercially, and will serve as a prototype of a medium size nuclear power plant. It is expected to yield very valuable data on all matters concerning such plants.

145. The reactor is located on the east bank of the Miami River and will supply steam to the Piqua Municipal Power Station, on the other side, by overhead pipes bridging the river. The reactor is owned by USAEC, under a contract with whom the City of Piqua has to supply the site and turbogenerator, and will also operate the plant for the first five years and purchase the steam produced by the reactor at a price to be mutually agreed upon. The plant is being built under a fixed price contract and the prime contractor for design and construction is Atomics International. Frank Messer and Co. is the building contractor.

##### B. Important design features

146. A summary of important data concerning the Piqua reactor is set out in Annex II, and a schematic diagram of the reactor system is shown in Figure 2.

147. Objectives. This reactor has been designed to fit into the Piqua municipal system and provide steam to an existing turbine. This consideration established the temperature and pressure conditions of the outlet steam from the reactor at 550<sup>o</sup>F and 435 psig. It is a load-following plant in the range of 20 to 100% of its rated capacity, and is capable of being fully integrated into the small system of which it is a part. In addition, it can supply processed steam to the local industries within a radius of 3 000 ft. The main consideration in the design is to use steam equipment with the minimum possible variation from the conventional type and to employ carbon steel in the primary loop.

148. The Piqua reactor has been developed on the basis of the experience gained with OMRE, which has established the technical feasibility of this type of reactor. Actual construction was preceded by two years of research and development to explore and study some additional problems connected with fuel element control, safety rods, the fuel handling system, and the various organic process systems to pave the way for the design of this reactor. The accumulated experience of the chemical processing and petroleum refining industries, which have employed organic materials as coolants under high temperature and pressure conditions, was used with great advantage. The Piqua reactor represents the next step in the development of organic reactor technology. An experimental organic reactor, the 40 Mwth EOGR, is currently under construction at the Idaho Reactor Testing Station. It is an experimental plant designed to study the behavior of fuel elements and organic coolants under high temperature and flux conditions. A 50 Mwe OMR, which will serve as a prototype for a 300 Mwe nuclear power plant, is under consideration for possible completion by 1964.

149. Interest in this type of reactor system stems from several possible advantages in using organic fluid as moderator and/or coolant in a reactor. Conventional materials and equipment such as carbon steel, pumps and valves can be used, which are cheaper and easier to handle. The reactor is inherently safe and operates at low pressure. The corrosion in the vessel core and piping due to coolant flow is negligible, and there is no danger of any chemical reaction with the cladding or uranium. A negative temperature coefficient shows good stability during load variations and the low level of coolant activity permits easy access to heat transfer components during operation.

150. Among the disadvantages are the chemical decomposition of the organic fluid under radiation, and the substantial cost of make-up (58 lbs/hr at full power for Piqua). The poor heat transfer characteristics of organic fluids necessitate the use of a special type of fuel element to increase the effective heat transfer area. The organic liquids tend to leave a film deposit on the fuel element surfaces, and although this in itself does not pose any problem, if a thick deposit is formed by particulates it interferes with heat transfer and steps have to be taken to prevent it.

151. Core. The reactor core is 4.8 ft. in diameter and 4.5 ft. long and consists of 85 aluminum-clad fuel elements and 13 control rods and 2 neutron sources. It is located at the bottom of the core tank and is surrounded by an annular thermal shield. Steel grid plates located above and below the core support the fuel elements and control rod. The organic moderator and coolant is an isomeric mixture of terphenyls commercially available as Santowax R. The flow through the core is maintained by forced circulation using two 6 000 gpm pumps. The heat output of the core is 45.5 Mwth. The coolant enters the core from above at 519°F and leaves the core through the bottom plenum at 575°F. Organic fluid fills all the available space in the tank and serves as moderator, coolant, reflector and shielding for the core.

152. Pressure vessel. The reactor vessel is made of low carbon steel and has an internal diameter of 7 ft. 8 in., an overall height of 27 ft. 3 in., and a thickness varying from 1 1/8 in. to 2 1/4 in. It is designed according to ASME specifications for an internal pressure of 300 psia and 750°F. The operating conditions are 120 psia and 575°F. Coolant inlet and outlet nozzles penetrate the vessel near its upper end. Six other nozzles are provided for thermo-couple leads, organic sample lines and control rod cables. The head is bolted to the vessel and sealed by a soft metal gasket. The reactor vessel is located below ground level and is supported on a ledge inside the core cavity liner, which is made of 1 in. thick mild steel. The reactor foundations are built around the cavity liner. In the event of core tank rupture, the cavity liner will serve as a secondary tank to retain the coolant at a level above the top of the reactor core.

153. Reactor heat transfer system. The organic coolant is pumped through the core at a constant rate of  $5.5 \times 10^6$  lbs/hr at all power levels. To vary the reactor output, a part of the coolant is by-passed around the boiler. Two 6 000 gpm pumps are used in parallel, which are made of carbon steel with stainless steel shafts and impellers, and are designed to minimize leakage. The coolant enters the core at 519°F and leaves at 575°F. After leaving the core, it first passes through the superheater and then the boiler. Both boiler and superheater are of the standard shell- and tube-type with double wall tube-sheet construction to facilitate leak detection. The coolant enters the superheater at 575°F and leaves at 571°F, producing 150 000 lbs/hr of steam at 550°F and 435 psia under full load conditions. After leaving the superheater, the coolant goes to the boiler where its temperature drops from 572°F to 519°F, while it generates saturated steam. It is then returned to the core to start the cycle again.

154. Shielding. Radial shielding consists of the coolant, the core tank wall which is 1.5 in. thick, a thermal shield 4 in. thick surrounding the core tank, the reactor vessel wall which is 1 1/8 in. thick, the cavity liner of 1 in. thick steel and 8 ft. of ordinary concrete which serves as the biological shield. Vertical shielding consists of the coolant, the upper grid plate, a 9 in. thick core tank head, and the top shield plug.

155. Radiation level in areas with uncontrolled access is less than .75 mrem/hr (1.5 rem/yr). This is well below the maximum permissible dose of 5 rem/yr recommended by ICRP. After one year of operation, the radiation dose rate at 1 ft. from the main heat transfer piping will be about 115 mrem/hr during full power. Thus, the radiation from plant piping will be low enough to permit limited access to the process area during plant operation. The background radiation in areas where decay tanks containing radioactive wastes are housed is expected to be of the order of 100-500 mr/hr.

156. Containment shell. Originally, the Piqua reactor was to be housed in a conventional type of building without a containment shell. There are, in fact, very good technical reasons why an OMR of this type and design need not require any containment shell at all. As discussed earlier, the reactor is inherently safe and has so many additional protective features that a large release of activity is not a logical possibility. It would appear that the containment shell is superfluous. Nevertheless, it was considered prudent, in view of the limited experience with power reactors at this stage and the proximity of the site to populated areas, that even the remotest possibility of radioactive hazard should be eliminated. It may be pointed out that some subsequent designs of OMR-type reactors do not provide for containment shells. [ 5 ]

157. The containment shell for Piqua is made of 3/8 in. to 1/2 in. thick carbon steel plates welded to form a shell measuring 73 ft. in diameter, 168 ft. in height. It is designed for 5 psig at 125°F, with a maximum leak rate of 0.1% per psig in 24 hours. The fabrication was done according to ASME standards. All joints are double-welded and 10% of the total field welds will be checked by radiography. All pipes and cable penetrations are required to meet rigorous standards and process pipes are provided with expansion bellows on either side. The shell is to be leak-tested twice; soon after erection, and then after the installation of the equipment. Initial proof testing was done at 6.25 psig while the second test will be at the design level of 5 psig. In addition, there will be periodic tests after the plant has been put into operation to check the integrity of all the welds and joints.

158. Fuel handling and storage. To change fuel in the reactor, it is first shut down and depressurized. The vessel head is replaced by a special top-shield and the port-holes in the top-shield and in the vessel's top are lined up; the fuel cask is positioned over the fuel element and is removed by appropriate indexing of the traveling bridge. A grappling and hoisting mechanism is used for lifting the fuel element into the cask, where, if necessary, it is cooled by a forced circulation system using an organic fluid. The carriage carrying the cask is moved over tracks to the water-filled storage pool. The fuel element is then lowered into the pool by opening the lower part of the cask. New fuel stored in the maintenance pit next to the pool is picked up and moved to the reactor in the cask and lowered into the core through the same fuel port.

159. It takes three persons including a health physics technician to carry out refuelling. Operations during fuel changing are planned and the shielding of the fuel transfer cask is designed so that the operator will not receive a dose in excess of 60 mr in an eight-hour shift (assuming eight fuel element changes per shift).

160. The important components of the fuel handling and storage system are the top-shield, fuel handling cask, carriage, spent fuel storage tank, crane, shipping cask, and new fuel storage pit.

161. The special top-shield is made of thick lead and steel laminations and serves the purpose of reducing the radiation level above the reactor, within safe limits for the protection of the operators during operation and refuelling of the reactor. It can be rotated and has a movable fuel removal port which can be positioned over any desired part of the core.

162. The fuel handling cask is made of steel with 10 in. thick lead shielding. It is 2½ ft. in diameter and 10 ft. in height. The grappling and hoisting mechanism for lifting fuel elements is installed on the top. To provide necessary cooling for the irradiated fuel elements during transit, an auxiliary forced circulation cooling system, using an organic

---

[ 5 ] "Small-sized Organic Moderated Reactors (10-40 MWE)", report TID-8511, USAEC, Washington, D. C. (October 1959).

liquid, is attached on the side. This cask is mounted on a carriage which moves on a track between the reactor and the storage area. This cask is also used for handling control rods and the source elements.

163. The spent fuel is stored in a water tight pool, 24 ft. deep. It can house 100 fuel elements in storage racks. An adequate amount of boron or cadmium is placed between the racks to avoid a critical configuration. There is always enough water above the fuel elements to reduce direct radiation at the surface of the pool to less than 0.75 mr/hr.

164. The loaded shipping cask weighs about 30 tons and can accommodate 13 spent fuel elements.

165. The new fuel elements are stored in the fuel storage room located on the operating floor which is above the reactor. During fuel loading the fuel is transferred to the maintenance pit which is adjacent to the spent fuel storage pool. This pit will accommodate about 1/4 of the full core loading.

166. Waste disposal system. In an organic-moderated and cooled reactor, special attention has to be paid to the provision of an adequate and efficient waste disposal system on site which can deal with gaseous, liquid and solid wastes. At Piqua, the arrangements for handling various categories of radioactive wastes are set out in paragraphs 167 to 169 below.

167. The waste gases consist essentially of hydrogen and hydrocarbon gases from the purification and de-gasifier systems. These gases first pass through an organic trap and then over activated charcoal beds where certain compounds are removed. Thereafter, they flow in series through a separator and a condenser so that water vapor may be removed. The gases are constantly monitored. Afterwards, they are held in decay tanks for about 48 hours so that their activity is reduced to a safe level. There are 22 waste-gas decay tanks, each measuring 10 in. in diameter and 15 ft. in height.

168. The industrial aqueous wastes intermittently discharged from the process systems, are collected in a multi-section hold-up tank and monitored for radioactivity. If the activity is below the maximum permissible level, the liquid is discharged into the liquid process waste system which empties into the Miami River. If it is above this level, it is pumped through a de-mineralizer into a hold-up tank and the process is repeated until the activity is reduced to safe level. Before being discharged, the waste is diluted with cooling water and monitored constantly.

169. The high boiler residue which is separated from the purification system is expected to accumulate at the maximum rate of 60 lbs/hr. Provision has been made for storing, if necessary, a six-months' output of this residue. The residue is transferred to the waste disposal system consisting of a partitioned storage tank, a liquid filter, a hydrocarbon burning facility, and a gas filtering system. If required, the high boiler residue is completely burned in a furnace. The flue gas is filtered by a collector separator which removes any particulates. After filtering and dilution, the gases of combustion are released through the stack. The heat generated in burning the residue is used to produce 175 psig steam for station use. If the residue contains any long-lived isotopes, it is disposed of by suitably packing the concentrate and burying it in a remote place.

170. Special auxiliary systems. The use of an organic fluid as the cooling medium introduces several problems in an OMR which are not found in water reactors. Under the effect of intense radiation in the core, the hydrocarbons decompose, leading to the formation of hydrogen and hydrocarbon gases and of high molecular weight compounds called high boilers. These must be removed from the system and this is accomplished by providing de-gasification, pressurizing and purification systems.

171. The de-gasification system is designed to remove gases of decomposition (hydrogen, methane, etc.) to avoid a pressure build-up in the core, and prevent fire hazard. It also removes water vapors introduced on account of minor leaks which can cause corrosion.

De-gasification is accomplished by constantly by-passing a part of the hot coolant and spraying it into a tank maintained under vacuum. Water vapor and gases of decomposition are separated from the coolant and vented to the stack. Coolant vapors are condensed and pumped back to the system by pressurizer pumps. The entire system is designed to limit water concentration to 200 parts per million in the coolant system by removing an average of one gallon/hr of water and 2 cu. ft/hr of gases of decomposition.

172. The pressurization system consisting of two direct current pumps delivers 200 gpm to the reactor vessel from the de-gasification tanks which are maintained at 1-4 psia. Under emergency conditions the pumps circulate organic coolant through the core to remove decay or shut down heat. To avoid the possibility of loss of power the pumps are also connected to the emergency bus-bars fed by batteries. The decay heat is dissipated through a decay heat exchanger and finned air cooler.

173. The coolant purification system continuously removes high boiler residue from the organic fluid and keeps it purified and decontaminated to maintain a 30% high boiler content in the coolant. It also removes impurities from the make-up. A vacuum distillation process is used to carry out this purification. The distillate is returned to the system and the residue is removed to the waste disposal tanks. The make-up is also processed through the system for the removal of impurities before it is added to the main coolant stream.

174. The presence of inorganic crystals in the coolant, which result from corrosion of metallic surfaces may lead to the formation of particulate matter in an organic-cooled reactor. Experiments conducted with Piqua fuel elements at OMRE indicate that particulate growth in the Piqua system will not be significant. Nevertheless, provision has been made for filtering out such formations by using a system which removes particles in sizes down to less than 1 micron. The coolant is by-passed at the rate of 20 gpm. A metered amount of filter aid (body feed) is added to it before it passes through two precoat-type filters operating in parallel. The filters remove the body aid and the particulate material. A guard filter is provided down stream as a back-up. The system is large enough to purify the equivalent of two system volumes a day. The filter cake formed as a result of filtration is removed and the solids separated to be stored in suitable drums for off-site disposal after adequate radioactive decay.

175. Since the organic coolant used for Piqua is a solid at room temperatures, it is necessary to provide some means of keeping it in fluid form under all conditions. This is accomplished by using a steam tracing system consisting of small pipes surrounding the large organic flow pipes. The tracing system is fed by steam at 175 psig that keeps the organic coolant in the pipes at a minimum temperature of 350<sup>o</sup>F at all times.

### C. Safety

176. Safety in design. The OMR concept has many inherent safety characteristics which, when combined with the special design features of the Piqua reactor, give this plant a high degree of safety. The low vapor pressure of the organic coolant at the operating temperatures of the reactor, permits the use of a low pressure primary system. In case of a line rupture, the coolant does not vaporize into the atmosphere because its boiling point at atmospheric pressure is 750<sup>o</sup>F as compared to the maximum operating temperature of 575<sup>o</sup>F. The organic coolant is, chemically speaking, very compatible with the reactor materials and there is no danger of metal-coolant reaction as in the case of water and zirconium. The induced activity in the coolant is small and at full power the entire organic coolant in the reactor contains 31 curies only. The corrosion effect is negligible. The result is that the activity in the primary system is low and external inspection and maintenance can be carried out during operation. The organic coolant also does not react with water and no chemical action will take place between the two in case of a leakage in the steam generator. An OMR has a large negative temperature coefficient of reactivity, which contributes towards its safety and stability under varying loads.

177. In spite of the inherent safety of an OMR, the design of the Piqua reactor provides for additional protective features. Notwithstanding the fact that there is only a remote possibility of the release of fission products, the reactor is provided with a containment shell which eliminates the radioactivity hazard to the population in the surrounding areas.
178. Inside the reactor building, the areas of potential contamination are kept at a slightly negative pressure so that in case of leakage the flow is inward to, rather than outward from, these areas.
179. The reactor is located below ground level, and plant shielding is designed to restrict radiation level in uncontrolled areas to less than .75 mrem/hr. Access to areas with higher radiation intensity is restricted.
180. The reactor is so designed that in case of a rupture in the primary system the core will always remain immersed under several feet of coolant and will not melt. Even if there is a leakage in the reactor vessel, the coolant will not drain away because the outer cavity liner holds the coolant and keeps its level above that of the core.
181. Emergency cooling of the core in case of power failure is provided by battery operated pressurizer pumps which come into operation automatically.
182. To prevent any fire hazard, adequate protective features have been built into the system. The core vessel is surrounded with a cavity liner and the intermediate space is filled with nitrogen. Leaks in the system are kept to a minimum and frequent checks carried out. A fire protection system has been installed, which will automatically release a spray of water if the temperature in the building rises beyond a pre-set value.
183. Control. The reactor is controlled by 13 tubular control rods containing boron carbide. These rods operate inside selected fuel elements. The drive mechanism is of the magnetic jack type so that in case of loss of power the rods automatically fall into the core by gravity. The drives consist of unitized assemblies locked inside the core tank and immersed in the coolant above the core. They are so arranged that they do not interfere with normal refuelling operations. The rods can be moved up and down manually or automatically in small steps. The maximum rate of reactivity insertion is  $0.008\% \frac{\Delta k}{k} / \text{sec}$ .
184. The control system provides for automatic load falling from 20% to 100% of the rated power and manual operation at any power level. The design of the control system emphasizes safety as well as reliability. The circuits are fail-safe and wherever necessary, multiple circuits have been used. Safety interlocks have been put in to prevent operating the reactor under potentially hazardous conditions.
185. The reactor has a negative temperature coefficient over the entire anticipated range of temperatures. Under operating conditions the total temperature coefficient is expected to be  $-7.5 \times 10^3 \% \frac{\Delta k}{k} \text{ per } ^\circ\text{F}$ . The maximum reactivity is available at low temperatures. The reactivity at  $360^\circ\text{F}$  is  $7.90\% \frac{\Delta k}{k}$ . The total worth of the 13 control rods is  $12.2\% \frac{\Delta k}{k}$  which provides a shut-down margin of  $4.3\% \frac{\Delta k}{k}$ .
186. Site. The reactor is located on the southern edge of the City of Piqua (population 20 000) on the eastern bank of the Miami River. The other principal towns in the area are Dayton (population 550 000; 30 miles south), and Columbus (population 620 000; 70 miles east). The reactor building is 120 ft. from the river and 900 ft. from the City of Piqua Municipal Power Station, which is on the opposite side of the river.
187. The principal consideration in selecting the present site was its proximity to the existing power station at Piqua. At first it was intended to build the reactor adjacent to the municipal power plant, but later it was decided to move it across the river and away from the community to provide a large area which could be treated as restricted.

188. The distribution of population in the surrounding area is as follows:

Table 10

Population distribution

Distance in miles	Population density/sq. mile
0.25	80
0.50	450
1.00	4 000
5.00	21 000
10.00	42 000
20.00	108 000

189. The nearest building from the reactor is at 200 ft. and the closest residence at 750 ft.

190. The surface and ground water flow is towards the river. The river flow is controlled by a series of dams upstream and the City of Piqua is well protected. The highest level of the river water at times of maximum discharge will be 9 ft. below the floor level of the reactor building.

191. Geological studies of the site indicate that the load-bearing capacity of the soil is more than adequate for the construction of the reactor and the auxiliary buildings.

192. Seismological studies show that earthquakes of moderate intensities can be expected, although no damage from earthquakes has so far been recorded. The plant has been designed and built in strict conformity with the Uniform Building Code, to ensure that the hazard from any possible earthquake shock is minimized.

193. Analysis of maximum credible accident. Usually, the most serious accident associated with a power reactor is considered to be the complete and sudden loss of coolant which, in turn, leads to complete melt-down of the core. In the case of the Piqua reactor, however, so many protective features have been incorporated that such an accident can be ruled out. The reactor is designed to prevent the core from ever being uncovered as a result of a rupture anywhere in the primary system or the core vessel itself. All inlet and outlet nozzles are at least 13 ft. above the core and a break in them cannot cause the coolant to drain away or the core to get uncovered. The core vessel itself is completely contained by the core cavity liner; if the vessel ruptures, the cavity liner will hold the coolant and the liquid level will remain well above the core. The cooling of the fuel elements is ensured by battery-driven emergency decay-heat removal pumps. Taking all these facts into account, the possibility of a complete core melt-down on account of coolant loss is not conceivable.

194. The only credible accident - which can possibly lead to the melting of some fuel elements - is during start-up, if the control rods are withdrawn from the core in a continuous and uncontrolled movement. For this to happen, either the operator should deliberately withdraw the rods, ignoring all alarm signals, or the control circuits should fail to function and continue to receive power. At the same time, it has to be assumed that all the alarm set-back and scram devices, which normally would lead to a shut-down, will also fail.

195. The minimum shut-down reactivity is  $4.3\% \frac{\Delta k}{k}$  and since the rods cannot add more than  $0.008\% \frac{\Delta k}{k}$ /sec, it will require about 540 seconds before the reactor becomes critical and a significant amount of heat is released. Twenty-seven seconds later, the burn-out flux point will be reached and the film boiling which vapor-locks the channels will start.

The void production in the six center elements introduces a negative reactivity of  $1.8\% \frac{\Delta k}{k}$  and the reactor is shut down. Meanwhile, the decay heat maintains the vapor lock, causing the center elements to melt. If 50% of the six central elements melt, the reactor becomes sub-critical even in the complete absence of control rods. The total energy release is less than 2 750Mw/sec, and is much below the amount needed to vaporize the coolant and bare the core. The coolant temperature will be increased by 100°F, with a small increase in the pressure, but there is no rupture in the coolant system, which remains intact.

196. The total amount of the fission products released by a melt-down of 50% of the six central elements is 7.5% of those contained in the entire core. The fission products thus released would lead to a direct radiation dose rate of 0.1 mrem/hr at the nearest residence immediately after the accident, decreasing to 0.004 mrem after 24 hours. The total integrated dose for a week is 0.1 rem.

197. To make the hazard analysis study complete, the case of a melt-down of the entire core has also been calculated, even though this is not credible. The calculations are based upon the following assumptions:

- (a) That the reactor has operated at the full power of 45.5 Mwth for one year prior to melt-down, and the accident occurs at the time of full power;
- (b) That 10% of the volatile fission products are released into the reactor building;
- (c) That internal pressure build-up is 1 psig, and the leakage rate is 0.2% of the volume per day; and
- (d) That all the leakage is swept by the wind only in one direction.

198. The largest contribution to the whole body dose will be from direct radiation; the table below summarizes the results.

Table 11  
Pigua nuclear power facility: direct radiation from reactor building in case of maximum credible accident

Time after melt-down	Dose rate (r/hr)		Total integrated dose (rem)	
	At control area boundary	One mile from reactor	At control area boundary	One mile from reactor
2 minutes	43	$1.3 \times 10^{-5}$	-	-
24 hours	0.54	negligible	2.2	negligible
1 week	0.14	negligible	4.5	negligible

199. Taking the effect of direct radiation and inhalation doses into account, the maximum whole body radiation dose is less than 25 r for all points outside the control area. It can therefore be concluded that the design of the containment building adequately ensures the safety of the inhabitants in the surrounding areas.

D. Operating personnel and training

200. The staffing plan for the Piqua nuclear power facility is given in Table 12 below.

Table 12

Piqua nuclear power facility: staffing plan

Category	Number of persons
Administration	
Plant superintendent	1
Secretary	1
Operations	
Operations engineer	1
Shift supervisors	4
Chief operators	4
Plant operators	4
Extra operator	1
Health physicist	1
Health physics technician	1
Maintenance	
Maintenance engineer (mechanical)	1
Instrumentation engineer	1
Mechanic/electrician	1
Electronic instrumentation technician	1
Instrumentation repairman	1
Laboratory technician	1
Utility man	1
	25
	TOTAL

It will be seen from the above that there is a staff of 25 persons for the power reactor plant only. The turbogenerator, however, is being manned by the staff which looks after the existing conventional power plants at the site.

201. A distinguishing feature is the fact that the staff has been drawn from among those who have already had long experience in this field of work, as can be seen from the following information:

Average reactor and nuclear plant experience	*	6.8 yrs/man
Average reactor experience only	*	5.7 yrs/man
Maximum reactor experience only	*	7 yrs/man
Minimum reactor experience only	*	3.5 yrs/man

202. The extensive prior experience of the operators, most of which was gained at OMRE, simplified the problem of training.

203. The plant superintendent has spent eight years at Hanford and was at the Canoga Park office of USAEC as the project officer for OMRE and the Piqua facility. The operations engineer has had four years experience with OMRE and two years at Savannah River. The shift supervisors are all experienced having worked at the Hanford, the material test reactor and the Westinghouse installations. Three of the four chief operators already hold licenses.

204. In addition to their original experience the operators have received three months training at Canoga Park in reactor physics, health physics, and electronics theory and application as well as in the study of the specific details of the PNPf system. The actual operation of the model 77 laboratory was included in their program. Later they received training at OMRE in actual operation of an organic system. Since their arrival at the site, about a year ago, a comprehensive and continuous training program has been in effect, based upon information contained in the safeguards report, standard operating procedures, interconnecting system drawings and design data of the plant. This training has been augmented by frequent lectures at the site.

205. The entire reactor staff will be a part of the pre-operational testing and start-up program and initial full power operation. The testing is being organized with a view to training the staff.

206. The health physicist is fully experienced and has worked at the material test reactor for five years. The health physics technician has not been engaged so far but it is hoped that a well trained person might be available.

207. The maintenance and instrumentation engineers had five years experience in their respective fields of work before joining PNPf. The electronics instrumentation technician had worked in conventional stations but not in a nuclear installation. He spent one month at OMRE and went to a training school run by the manufacturer of the instruments.

208. The laboratory technician has had three years experience in general chemical laboratory work.

E. Construction experience

209. The construction of PNPf started in July 1959 and according to the latest schedule the reactor should be critical by November 1961 with full power operation in February 1962. Details concerning the time schedule for the project are given in Table 13.

Table 13

Piqua nuclear power facility: time schedule for the project

Item	Revised schedule	Actual
Start of construction	July 1959	July 1959
Start operator training	May 1959	May 1959
Containment shell erection	May 1960	June 1960
Complete operator training	December 1960	December 1960
Steam generator installation	August 1961	August 1961
Install reactor vessel	April 1961	July 1961
Pumps and process equipment	July 1961	August 1961
Completion of construction	September 1961	
Pre-operational tests	September 1961	
Initial criticality	November 1961	
Full power operation	February 1962	

210. The progress of work on this reactor has been largely according to schedule and no major problem arose during construction. By July 1961 the plant was about 85% complete and roughly three months behind the earlier schedule. The delay was caused mainly by the steel strike which retarded the fabrication and delivery of the pressure vessel by two months.

211. The skills required for building the plant are mainly conventional because of the extensive use of carbon steel in the system. Most of the techniques are those required in the construction of a refinery, excluding the techniques required for building the reactor core. In the case of the reactor plant the welding calls for greater skill and is subjected to a rigorous X-ray examination before acceptance. The piping and layout of the process system needs careful fabrication and installation under expert guidance. It is, however, conceivable that skilled workmen having experience in building a refinery or process plant could, under proper supervision, do most of the construction and installation in an organic reactor of this type.

212. In the case of PNPf certain local factors influenced the construction schedule. Originally the reactor was to be located adjacent to the existing steam plant but later it was decided to build it on the other side of the Miami River. This change in location necessitated an extension of the utilities and the erection of additional piping and structure, which added to the total cost of the plant. The site on which the plant has been built was an old city dump and was therefore not the best for the laying of the foundations. Several piles had to be sunk - a process both time-consuming and expensive.

#### F. Fuel cycle

213. Objectives. The Piqua reactor is to be fueled with 85 aluminum clad slightly enriched uranium metal fuel elements containing 3.5% Mo, and 0.1% Al as a stabilizing material.

214. Development work has been directed toward uranium metal alloyed with from 1.5 to 10% Mo. Additions of ternary alloying materials have also been studied. Prototype fuel elements containing 3.5% Mo and additions of 0.1% Al and 0.5% Si have been irradiated. One element of the plate type has been successfully irradiated for nine months in OMRE (maximum burn-up of 4 000 Mwd/MTU) while a tubular fuel section, approximately the shape of Piqua fuel elements has been irradiated for 17 months. Preliminary evaluations of the tubular element indicates the absence of fouling or dimensional change. Further test specimens of U-10% Mo have shown good stability to 24 000 Mwd/t below 1 050 °F and 8 400 Mwd/t at 1 300 °F. The warranty for average burn-up is 3 000 Mwd/t.

215. Fuel element design. The fuel elements consist of metallic uranium-3.5% Mo containing 1.94%  $U^{235}$  and 0.1% Al. The fuel is clad with 35 mil aluminum which has a finned surface to increase the area of heat transfer. The cladding is metallurgically bonded to the uranium fuel using a barrier of nickel about 1 mil thick.

216. The fuel elements are circular in cross section, 5.22 in. outer diameter and 3.08 in. inside diameter for the main portion, and approximately 80.5 in. in length. The uranium in the element is in the form of two concentric tubes each 0.21 in. thick, and 3.6 and 4.6 in. in mean diameter, respectively. Four sections make up the 34 in. of active fuel length. The fins of the cladding are twisted in a slight spiral along the longitudinal axis. The two concentric fuel tubes are positioned between two 30 mil stainless steel tubes.

217. The ends of the steel tubes are joined to upper and lower and grid plate adapters, and stainless steel wire screens are welded in place at the entrance to the annulus between the tubes and at the bottom cavity in the inner tube. The upper end piece, 5.6 in. inside diameter, fits in the upper grid plate and is designed to facilitate fuel handling and supports the weight of the element. The lower end piece, 4.36 in. inside diameter, guides the element in the lower grid plate. Adjustable flow-regulating orifices are installed at the upper grid plate adapter of all fuel elements except the 13 elements which accommodate the control rods to regulate the flow through the outer regions where the heat generation is less. The orifices will be adjusted during shut-down to equalize the temperature rise.

218. As of May 1961, 46 fuel elements were completed, passed inspection, and were accepted.

219. Fuel management. The initial order was for 100 elements, and recently an additional 20 elements were ordered. The core consists of 85 fuel elements. Future requirements of fuel during the five years in which the Government will operate the plant will depend upon developments, and possibly sintered aluminum fuel may be used.

220. The reactor will operate upon a partial fuel loading cycle. It will be shut down periodically (at four to six months intervals) and the spent fuel will be replaced through the top cover and shield of the vessel by means of a fuel handling cask placed over the port. After replacing a part of the core, a sample of the remaining fuel elements will be inspected.

221. The spent fuel elements are placed in a storage pool which can hold 100 elements. After cooling the spent fuel will be shipped for re-processing in a 30 ton dual purpose cask (specially designed for Elk River and Piqua fuel) which will accommodate 13 Piqua elements.

#### G. Cost data

222. The Piqua reactor is being designed and constructed for USAEC by Atomics International under a fixed price contract. The current cost estimate is \$9.1 million which includes \$1.2 million for the fabrication and development cost of 100 fuel elements. The cost of pre-construction research and development, and operation and testing (excluding reactor designers training costs) are estimated respectively at \$3.5 and \$1.2 million giving a total project cost to the Government of \$13.8 million for the reactor plant, research and development, fuel and operation and training.

223. Construction. As of May 1961 the total cost incurred or committed for design (94% complete) and construction (84% complete) was \$7.76 million (\$1.6 million for engineering and \$6.3 for construction), compared to the authorization of \$7.93 million.

224. Fuel. The cost of the initial order for fabricating 100 fuel elements is estimated at \$1.2 million which will include withdrawal charges for source and special nuclear materials, escalation charges, and contingencies. This gives a unit cost of about \$147/kg U. However, as mentioned in paragraph 219 above, an additional 20 fuel elements were recently procured the cost being \$102 000 (\$5 100/element) or \$63/kg U which is less than one-half the unit cost of the initial order. At the warranty burn-up level of 3 Mwd/kg U and 25% thermal efficiency this fabrication cost contributes 3.5 mills/kwh to the fuel cost. The total fuel cost for a second Piqua reactor has been estimated to be of the order of 5 mills/kwh for an exposure of 3 Mwd/kg U. The fuel cost would be drastically reduced if high burn-ups are achieved as has been indicated by irradiation of test specimens of U-10% Mo.

225. Operation and maintenance and organic make-up costs. Estimates of 2 to 5 mills/kwh have been made for operation and maintenance including the cost of organic make-up. Data concerning the estimated operation and maintenance costs based upon a preliminary analysis by the City of Piqua are given in Table 14 below.

Table 14

Piqua nuclear power facility: operation and maintenance cost estimates

Item	\$/yr	\$/kw-yr	Mills/kwh (at 80% load factor)
General supplies, materials and services (excluding electricity and organic make-up)	17 000	1.5	0.2
Maintenance Tools, test equipment, spare parts, etc.	49 000	4.3	0.6
Health physics and safety Environmental survey, clothing, badge renewal and safety equipment	50 000	4.4	0.6
Analytical laboratory	9 000	0.8	0.1
Salaries	276 000	24	3.4
TOTAL	401 000	35	5

226. The estimated requirements for organic make-up vary from 30 to 60 lbs./hr. At 15/lb. this would be equivalent to about 0.4 to 0.8 mills/kwh for organic make-up.

227. Currently the environmental survey and control is being conducted by an outside concern for \$10 000 per year.

H. Integration of the reactor into the utility system

228. The Piqua reactor is expected initially to operate on base load, and would be utilized as a load following plant only after a demonstrated period of uninterrupted and assured operation. Under the contract with the reactor manufacturer there is a 28 day warranty and a 60 day training period before the reactor is turned over to the utility for operation.

229. The power system of the City of Piqua is an isolated system consisting of a single power station supplying electricity for local use, and steam to about ten industrial users.

230. The present installed capacity is 33 Mw, and a further 20 Mw are expected to be available at the end of 1961 from a plant that is now being installed. Details of the generating capacity are given in Table 15 below.

Table 15

Piqua municipal power plant: generating capacity

Turbine number	Rating: Mw	Absolute minimum operating load: Mw	Minimum efficient operating load: Mw
1	4	1	2
2	4	1	2
3	4	1	2
4	7.5	1.6	3
5	1	0.3 <sup>a/</sup>	0.5 <sup>a/</sup>
6	12.5	1.6	7
7	20	5	10

a/ Exclusive of industrial sales.

231. In 1960 the peak and minimum demands were 291 000 and 76 000 lbs./hr of steam and 22 and 5 Mwe, respectively. The peak average work day demand in general varied from 18 to 20 Mw and the minimum from 6 to 7 Mw. On weekends the peak demand dropped to about 12 Mw. In December the day peak was 23 Mw and the night peak 8 Mw.

232. All reactor steam for the generation of electricity will be fed to turbines 1, 2, or 3 (a total of 12 Mw compared to the output of 12.5 Mw of the Piqua facility) which will accept steam up to 550°F-435 psig. Efficiency losses in turbines 4, 5, or 6 which operate on 750°F-435 psig steam will not permit the mixing of the steam produced by the reactor and that produced by the municipal power plant, except in an emergency. Steam from the reactor will be transmitted to the City of Piqua, across the Miami River, a total distance of 1 200 ft.

233. The addition of the reactor will impose a constant electrical demand of 1.1 Mwe for plant use on the existing system.

234. Although there is no exchange of power with any other system, there is the possibility of selling 0.55 Mw to the Pioneer Rural Co-operative Inc. which serves an adjacent area.

235. Because of possible outage of the reactor, back-up power will be required until such time as it has been clearly demonstrated that the reactor is capable of reliable and sustained operation. There is a possibility of providing back-up power from the Dayton Power and Light Company. However, there are legal and economic considerations which restrict such an inter-connection. Hence, spinning reserve may be required. The turbine can be brought to full power in 30 minutes.

236. Low grade coal is now being delivered by rail to the Piqua municipal power plant at a cost of \$5.21/t (including \$3.39/t for freight), or 22.5¢ per million BTU. Based upon an average consumption for the station of 1.6 lbs. coal per kilowatt-hour of electricity sent out this amounts to 4.2 mills per kilowatt-hour of electricity sent out by the station.

I. Selected references

237. A list of selected references concerning the Piqua nuclear power facility is given below:

"Preliminary Design Description for the Piqua Organic Moderated Reactor Plant, Piqua Ohio", NAA-SR-3300, Atomics International, Canoga Park, Calif. (18 August 1959)

STIENS, R. R., "Dust Collection System for Piqua Residue Handling Prototype", NAA-SR-MEMO-3927, Atomics International, Canoga Park, Calif. (28 May 1959)

"Small-sized Organic Moderated Reactors (10-40 MWE)", report TID-8511, USAEC, Washington, D. C. (October 1959)

WEISNER, E. F., "Engineering Design of Piqua OMR", Nuclear Engineering, v. 5, No. 45, London (February 1960) p. 68-71

BAUMEISTER, E. B. and WILDE, J. D., "Selection of the Piqua OMR Fuel Element", NAA-SR-4239, Atomics International, Canoga Park, Calif. (15 March 1960)

NADLER, H., "Piqua Prototype Handling System", NAA-SR-4361, Atomics International, Canoga Park, Calif. (1 May 1960)

HOWELL, J. D. et al., "OMR (Piqua) Unitized Control-Safety Rod Prototype Tests", NAA-SR-5077, Atomics International, Canoga Park, Calif. (30 June 1960)

GILROY, H. M. and WILSON, J. H., "Piqua OMR Waste Gas Disposal", NAA-SR-4576, Atomics International, Canoga Park, Calif. (15 July 1960)

STIENS, R. R., "Piqua OMR High Boiler Handling", NAA-SR-4791, Atomics International, Canoga Park, Calif. (30 August 1960)

CORPORALES, G. W. and BENSON, P. R., "Operation of the Piqua OMR Degasification System Prototype", NAA-SR-4894, Atomics International, Canoga Park, Calif. (30 August 1960)

WEISNER, E. F., JACOBSON, J. and WHEELLOCK, C. W., "Design of Small Central-Station Organic-Reactor Power Plants", Small and Medium Power Reactors, v. 1, IAEA, Vienna (1961), p. 339

BLEY, W. N. and BURKHARDT, R. W. "Piqua OMR Purification System Development", NAA-SR-5073, Atomics International, Canoga Park, Calif. (1 November 1960)

BINSTOCK, M. H., "Fuel Element Development for Piqua OMR", NAA-SR-5119, Atomics International, Canoga Park, Calif. (30 June 1960)

"Final Safeguards Summary Report for the Piqua Nuclear Power Facility", NAA-SR-5608, Atomics International, Canoga Park, Calif. (February 1961)

BENAROYA, V., and MINER, S., "Process Systems for the Piqua Organic Moderated Reactor", American Institute of Chemical Engineers meeting, New Orleans, La. (26 February - 1 March 1961)

## V. THE BONUS POWER REACTOR

### A. General

238. The BONUS is a boiling-water reactor with integral superheat and a net electric output of 16.3 Mwe. It is now under construction in Puerto Rico as part of USAEC's program of demonstrating the technical and economic feasibility of nuclear superheat. It is located at Punta Higuera, on the westerly tip of Puerto Rico, close to the sea shore. It will form part of the system of the Puerto Rico Water Resources Authority (PRWRA). Under arrangements between PRWRA and USAEC, PRWRA will supply the site, the turbo-generator facilities and perform the design and engineering of the conventional part of the plant. USAEC will furnish the complete reactor and auxiliaries. The prime contractor for the reactor plant is the General Nuclear Engineering Corporation, which will perform the necessary development work, design and start up the reactor and carry out post construction research. The construction contractor is Maxon Construction Company and the reactor components are being procured from various suppliers at a fixed price.

239. The construction of the plant started in the last quarter of 1960 and it is estimated that the entire project will be completed within 30 months, which is a relatively short time for the construction of a nuclear plant involving several new features.

### B. Important design features

240. A summary of important data concerning the BONUS power reactor is set out in Annex III, and a schematic diagram of the reactor system is shown in Figure 3.

241. Objectives. The primary objective of this plant is to demonstrate the use of integral superheat. In this reactor the integral nuclear superheater is located on the periphery and the boiler in the center of the core. It is the first reactor of this particular design and is expected to yield extremely interesting data on the technical and operational aspects of a nuclear superheat reactor, which will provide a basis for extrapolation of certain design features to larger plants. In designing the reactor great importance has been given to safety, as has been explained in paragraphs 259 - 263 below. It is not meant to be a load following plant but a base load unit. In the initial phases, it will feed into the network whatever power it can produce with priority being given to the development of essential research information.

242. The lower power level of 16.3 Mwe was chosen so that the required information on feasibility and operational problems could be obtained at minimum cost. The plant is convertible to a straight boiling reactor in conjunction with a conventional superheater should the performance of the nuclear superheater prove to be less than satisfactory.

243. Core. The reactor is designed to deliver 152 000 lbs/hr of steam at 850 psig and 900°F, producing 50 Mwth and 16.3 Mwe net with a plant efficiency of 32%. Of 50 Mwth heat output, 38.6 Mwth are generated in the central boiler region and 11.4 Mwth in the superheating region.

244. The boiler region is 35.5 in. square and the entire core measures 54 in. across the flats, and the active length is about 55 in. The total area of the core is equivalent to a circle having a diameter of about 56 in. The power density in the central region is 32.9 kw/l, and in the superheating region 11.6 kw/l. Water is circulated through the 64 fuel elements in the boiler section by forced circulation, and the flow to each assembly is regulated by orifices in the inlet plenum. The rate of flow is 7 500 gpm and two pumps are used for reliability and safety instead of only one. The water enters the core at 532°F, producing steam at 540°F, which is separated from the water by gravitation. Before entering the superheater, this 5% moist steam passes through conventional corrugated plate driers which reduce the moisture to below 0.1%. The dry steam at 540°F makes four passes through superheater elements arranged in groups of eight each, and is superheated to 900°F.

245. Exhaust steam from 32 superheater assemblies is collected in 11 separate pipes leading to the outside of the reactor shield and monitoring is carried out for temperature flow and radioactivity.

246. Stability. No practical experience has yet been gained in the dynamics of an integral superheater reactor, although Borax-5 will, in the near future, yield useful data on the subject. The theoretical analysis of the stability of BONUS was undertaken by using a mathematical model similar to EBWR, but modified to include the integral superheater. Important parameters and variables were considered in obtaining a set of transfer functions which were simulated on an analog computer and the frequency response of the open and closed loop system was studied. The results indicate that the BONUS system will be very stable even under adverse conditions not likely to be encountered in actual operation. The linear transience response also indicates a marked degree of stability.

247. Pressure vessel. The pressure vessel is made of 2.75 in. thick carbon steel clad internally with 0.25 in. of stainless steel. Its internal diameter is 7 ft., height 27.5 ft., and weight 57 tons. It is designed to withstand 1 150 psig at 600°F, but will operate at 950 psig and 540°F.

248. Thermal and biological shield. Outside the reactor pressure vessel a steel tank serves as a support for the vessel and as a container for the iron-water thermal shield. In the radial direction, this external thermal shield is followed by a 9 ft. thick biological shield made of ordinary concrete. Special plugs or tanks of lead, concrete and water are used for shielding above and below the pressure vessel. The top shield plug is removable for access to the control rod drive mechanism and to the bolts on the top-head itself.

249. The shield design is based upon the consideration that no person in the controlled area will receive a radiation dose of more than 5 rem/yr under normal conditions, and outside the controlled area of more than 0.5 rem/yr. The components containing radioactive coolant water or steam are located in controlled areas and have limited access during reactor operations. Shortly after reactor shut-down when nitrogen-16 with a half life of 7.35 secs decays, access to the area for routine maintenance is possible.

250. In high activity areas the typical dose rates at various locations due to nitrogen-16 are in rem/hr: pump room 10, condenser hotwell 10, feedwater heater 1, air ejector 90. All these areas are inaccessible during operation. At the main superheated steam outlet pipe, the dose rate is at one meter, without concrete shield, 0.09 rem/hr. In the other areas outside the reactor and component shields, the radiation dose is 2.5 mrem/hr or less to allow a normal 40 hours work week.

251. Containment shell. The containment shell for the BONUS reactor represents a new approach and is different from the usual two building arrangements used in current plants where the reactor is located in a steel dome designed for high pressures and the turbo-generator and control room in a separate conventional building. The design of the BONUS containment shell is based on the consideration that in order to contain a certain amount of vapor and fission products it is just as well or perhaps better to employ a large volume low pressure shell instead of a small volume high pressure one. It can be shown that the amount of steel needed is the same in either case as long as the amount of vapor to be contained is the same.

252. Consequently, the BONUS reactor has only a large shell 167 ft. in diameter and made of 3/8 in. thick steel, which houses the reactor, the turbogenerator, the condenser, the auxiliaries and the storage pit. It is designed for a low pressure of 5 psig as compared to 16 psig for EBWR, 29.5 psig for the Dresden plant, 75 psig for VBWR and 52.8 psig for the Shippingport reactor.

253. According to the reactor designer some of the disadvantages of the two building arrangement with a small high pressure containment shell for the reactor are:

- (a) The erection of the equipment is difficult because of the relative lack of space in the shell;
- (b) The time required for construction is longer because the shell has to be put up first before internal concrete work can be started and the equipment can be erected;
- (c) Numerous penetrations in the high pressure shell for pipes and cables necessitate special non-leakage seals involving extra cost and maintenance;
- (d) Some of the equipment in the reactor shell and the turbogenerator building has to be duplicated. For instance, one separate crane is needed in each building, which adds to the plant costs;
- (e) Longer steam and feed water lines are needed from the reactor to the turbogenerator building, and they have to be provided with duplicate valves and auxiliary controls;
- (f) During air leak tests, the high pressure shell requires special provision for protecting the equipment;
- (g) The provision of emergency shut-down cooling becomes difficult. If the water storage tank is outside, it has to be able to withstand the same high pressure as the shell to be able to inject water under gravity into the core;
- (h) For shells above 15 psig, ASME codes apply which require X-raying of all joints in addition to leak tests. This imposes a high economic penalty; and
- (i) In the event of an accident leading to pressurization, the probability of harm to the personnel is greater in a high pressure building than in a low pressure one.

254. The disadvantage of the large low pressure shell is that it requires more steel surface area, and a greater amount of work in excavation, foundation, welding, radiographing, insulation, etc. But if the extra space is used for housing the turbogenerator, the condenser and other essential equipment, as has been done in the case of BONUS, then the additional expenditure may be justified.

255. The building is designed for 5 psig and 150°F, and a leakage rate of 0.25% of volume/day. The temperature and pressure expected in case of maximum credible accident are however less than this rating. Because of the elimination of a large number of penetrations, the less onerous code requirements for low pressure buildings, the use of a single handling crane and the shortening of water and steam lines and cables, it is expected that an over-all lowering in construction costs will be effected. Moreover, the low pressure shell provides greater insurance than the high pressure one against the leakage of objectionable amounts of radioactivity into the atmosphere, and greater safety for the population in the surrounding area.

256. Fuel handling. The fuel handling system is similar to that used for EBWR. A properly mounted shield cask of lead is used which is capable of being moved on rails between the reactor and the adjacent storage pool for spent fuel. The reactor is shut down and the shield plug is removed together with the vessel core and rod drives. After centering the index plug of the shield over the irradiated fuel element in the core or superheater, it is lifted by a grappling device into the cask and there discharged in the storage pool filled with water, where it is allowed to cool off. For shipment to a processing plant, the fuel elements are loaded into special casks while submerged under water.

257. Waste disposal system. The radiolytic and radioactive gas disposal system disposes of non-condensable gases removed from the main condenser by the steam jet ejector. Normally, these gases are nitrogen-16 and argon-41, and can be released through the stack after an interval of two minutes. To deal with fuel or element failures and consequent release of fission products, a vapor sphere of 1 300 ft.<sup>3</sup> is provided to permit complete collection of all exhaust for 30 minutes, during which the reactor can be properly shut down.

The disposal of the upper gases is done either by dilution and release with the atmosphere, or by passing it through a charcoal bed which retains active gases.

258. To hold liquid wastes, two 3 000 gallon retention tanks and one 1 000 gallon ion-exchange neutralizer are provided. Since very little activity is expected in this water, only minimum waste-processing facilities are planned initially for BONUS. Arrangements are being made for concentrating the water so that it can be stored in drums as solid waste, for eventual disposal through burial in a pit.

### C. Safety

259. Safety in design. As stated earlier, the primary emphasis in the design of BONUS is on safety. To all the inherent safety features of a boiling water reactor have been added the advantages of a UO<sub>2</sub> fuel and several automatic built-in safety devices have been incorporated to prevent or terminate any potential hazard. The use of an integral superheater introduces, however, new problems of safety, such as:

- (a) The change in reactivity owing to the expulsion from, or addition of, water to the steam coolant gaps of the superheater fuel elements; and
- (b) The cooling of superheater fuel elements in case of loss of steam flow and the prevention of excessively high cladding temperatures.

260. The superheater fuel region is so designed that there is very little change in reactivity because of expulsion or addition of water at operating temperatures. For instance, if all the water is expelled from the superheater when operating at 525°F and low power, the net change in reactivity is almost zero. At full power, sudden flooding of this region would add only 0.2%  $\frac{\Delta k}{k}$  in reactivity. During start-up, the rapid expulsion of the cold (60°F) moderator from the superheater could cause a 0.9%  $\frac{\Delta k}{k}$  change in reactivity. To safeguard against this, an interlock system has been provided to prevent nuclear start-up unless the temperature of the water moderator is 500°F. An electrical preheater is provided to heat the water to 525°F before start-up.

261. To meet the hazards from the loss of steam coolant in the superheater region, the cooling system has been so designed that there is always sufficient cooling through the superheater assemblies to prevent excessive temperatures. If the steam flow is stopped two minutes after a scram, no damage is done to the fuel elements. Should this arrangement also fail, then the fuel assemblies are designed to be able to dissipate their heat by radiation without any melting of the cladding.

262. Normally, the steam from 11 superheater pipes from various segments of the core is continuously monitored and if the temperature in any one exceeds 950°F or there are other indications of a restriction of steam flow in the superheater, an immediate scram takes place and adequate cooling for air fuel is provided in a shut-down condition.

263. Besides the special safety features for the superheater, many other safeguards similar to those for other boiling-water reactors have been provided. Some of these are summarized below:

- (a) The boiling zone of this reactor will automatically limit the power level of the reactor. Owing to the negative reactivity effect, additional steam voids are formed as the power level increases;
- (b) To shut down the reactor, two independent systems are provided. The primary system has 17 control safety rods which fall within two seconds at any indication of trouble. The back-up system to be initiated by the operator can shut down the reactor by slow injection of boron solution;
- (c) An emergency shut-down cooling system has been incorporated, which is independent of all power sources and comes into action when the normal cooling system fails;

- (d) All safety devices and controls are designed to prevent malfunction or to cause a scram in case of a malfunction;
- (e) An emergency water spray system provides sufficient cooling to prevent melting of the fuel elements and consequent release of fission products, even in case of complete drainage of coolant from the reactor vessel;
- (f) A building spray system has been incorporated to reduce pressure and temperature resulting from the release of all reactor water; and
- (g) Because of the location of the reactor in a hurricane area, the containment shell is designed to withstand winds up to 155 mph.

264. Control. The BONUS reactor is controlled by 17 two per cent boron stainless steel rods. The nine control rods located in the boiling region are 1/8 in. thick cruciforms with a 7 in. span. The rods located between the boiling and superheating regions (there are no control rods in the superheater as such) are 1/4 in. thick slabs, 12 in. wide. Drives for the rods are of the rock and pinion type and are mounted above the elliptical cover of the pressure vessel.

265. With enrichments of 1.85% in the boiler and 3.5% in the superheater region, the initial excess reactivity under cold clean conditions is  $16.6\% \frac{\Delta k}{k}$ . At full-power operation and with equilibrium xenon and samarium, the initial excess reactivity is  $6.7\% \frac{\Delta k}{k}$ . The 17 control rods have a combined strength of  $19\% \frac{\Delta k}{k}$  when the reactor is cold. This provides a shut-down margin of  $2.4\% \frac{\Delta k}{k}$  under cold clean conditions.

266. The initial excess reactivity of  $6.7\% \frac{\Delta k}{k}$  is considered sufficient to achieve a burn-up of 6 500 Mwd/t. By replacing four central assemblies of natural uranium by enriched ones, enough additional reactivity will be gained to reach 10 000 Mwd/t. There will be an inward shifting of the outer fuel elements which will also help in flux flattening.

267. Site. Based upon visual inspections, core drillings, topographical maps, meteorological and seismological data, the distribution of population, the availability of cooling water, etc., the site was found to meet all the essential requirements for the safe location of a nuclear power plant. The fact that the wind almost always blows towards the sea makes this site more suitable from the standpoint of minimizing potential radioactivity hazard. The plant is designed to withstand hurricanes with speeds up to 150 mph, as well as earthquakes.

268. The average elevation of the site is 175 ft. above sea-level and the surface and underground run-off is towards the sea.

269. The nearest community, about 2 miles distant, has a population of 1 065, and the nearest city, 13 miles away, of 59 000. The distribution of population at various distances is shown in Table 16 below.

Table 16

Population distribution

Distance in miles	Population density/sq. mile
0.25 (exclusion area)	40
0.50	470
0.75	830
1.00	1 160

270. Analysis of maximum credible accident. The worst reactor accident which can logically be postulated for the BONUS reactor is the sudden and complete rupture of the 16 in. inlet pipe at the bottom of the pressure vessel. This drains out all the water in the reactor vessel in four seconds. A detailed analysis of this accident and consequences thereof is given in the preliminary hazards summary report and is based upon very pessimistic assumptions, including the following:

- (a) That prior to the accident the reactor has operated at full power for a year with consequent accumulation of fission products in the fuel; and
- (b) That all the fuel elements melt, releasing 100% of the volatile, and 30% of the non-volatile fission products.

271. Immediately after the hypothetical rupture, steam is released into the dome; the building spraying system, which does not depend upon any power source, comes into operation. The cooling effect of the spraying water reduces the pressure by a factor of two in the first half hour. This water also dissolves 99% of iodine in the fission product cloud. The leakage rate decreases from 0.25% of volume per day to 0.177% of the volume per day in the first half hour, and remains unchanged thereafter.

272. Assuming that extremely adverse meteorological conditions exist at the time of the release of fission products from the dome, the calculated dose rates at various distances from the shell will be as shown in Table 17 below.

Table 17

BONUS power reactor: eight-hour integrated dose (rep)  
(For average lapse condition)<sup>a/</sup>

Distance in meters	Thyroid	Beta	Gamma	Population	Average population subjected to radiation hazard
300	5.12	0.144	0.045	-	-
402.5	3.29	0.085	0.030	40	2
805	1.17	0.025	0.011	470	12
1 210	0.64	0.013	0.007	830	20
1 610	0.55	0.008	0.004	1 160	25

<sup>a/</sup> This is considered to be the worst expected condition.

273. For the purpose of reference, the maximum permissible exposure levels which have generally been accepted by a number of medical experts[ 6 ] are 25 rem for whole body, bone, lung, etc., and 1 500 rem for the thyroid.

274. Comparing these permissible levels with the radiation doses shown in the above table, it has been concluded in the hazards evaluation report that in the event of the maximum credible accident, the amount of radioactivity released will not constitute an extreme radiation hazard for the population in the surrounding area.

[ 6 ] BRITTAN, R. O., "Reactor Containment (including a technical progress review)", ANL-5948, Argonne National Laboratory, Lermont, Ill. (May 1959).

D. Operating personnel and training

275. The provisional staffing plan is set out in Table 18 below.

Table 18

BONUS power reactor: staffing plan

Category	Number of persons
Administration	
Plant superintendent	1
Assistant plant superintendent	1
Clerks	2
Operation	
Shift supervisors	5
Control room operators	10
Auxiliary operators	5
Relief operator	1
Health physicist	1
Chemist or technician	1
Janitors	2
Maintenance	9
	<hr/>
TOTAL	38

276. At the present time, five persons are attending the ORSORT course for reactor operations and supervision, which will last for one year. The shift supervisors will receive an additional six months' training on a boiling-water reactor.

277. The existing research reactor at Puerto Rico is being used for the training of operators who have had previous experience of steam plants in the PRWRA system.

278. The total budget for the training of personnel is \$300 000.

E. Construction experience

279. Actual construction of the plant started in August 1960 and the target date for full power operation is February 1963. This total period of 30 months is relatively short for the construction of a nuclear plant which incorporates several new features. The progress up to date indicates that construction is ahead of the proposed schedule set out in Table 19 below which, it is expected, will be met.

Table 19

BONUS power reactor: time schedule for the project

Item	Proposed
Start of construction	August 1960
Start of personnel training	August 1960
Erection of containment shell	June 1961
Pressure vessel installation	October 1961
Turbogenerator and steam equipment	August 1962
Completion of training	September 1962
Construction complete	November 1962
Cold testing	September 1962
Initial criticality	December 1962
Full power operation	February 1963

280. An interesting feature of this plant is that it is being built in an area which is not highly industrialized and experience gained in its construction may have some useful parallels with developing countries. The local contractors in Puerto Rico are actively participating in different phases of construction and providing skilled labor for welding, electrical and piping work. It is hoped that the details of the participation of local industry in this project will be available in the near future.

F. Fuel cycle

281. Objectives. One of the objectives is to verify that superheater fuel elements having thin-walled cladding can operate with high integrity in a high temperature steam environment over a long period and thus achieve acceptable fuel cycle costs. The amount of burn-up which can be achieved and the degree of long-term contamination of the turbine owing to transport of stainless corrosion products, of water impurities, and of fission products from fuel element failure will be determined by actual operation of the station. The cost will increase substantially if it is found necessary to replace the superheater fuel before it reaches its design value.

282. Fuel element design. Of the 64 water cooled boiler fuel assemblies, in an 8 by 8 array, 60 contain zircaloy clad  $\text{UO}_2$  enriched to 1.85%  $\text{U}^{235}$  and the four central ones contain natural  $\text{UO}_2$  (total loading of 2 546 kgU). The 32 steam cooled superheater fuel assemblies which surround the boiler assemblies contain stainless steel clad  $\text{UO}_2$  enriched to 3.5%  $\text{U}^{235}$  (total loading of 1 627 kgU).

283. Each boiler fuel assembly contains 32 fuel rods, 0.450 in. inside diameter and 0.500 in. outer diameter, containing  $\text{UO}_2$  pellets 0.445 in. in diameter. The fuel rods are segmented, having lengths equal to one-half of the active core length of 54 in. and fastened at their ends to zircaloy grid plates. Two such sub-assemblies are then placed end-to-end in a zircaloy box, 0.086 in. thick and 3.929 in. square, to form a complete fuel assembly. The two grids at the center of each assembly and the grids at the end are welded to the zircaloy box. Guide pins in the ends of individual fuel rods, mounted with springs, pass through holes in the top and bottom grid plates but are not fastened to the grids so as to allow individual thermal expansion.

284. The zircaloy fuel assembly is riveted to stainless steel end fittings to permit accurate positioning in the core-support plate at the bottom and the egg-crate superstructure at the top.

285. Each superheater fuel assembly consists of 32 stainless steel rods 0.506 in. outer diameter and 0.542 in. inside diameter containing  $UO_2$  pellets, 0.500 in. in diameter. Each fuel rod is surrounded by a thin stainless steel coolant tube which defines an annular path for the steam flow in cooling the fuel. Surrounding the coolant tube is an 18 mil pressure tube which isolates the superheater fuel from the water surrounding each element, and provides a static steam insulating gap with respect to the coolant tube. This prevents excessive loss from the superheated steam to the water.

286. Fuel management. Burn-ups of 11 000 Mwd/MTU are expected to be achieved for both the boiler and the superheater fuel elements. The superheater elements will be rotated  $180^\circ$  to gain reactivity and achieve uniform burn-up. These burn-ups correspond to fuel residence times of 2.6 and 4.7 years for the boiler and superheater fuel, respectively.

#### G. Cost data

287. The only data received are estimates presented in the preliminary design study made in January 1960; they are set out below:

##### (a) Construction

The construction cost estimates are as follows:

Table 20

BONUS power reactor: construction cost estimates

(In thousands of dollars)

Item	Cost
Land and land rights	-
Structures and improvements	1 611
Reactor plant equipment	2 928
Turbogenerator unit	1 540
Accessory electrical equipment	745
Miscellaneous power plant equipment	70
	Sub-total
	6 894
Escalation (7% of the sub-total)	483
	Sub-total
	7 377
Contingency (15% of the sub-total)	1 106
	Sub-total
	8 483
Indirect construction costs (15% of the sub-total)	1 272
Interest during construction	(not included)
	Sub-total
	9 755
Start-up supervision	50
Engineering and design	1 345
	TOTAL (plant cost)
	11 150
	TOTAL (plant cost in \$/net kwe)
	684

It is expected that it will take 35 months to design, build and bring the plant to full power operation.

(b) Fuel

The estimated fuel cost is as follows:

Table 21

BONUS power reactor: estimated fuel cost

(In dollars per kgU)

Item	Boiler	Superheater
Cost of U <sup>235</sup> consumed	134.90	194.40
Value of plutonium produced	56.76	36.60
Net burn-up cost	78.14	157.80
Chemical processing cost	44.00	55.00
Chemical processing loss U <sup>235</sup> , 1%	0.63	2.61
Chemical processing loss plutonium, 1%	0.57	0.37
Conversion plutonium to metal	7.02	4.53
Fuel fabrication cost	140.00	125.00
Conversion salt to UF <sub>6</sub>	5.60	5.60
Interest of fabrication capital, 6%	13.02	19.49
Use charge on new fuel in shipping	0.66	1.52
Use charge on new fuel in storage	1.32	3.04
Use charge on fuel in reactor	13.56	67.27
Use charge on irradiated fuel	5.22	27.00
Shipping new fuel to site	2.00	2.00
<b>TOTAL (\$/kgU)</b>	<b>311.74</b>	<b>471.23</b>

The loadings for the boiler and superheater fuel are 25 646 and 1 627 kilograms respectively, hence the effective average fuel cost is \$352/kgU. Based upon the generation of  $8.6 \times 10^4$  kwh/kgU, the fuel cost is 4.1 mills/kwh.

(c) Operation and maintenance

The estimated cost of operation and maintenance is \$338 400/yr or \$21/kw/yr. For an 80% plant factor this is equivalent to 3 mills/kwh.

H. Selected references

288. A list of selected references concerning the BONUS reactor is given below:

Nuclear Superheat Development Program, First Quarterly Progress Report, July-September 1959, GNEC-118, General Nuclear Engineering Corp., Dunedin, Fla.

Nuclear Superheat Development Program, Second Quarterly Progress Report, October-December 1959, GNEC-125, General Nuclear Engineering Corp., Dunedin, Fla.

Boiling Nuclear Superheater (BONUS) Power Station. Preliminary Design Study and Hazards Summary Report, PRWRA-GNEC-3, Puerto Rico Water Resources Authority, San Juan, and General Nuclear Engineering Corp., Dunedin, Fla. (June 1960).

Nuclear Superheat Development Program, Third Quarterly Progress Report, January-March 1960, GNEC-131, General Nuclear Engineering Corp., Dunedin, Fla. (September 1960).

Nuclear Superheat Development Program, Fourth Quarterly Progress Report, April-June 1960, GNEC-138, General Nuclear Engineering Corp., Dunedin, Fla. (November 1960).

Nuclear Superheat Development Program, Fifth Quarterly Progress Report, July-September 1960, GNEC-149, General Nuclear Engineering Corp., Dunedin, Fla. (November 1960).

WEST, J. M., BEVILACQUA, F. and JAMESON, A. S., "'BONUS' - A Small Boiling Nuclear Superheater Power Plant", Small and Medium Power Reactors, v. 1, IAEA, Vienna (1961), p. 195.

KNAPP, R. W., CEND Critical Facilities Safeguards Report, BONUS Critical Experiment, CEND-110, Combustion Engineering, Inc., Windsor, Conn. (29 October 1960).

Nuclear Superheat Development Program, Sixth Quarterly Progress Report, October-December 1960, GNEC-159, General Nuclear Engineering Corp., Dunedin, Fla.

Boiling Nuclear Superheater (BONUS) Power Station. Preliminary Hazards Summary Report, PRWRA-GNEC-2, Puerto Rico Water Resources Authority, San Juan, and General Nuclear Engineering Corp., Dunedin, Fla. (21 December 1959).

## VI. THE PATHFINDER POWER REACTOR

### A. General

289. The Pathfinder is an integral nuclear superheat controlled re-circulation boiling-water reactor with a net output of 62 Mwe. It is intended to demonstrate the technical and economic feasibility of integral superheat in a full scale power plant operating in a network. The reactor is privately owned but supported by a substantial research and development grant by USAEC and thus forms part of the program of USAEC for the development of superheat reactors.

290. The plant is situated on a site, 1300 acres in area, on the south bank of Big Sioux River, 3.5 miles north east of Sioux Falls, South Dakota. It will be owned and operated by Northern States Power Company (NSPC). USAEC has allocated \$8.3 million towards the research and development program and will obtain all the technical and economic information gained from this project. It will also waive the fuel charge to the extent of \$2 million.

291. According to NSPC it is proceeding with this project for three basic reasons, namely:

- (a) To learn through direct experience how to operate a nuclear power plant;
- (b) To obtain realistic cost data; and
- (c) To ensure a continuing supply of fuel at the proper time when coal oil and gas become scarce and expensive.

292. A group of utilities in the area, called Central Utilities Atomic Power Associates, with a membership of eleven companies, is contributing \$3.7 million towards research and development with a view to sharing the know-how developed through this project.

293. The principal sub-contractor to NSPC for the project is the Allis-Chalmers Manufacturing Company. This company will carry out the necessary research and development at a cost of \$8.3 million. It will also design, build and initially operate the plant, on the basis of a fixed price contract of \$20 million. The contract was signed in November 1957; the research and development work was initiated in August 1957, and actual construction started in October 1959. The construction schedule is given in Table 22 below from which it will be seen that full power operation is scheduled for October 1962.

Table 22

Pathfinder power reactor: construction schedule

Items	Actual schedule and anticipation targets
<b>Construction</b>	
Start of construction	October 1959
Containment shell	August 1960
Reactor building	August 1961
Turbine building	January 1961
Water treatment	November 1960
Fuel handling	March 1961
<b>Installation of equipment</b>	
Reactor pressure vessel	August 1961
Re-circulation pumps	August 1961
Reactor building equipment	December 1961
Turbine building equipment	December 1961
Fuel handling and water treatment equipment	December 1961
Fuel delivery	May 1962
<b>Training and testing</b>	
Off-site operator training	August 1961
On-site	July 1962
Pre-operational tests	May 1962
Initial criticality	June 1962
Full power operation	December 1962

**B. Important design features**

294. A summary of important data concerning the reactor is set out in Annex IV, and a schematic diagram of the reactor system is shown in Figure 4.

295. Objectives. The primary purpose of this plant is to demonstrate the feasibility and economics of integral nuclear superheat in a central power station. It is the first full scale superheat power reactor. It has been preceded by an extensive research and development program and will also benefit from the experience with Borax-5 experimental superheat reactor which will precede it by six months.

296. The plant has several distinguishing features which may be summarized as below:

- (a) The reactor has a central superheating region as distinct from the BONUS where the steam is superheated in the peripheral part of the core. Present research indicates that the central location of the superheater is more suitable for large plants and helps in flux flattening;
- (b) It has a high power density in the core with 46 kw/l in the boiler and 50 kw/l in the superheater region;
- (c) It is a high volume forced circulation reactor with a flow of 60 000 gpm and uses specially developed low leakage pumps;
- (d) The controlled re-circulation of water can be used to regulate power level between 75 - 100% of full power;

- (e) It employs non-uniform axial fuel loading in the boiler with a lesser amount of fuel being used towards the top, which results in more uniform power distribution and increases reactor stability;
- (f) Internal steam separation is attained by using 45 centrifugal type steam separator located around the core; and
- (g) The vessel head is bolted by using tension bolts and can be removed under water in a very short time.

297. Core. The core is 6 ft in diameter and 6 ft in height. The central superheater region has a diameter of 32 in. The boiler section has 96 fuel elements of low enrichment (2.2 to 3.2%) and 16 cruciform type boron control rods. The superheater has 415 highly enriched fuel elements and four control rods. The power density in the boiler is 46 kw/1 and in the superheater 50 kw/1. The 99.9% dry steam enters the superheater at 489<sup>o</sup>F and leaves at 825<sup>o</sup>F. The turbine throttle conditions are 825<sup>o</sup>F and 540 psig. In the initial stages the steam temperature will be kept at 750<sup>o</sup>F.

298. Stability. A detailed theoretical analysis of the reactor indicates that the system is stable and has good load-following characteristics without divergence. Perturbations do not introduce any phase differences in reactivity and oscillations are damped. Therefore sharing of load between the boiler and superheater regions at varying power levels is not expected to present any stability problems.

299. Pressure vessel. The pressure vessel is 11 ft 6 in. in outer diameter and 36 ft in height. It is made of grade B carbon steel clad with 0.25 in. thick stainless steel.

300. Shielding. The core is shielded in the radial direction by 2.5 ft of water, 0.5 in. thick steel separators, a 3 in. thick pressure vessel, and 10 ft of ordinary concrete which serves as the biological shield. The dose rate around the reactor is 0.1 mrem/hr. The biological shield is air-cooled, having provisions for water cooling if necessary.

301. The dose rate around the turbine is 10-30 mrem/hr. The radiation level at the air ejectors is about 300 mrem/hr. While the reactor is in operation the air ejector and feed water heaters are not accessible.

302. Containment shell. The containment shell is made of 1 3/8 in. carbon steel plates and measures 50 ft in diameter and 120 ft in height. It is designed to withstand 78 psig with a safety factor of 4. The rated leakage is 1% of the volume per day and tests showed that the actual rate was less than 0.2% of the volume per day.

303. Fuel handling. Re-fuelling is done manually under water. The reactor is first shut down and allowed to cool. The vessel top head, which is held by tension bolts, is removed while covered by water in the shield pool. The fuel elements are picked up by using handling tools which securely latch on to the upper end. The fuel elements are then laid horizontally on a cart and moved under water through a horizontal tunnel which leads to the adjoining fuel storage pit. They are then lifted into a vertical position and allowed to cool off under water for 90 days before being stopped for re-processing.

### C. Safety

304. Safety in design. The reactor possesses the basic inherent safety features of a boiling-water reactor and large negative temperature coefficient in the boiler zone owing to the formation of voids in an excursion. Certain special features have also been incorporated to ensure safe operation of the reactor under all conditions and particular attention has been devoted to the performance of the superheater region, as summarized below:

- (a) The flooding of the superheater actually leads to a negative change in reactivity of the order of 0.1%  $\frac{\Delta k}{k}$ . This effect is obtained by balancing changes in leakage and thermal utilization,<sup>k</sup>

- (b) The superheater is coefficientless and shows no significant change due to temperature variations;
- (c) Unflooding of the superheater adds 0.5 to 0.8%  $\frac{\Delta k}{k}$ ; and
- (d) Cooling of the superheater elements is assured under shut-down conditions by adequate steam supply. If the steam supply is cut off three minutes after shut-down the elements will become very hot but do not melt because they can dissipate their heat by radiation and conduction.

305. A boron solution injection system has been incorporated in the reactor to be used in an emergency, and will introduce about 15% negative reactivity to provide a safe shut-down margin under all conditions.

306. Control. In addition to the use of control rods, this reactor uses the regulation of the coolant flow as a means to control the power level of the reactor in the operating range between 75% to 100% of the rated power. The coolant flow rate is regulated by butterfly valves in the pump discharges. Interlocks are provided so that the valves and control rods cannot be operated simultaneously.

307. The boiler region has 16 plate-type cruciform control rods with 10 in. blade span and having 2% boron by weight dispersed in stainless steel. The superheater has four cruciform control rods consisting of a cluster of 13 rods for each control rod assembly. The type of poison material to be used has not been decided.

308. The control rods in the boiler region adjust power in both the boiler and the superheater regions. Relative power adjustments between the boiler and the superheater, necessitated by different fuel burn-ups, are made by the control rods in the superheater. These rods also adjust the final steam temperature.

309. Site. The plant is situated 3.5 miles north east of the city limits of Sioux Falls, South Dakota (population 70 000). According to NSPC, the following considerations were taken into account in selecting this location:

- (a) The fuel costs in the area are rather high (38¢/mBTU for coal) and a nuclear plant will take less time to prove competitive in this area than in others served by NSPC;
- (b) Long-range studies indicate good prospects for load growth and it will be possible to integrate easily a plant of this size into the system;
- (c) There is a good transmission system linking this area with other parts of the system;
- (d) The proximity of an existing steam plant to this site would enable common use of some facilities and labor; and
- (e) The site is readily accessible by rail and road.

310. The plant site is at the base of a sand and granite terrace about three-eighths of a mile from the Big Sioux River down stream from the city. The primary water supply for the plant will come from the river, supplemented by water from wells close by. Since enough water is not available from the river, it is necessary to install cooling towers to dissipate station condenser heat. There are no public water supply systems in the vicinity of the site

311. A detailed meteorological, geological, hydrological and seismological analysis of the site has shown that it is suitable for a nuclear plant.

312. The area immediately surrounding the site is farming country rolling and treeless. The plant is 3.5 miles from the city limits of Sioux Falls and 5.5 miles from its center. The distribution of population in the surrounding area is as follows:

Table 23

Population distribution

Distance in miles	Population density/sq. mile
0.25 (exclusion area)	0
0.50	2
1.00	23
2.00	112
3.00	604
10.00	about 71 000

313. Analysis of maximum credible accident. The final safeguard report is now under preparation and is expected to be completed in the near future. According to the preliminary hazards summary report the maximum credible accident is postulated on the basis of a complete and sudden break of the coolant re-circulation line even though there is no reason to suspect that such an accident will occur. The water and flashing steam from this break is assumed to be released directly into the free volume of the reactor building, after 5 to 10 seconds of the break. The building pressure rises to 77 psig which is below the design value of 78 psig.

314. The loss of coolant will lead to a complete core melt-down and it is assumed that in the worst case 100% of the gaseous, 50% of the volatile and 1% of the solid fission products will be released into the building. The designed leakage rate is 1% of the volume per day. Under the worst meteorological conditions the maximum total integrated doses outside the building and in surrounding areas are not expected to be above the accepted emergency dose rates.

#### D. Fuel cycle

315. Objectives. The fuel of the Pathfinder consists of two types - one for the outer boiler and the other for the inner superheater region. The design requires a proper sharing of power by the two regions as the fuel burns up over the core life; this calls for the development of two very different fuel elements.

316. The initial loading consists of 96 zirconium clad, low enrichment,  $UO_2$  (2.2%  $U^{235}$ ; 6.6 metric tons of uranium) boiler fuel elements, and 415 stainless steel clad, high enrichment, double annular  $UO_2$  (approximately 93%  $U^{235}$ ) superheater elements.

317. The fabrication of a high integrity fuel for the superheater at low costs is particularly important. Research is in progress to develop spherical  $UO_2$  particles and improved methods of dispersing the highly enriched particles in the stainless steel matrix for the preparation of the annular superheater fuel elements. Also under development is a low enrichment, seven rod cluster superheater fuel for the second core loading.

318. Fuel element design. Important design data concerning the boiler fuel and the high and low enrichment superheater fuels are given in paragraphs 319 to 327 below.

##### (a) Boiler fuel

319. The overall length of a fuel assembly is about 99 in. It consists of four fuel sections each 18.25 in. long (16.5 - 17 in. active length of fuel) and stainless steel grid pieces at the top and bottom. The nozzle assembly is welded at one end and a handling fitting at the other.

320. Each fuel section consists of 81 fuel rods, with threaded ends for joining the sections; in a 9 by 9 array. A stainless steel grid screen separates the fuel sections and provides rigidity and the proper spacing between rods. The fuel rod diameter is reduced in the upper two fuel sections from 0.353 to 0.315 in. inside diameter, to accommodate increasing steam-void volume.

321. The fuel rods are prepared by loading zirconium tubes (28 and 26 mills for the lower and upper sections, respectively) with pellets 1.5 in. long and containing 2.2% U<sup>235</sup>. The two end pellets contain 1.8% dysprosium oxide as a buffer to smooth out peaking at the interconnection of the fuel sections.

(b) High enrichment superheater fuel

322. The overall length of the fuel element including end pieces will be 78.25 in. with a 72 in. fuel section. The fuel will consist of double annular cermet elements, 20 mills thick, containing 93% U<sup>235</sup> dispersed in stainless steel and clad with 7.5 mills of stainless steel. The center of the element will have a burnable poison rod with a diameter of approximately 0.5 in. consisting of boron carbide in aluminium oxide. The burnable poison rod will be inserted in a 26 mills stainless steel tube.

323. The annular cermet fuel tubes will be fabricated by rolling the cermet plates and seam-welding to form the tubes. Straight wires will be used for spacers. The assembly of the inner and outer tubes will be performed by slightly deforming the outer tube into a triangle and then inserting the inner tube.

324. The completed fuel element will consist of the center burnable rod encased in a tube surrounded by a 50 mills steam space, the first fuel tube, a second steam space of 75 mills, the second fuel tube, a third steam space of 45 mills, a 15 mills stainless steel process tube, an insulating stagnant steam space of 25 mills, and finally a 26 mills tube.

325. The design of the element has been completed and it has been established that it is feasible to fabricate it. The techniques of fabrication are now being established, and an order is expected to be placed in the last quarter of 1961 for delivery early next year.

(c) Low enrichment superheater fuel

326. A low enrichment UO<sub>2</sub> stainless steel clad, seven-rod cluster fuel is being developed for subsequent core loadings. These elements are designed to fit in the same process tubes as the initial loading. Work is proceeding on the swage compaction of the fuel rods, and methods of assembling them.

327. The goal is the development of a fuel element capable of achieving a burn-up of 10 000 Mwd/t.

328. Fuel management. A contract has been concluded for the procurement of 142 boiler fuel elements: 110 of 2.2% U<sup>235</sup> enrichment and 32 of 3.2% for versatility during start-up and operation. About 90% of the pellets have been fabricated, and 20% of the zirconium tubing is in the process of acceptance. One-third of the boiler fuel is expected to be re-loaded every six months at 80% plant factor. The average expected exposure is 10 000 Mwd/t under equilibrium conditions.

329. A burn-up of 60 atom per cent of U<sup>235</sup> or 1.5 total atom per cent is the basis of the design which gives a fuel life of nine months. The superheater fuel will be subject to considerable research and development and a change will be made from the highly enriched tubular element to the low enrichment, seven rod cluster element after the first core.

E. Cost data

330. The following data were obtained for the reactor project:

	<u>Million \$</u>
(a) Contract with reactor manufacturer	
Reactor plant	19.01
Research and development	3.65
	<hr/>
TOTAL	22.66
(b) USAEC contribution	
Research and development (maximum)	8.5
Waiver of fuel use charge	1.2
	<hr/>
TOTAL	9.7
(c) Excess operating cost during initial period	1.2

331. NSPC is capitalizing the cost of research and development incurred by the reactor manufacturer, or the total of the contract price of 22.66 million, and they have given the unit capital cost as \$450/kwe.

F. Operating personnel and training

332. The provisional staffing plan for the Pathfinder power plant is shown in Table 24 below, from which it will be seen that a total of 50 persons will run and maintain this plant.

Table 24

Pathfinder power plant: tentative staffing plan

Category	Number of persons
<hr/>	
Administration	
Plant superintendent	1
Assistant plant superintendent (L)	1
Clerical staff	3
Operation	
Nuclear engineer (L)	1
Shift supervisors (L)	5
Senior plant equipment operators (L)	5
Plant equipment operators (L)	5
Assistant plant equipment operators	4
Plant attendants	4
Radiation and chemical engineer	1
Radiation safety technicians	3
Maintenance	
Plant-results engineer	1
Test engineers	3
Instrument engineer	1
Instrument technicians	3
Station electrician	1
Chemist	1
Laboratory technicians	2
Machinist	1
Mechanic	1
Repairmen	2
Laborer	1
	<hr/>
TOTAL	50

(L) Indicates licensed reactor operator.

333. Most of the staff has been drawn from the steam plants of NSPC, and has prior experience in conventional plant operation. The plant superintendent has been working for utilities for 32 years including 20 years in the capacity of plant superintendent. He has received five months' training at Shippingport. The assistant plant superintendent has served as a results engineer in steam plants for ten years and has spent a year and a half at Argonne during which he received theoretical and practical experience in the operation of reactors. The nuclear engineer is a graduate in electrical engineering and nuclear physics and has worked for a year in the nuclear laboratory of the reactor designer and manufacturer at Greendale. The plant-results engineer has six years' experience in his field of work; he attended the Shippingport school for six months and spent nine months at Greendale.

334. The radiation and chemical engineer was at Oak Ridge for nine years and has extensive experience in radiation protection techniques and regulations. He will be the health physicist for the plant and train the three radiation safety technicians who will work under him.

335. Each of the five shift supervisors has had ten years of experience or more in the same capacity in a conventional steam plant. They are currently undergoing comprehensive training consisting of a three months' basic course in reactor theory, six months' work at Greendale and six months' reactor operations at the Experimental and at the Material Test Reactors.

336. Each of the five senior plant equipment operators has had five years' plant operating experience and their supplementary training comprises a three months' basic course in reactor theory, five months' practical work at Greendale and four months' reactor operations with CP-5.

337. Each of the five plant equipment operators has three to four years of operating experience. They will attend a three months' basic course in reactor theory and receive additional training at the plant.

338. All the shift supervisors and the senior and assistant plant equipment operators will participate in the criticality tests and critical power runs. They are required to obtain operators' licenses before taking over the plant.

339. The four assistant plant equipment operators and four plant attendants have not so far been selected.

340. The instrumentation engineer has ten years' experience in the plants of NSPC and has spent five months at Savannah River. He will be assisted by three instrument men each having five years' experience in NSPC. They are being trained at the facilities of the instrumentation supplier.

341. The maintenance of the plant will be under the direction of the assistant plant superintendent who may have a junior engineer to help him. The maintenance staff consists of experienced machinists, mechanics and repair men.

G. Selected references

342. A list of selected references concerning the Pathfinder power reactor is given below:

Pathfinder Atomic Power Plant, Safeguards Report, ACNP-5905, Allis-Chalmers Manufacturing Company, Milwaukee, Wis.

Allis-Chalmers Critical Facility, Preliminary Safeguards Report, ACNP-5809, Allis-Chalmers Manufacturing Company, Milwaukee, Wis.

Pathfinder Atomic Power Plant, Technical Progress Report for 1 April - 30 June 1959, ACNP-5915, Allis-Chalmers Manufacturing Company, Milwaukee, Wis. (August 1959)

Boiling Water Reactor with Internal Superheater, Pathfinder Atomic Power Plant, Final Feasibility Report, ACNP-5917, Allis-Chalmers Manufacturing Company, Milwaukee, Wis. (August 1959)

Pathfinder Atomic Power Plant, Technical Progress Report for 1 July - 30 September 1959, ACNP-5924, Allis-Chalmers Manufacturing Company, Milwaukee, Wis. (February 1960)

Pathfinder Atomic Power Plant, Technical Progress Report for 1 October - 31 December 1959, ACNP-6001, Allis-Chalmers Manufacturing Company, Milwaukee, Wis. (March 1960)

Pathfinder Atomic Power Plant, Technical Progress Report for 1 January - 31 March 1960, ACNP-6006, Allis-Chalmers Manufacturing Company, Milwaukee, Wis. (June 1960)

Pathfinder Atomic Power Plant, Technical Progress Report for 1 April - 30 June 1960, ACNP-6007, Allis-Chalmers Manufacturing Company, Milwaukee, Wis. (October 1960)

Pathfinder Atomic Power Plant, Technical Progress Report for 1 July - 30 September 1960, ACNP-6012, Allis-Chalmers Manufacturing Company, Milwaukee, Wis.

Pathfinder Atomic Power Plant, Technical Progress Report for 1 October - 31 December 1960, ACNP-6102, Allis-Chalmers Manufacturing Company, Milwaukee, Wis. (April 1961)

BRAUN, C.R., "Pathfinder and Nuclear Superheat", Conference of Atomic Power Engineering Group, Chicago, Ill. (16 February 1961)

## VII. THE SMALL-SIZE PRESSURIZED WATER POWER REACTOR

A. General

343. The original offer by the United States inviting Agency participation in the Small Power Reactor Projects of USAEC, specifically mentioned the proposed 20 Mwe small-size pressurized water reactor (SSPWR) which it was then planned to build at Jamestown, New York. The project had subsequently to be deferred because of difficulties concerning the site, but the experience gained in its planning and design is very valuable, and some essential features of this project, as well as the difficulties encountered in the selection of the site, are summarized in the paragraphs that follow.

B. Selection of the size and type of reactor

344. In 1959, USAEC decided to undertake a detailed study of the suitability of certain small power reactors for use in a small utility system. The Oak Ridge National Laboratory was assigned the task of analyzing various reactor systems. The objects of this study were:

- (a) To determine the size and type of nuclear plant the immediate construction of which would be possible, considering both the present state of technology and the possibilities of significant improvement in performance; and
- (b) To compare the costs of a small nuclear plant with that of a conventional plant in a high-cost-fuel area.

345. The analysis of the various reactor systems by Oak Ridge Laboratory indicated that only three types, i. e. BWR, PWR and OMR deserved serious consideration in the 5-40 Mwe size range. A detailed study was carried out to examine their technical and economic features, and it was established that, notwithstanding the lower cost of nuclear fuel, it was profitable in all cases to use a conventional superheater in conjunction with small power reactors to permit the use of a standard turbogenerator and achieve high efficiency.

346. Most of the small utilities indicated a preference for a 20 Mwe net size plant. It was also felt that a plant of this size offered better prospects of being competitive than a smaller one and could yield a great deal of useful information without requiring a large investment per kw installed. Consequently, this size was selected for detailed investigations.

347. The results of the cost comparison among the types of plant considered are given in Table 25 below:

Table 25  
Small power reactors: cost comparison

Item	BWR	Type of plant OMR	PWR
Rating, Mwe	23.5	23.5	23.5
Plant cost, \$/kwe	465	480	442
Costs, mills/kwh			
Fixed charges (at 60% load factor and 7%/yr capital charge)	6.2	6.4	5.9
Fuel	5.2	6.0	6.5
Operation and maintenance	2.0	2.5	2.0
Total generating cost	13.4	14.9	14.4

348. From the above comparison it was concluded that the estimated generating costs of the plants under study were very close, the differences being so small as to be well within the margin of uncertainty, and a PWR of 22 Mwe gross and 20 Mwe net output was selected for the project. Perhaps the overriding consideration in making this choice was that no plant of this type, using slightly enriched uranium was being built at the time under USAEC's Demonstration Power Reactor Program and it was felt that its construction would yield very useful information concerning small-size pressurized-water reactors. Moreover, other types of small plants, such as the Elk River BWR and the Piqua OMR, were under construction and there was no great incentive to build a type of plant that would essentially duplicate the experience to be gained from these projects. Further, whereas other plants could offer good reliability, none could match the high degree of assurance of the PWR as a source of continuous supply in a small utility system. It has excellent load-following characteristics, there is a great deal of operating experience with this type, and its technology is well established. There are no problems of radioactive carry-over as in the case of a direct cycle BWR, and it offers the possibility of achieving maximum fuel utilization through higher burn-ups.

349. After selecting the reactor size and type, USAEC invited applications from small publicly-owned utilities to supply the site and the turbogenerator, operate the plant for five years and buy steam from USAEC at a rate comparable with the cost incurred by them for producing from conventional plants in their own systems. As a result of screening a number of applications, the public utility of Jamestown, New York, was selected for the project.

#### C. Important design features

350. A conceptual study of the plant was then carried out, the principal objectives being to build on the basis of accepted technology the most economical power unit possible using equipment commercially available and with emphasis being placed on simplicity of operation and safety.

351. The conceptual study indicates that the plant is intended for base load operation and primary consideration is the production of power. Therefore, it is not designed to accommodate any experimental facility or serve any research and experimental program for the development of advanced reactor technology. It is not an experimental power plant. It is designed for reliable and continuous operation with the minimum of innovations and untried features.

352. To make the plant very safe, provisions are made for rapid injection of water into the core in the event of a loss of coolant accident and a core melt-down is not considered to be a credible accident. A unique feature of the plant is the use of an internal air recirculation system which filters all the air in the containment shell every 11 minutes. An arrangement for water spray is also included to suppress the build-up of pressure and dissolve radioactive iodine, should there be any release of steam containing fission products. The reactor is housed in a containment shell to fully protect the surrounding areas from any possible radioactive hazard.

#### D. Difficulties in the selection of the site

353. The public utility of Jamestown offered a site near its existing conventional thermal station and about half a mile from the center of the town (population 45 000). The necessary supply of cooling water and other conventional requirements were available in the area, which from the point of view of the utility had an added advantage in that it would have enabled it to reduce total expenditure by using for the nuclear plant some of the services provided for the existing station.

354. The conceptual study shows that in designing the reactor due note was taken of the fact that it would be built close to the town and great emphasis appears to have been placed on safety in reactor design and control. After necessary investigations around the site, the preliminary hazards analysis report was prepared and submitted to ACRS which, after careful review of the report felt that it could not approve the site because of its proximity to the populated area. At the same time, two other sites each about three miles from the city were considered acceptable by the committee.

355. Unless ACRS fully approves of a particular site USAEC does not consider it suitable. The utility was, therefore, asked to look into the possibility of using either of the two sites outside the town which were found acceptable by ACRS.

356. The company considered the possibility of shifting the reactor to one of these sites but the duplication of certain sub-station facilities and the provision of an additional transmission line would have added to the total costs. Moreover since the sites were outside the city limits, the utility would have had to pay a substantial amount to the county in taxes for the use of the land. Therefore, on economic grounds, it decided to withdraw its request for the reactor.

357. Another small utility in Wisconsin indicated an interest in the plant. In this case no problems arose over the site but the area served by the utility was provided with a good system of water transport, and the cost of conventional fuel was relatively low. This would have increased the disparity between the nuclear and conventional generating costs. The location of the plant at the Wisconsin site would consequently not have served one of the main objectives in building SSPWR, namely, to demonstrate that it could be possible for a small nuclear power station to be nearly competitive in a high-fuel-cost area.

#### E. Present position

358. The present position is that the project is currently being reconsidered by USAEC in the light of the interest expressed by another small utility in this reactor. It may, however, be necessary to modify the design objectives to suit a new site.

359. Continued interest in the reactor is based upon several considerations. For instance, the plant has been optimized for 20 Mwe and incorporates several attractive features to improve its competitive position in a high-cost-fuel area. It can no doubt yield technical and economic data of value to many countries besides the United States - especially the developing countries which have taken a keen interest in small and medium size plants.

360. The difficulties encountered in siting the reactor also emphasize the fact that the construction of a nuclear power plant close to a populated area may pose problems and in planning the installation of such a plant the problems of siting should not be underrated.

#### F. Selected references

361. A list of selected references concerning the small-size pressurized water power reactor is given below:

Task Force Evaluation Report - Small-sized Nuclear Power Plant Program,  
TID-8508, USAEC, Oak Ridge, Tenn. (October 1959)

Generating Cooperatives and Municipalities, Statistical Survey, TID-8509,  
USAEC, Oak Ridge, Tenn. (June 1959)

Survey of PWR Power Plants, 10 - 30 eMW Size, TID-8513, Alco Products, Inc.,  
Schenectady, N. Y. (October 1959)

Small Size Pressurized Water Reactor Specifications, TID-8525, Gibbs and Hill, Inc. and Internuclear Co. Inc., Clayton, Mo. (November 1959)

Small Size Pressurized Water Reactor Conceptual Design, TID-8526, Gibbs and Hill, Inc. and Internuclear Co. Inc., Clayton, Mo. (April 1960)

COPE, D.F., and LE GASSIE, W.A., "History and Status of United States Small Power-Plant Program and Small Pressurized-Water Reactor Project", Small and Medium Power Reactors, v.1. IAEA, Vienna (1961) p. 269

## VIII. THE EXPERIMENTAL LOW-POWER PROCESS HEAT REACTOR

### A. General

362. ELPHR is a 30 - 40 Mwth experimental low-power process heat reactor of pressurized water type. Its construction at a suitable site is now under consideration as part of the USAEC program to demonstrate the technical and economic feasibility of a low temperature process heat reactor. Construction was actually authorized in 1959 and the estimated costs were above \$4 million. At one time it was proposed to build it on the West Coast for desalinization of sea water by operating it as a steam source for the vacuum-flash evaporation distillation plant of the Department of the Interior. Because of certain administrative difficulties and other considerations connected with the site the proposal could not be carried out.

363. In response to an invitation from USAEC, four paper manufacturing companies in relatively high-cost-fuel areas have expressed an interest in participating in this project. It is envisaged that the selected organization should provide the site and facilities for the use of the steam, operate the entire plant for five years, and purchase the steam produced by the reactor. The reactor design will be based upon existing technology and the plant output will be 30 - 40 Mwth at steam pressures ranging from 15 - 200 psig. The project is scheduled for completion at the end of 1964.

### B. Summary of technical aspects

364. Before selecting the size and type of this plant, an extensive survey was carried out of the requirements of process heat in the United States. The market survey indicated that the average size of a steam plant was about 10 Mwth - which was considered uneconomic for a nuclear reactor. Both on the basis of cost and technical considerations it was decided to optimize the reactor to 40 Mwth with a steam output of about 140 000 lbs/hr to give meaningful data which would be useful for designing future reactors.

365. A comparison of three reactor types showed that in the light of the above considerations a pressurized-water reactor would be the most suitable. OMR was a close second and might even be better for applications requiring a higher steam temperature. BWR would have been favored if the steam could have been used directly from the reactor without having to employ an intermediate steam generator.

366. It has been estimated that nuclear reactors could become competitive with conventional process steam plants within the next ten years in the high-fuel-cost areas of the United States.

367. The design objectives of the ELPHR plant are:

- (a) To construct a reactor on the basis of the current technology;
- (b) To use a primary system of low-alloy steel fuel elements with a cladding of aluminum alloy, and the maximum amount of standard equipment; and
- (c) To design a compact core.

368. It is expected that the operation of this reactor will yield very useful data of interest to processing industries and may lead to the possible use of nuclear power for desalinizing sea water.



ANNEX I

IMPORTANT DESIGN FEATURES OF THE ELK RIVER POWER REACTOR

Location	Elk River, Minnesota
Owner/Operator	USAEC/RCPA
Type	indirect cycle boiling-water reactor, with conventional fuel fired superheater
Power	
Gross thermal	boiler: 58 Mw; superheater: 14 Mw
Electrical	net: 22 Mw
Over-all efficiency	30.5%
Fuel element	
Type	25 rod clusters, SS cladding containing boron as burnable poison
Fuel	4.3% U <sup>235</sup> , 0.3% U <sup>238</sup> , 95.4% Th; in form of dioxides
Core	
Dimensions	5 ft diameter, 5 ft high
Number of fuel elements	148, room for 16 more
Power density	39.6 kw/l
Pressure vessel	7 ft diameter, 25 ft high; carbon steel with SS cladding
Control rods	
Type	cruciform
Number	13
Containment shell	74 ft inside diameter, 115 ft high; steel plates, inside lined with concrete
Turbine steam conditions	
Temperature	825°F
Pressure	620 psig
Mass flow rate	225 000 lb/hr
Construction schedule	
Start of construction	August 1958
Reactor critical	October 1961
Full power operation	February 1962
Costs	approximately \$10 million (excluding \$600 000 for first fuel core and fuel development)



ANNEX II

IMPORTANT DESIGN FEATURES OF THE PIQUA NUCLEAR POWER FACILITY

Location	Piqua, Ohio
Owner/Operator	USAEC/City of Piqua
Type	organic-moderated and cooled reactor
Power	
Gross thermal	boiler: 45.5 Mw
Electrical	gross: 12.5 Mw; net: 11.4 Mw
Over-all efficiency	25.1%
Fuel element	
Type	two concentric tubes in aluminum cladding
Fuel	enrichment: 1.94% metal, alloyed with 3.5% Mo
Core	
Dimensions	4.8 ft diameter and 4.5 ft high
Number of fuel elements	85
Power density	19.4 kw/l
Pressure vessel	7 ft 8 in. inside diameter, 27 ft 3 in. over-all height, low carbon steel
Control rods	
Type	tubular rods with boron carbide
Number	13
Containment shell	73 ft diameter, 168 ft high, steel plates
Turbine steam conditions	
Temperature	550 <sup>o</sup> F
Pressure	435 psia
Mass flow rate	150 000 lb/hr
Construction schedule	
Start of construction	July 1959
Reactor critical	November 1961
Full power operation	December 1961
Costs	\$9.8 million



ANNEX III

IMPORTANT DESIGN FEATURES OF THE BONUS POWER REACTOR

Location	Punta Higuera, Puerto Rico
Owner/Operator	USAEC/PRWRA
Type	boiling-water reactor with internal nuclear superheat
Power	
Gross thermal	boiler: 38.6 Mw; superheater: 11.4 Mw
Electrical	gross: 17.3 Mw; net: 16.3 Mw
Over-all efficiency	32%
Fuel element	
Type	rods
Fuel	UO <sub>2</sub> ; enrichment: boiler - 1.85% and natural superheater - 3.5%
Core	
Dimensions	boiler: 35.6 x 35.6 x 55 in.; superheater: 4 adjacent slabs 8.95 in. thick; height 55 in.
Number of fuel elements	boiler: 64; superheater: 32
Power density	boiler: 32.9 kw/l; superheater: 11.6 kw/l
Pressure vessel	7 ft inside diameter, 27.5 ft over-all height; carbon steel with SS cladding
Control rods	
Type	boiler: cruciform; superheater: plates
Material	boron steel
Number	boiler: 9; superheater: 8
Containment shell	165 ft diameter, 106 ft height; hemispherical steel dome on 24 ft concrete wall
Turbine steam conditions	
Temperature	900 <sup>o</sup> F
Pressure	850 psig
Mass flow rate	152 000 lb/hr
Construction schedule	
Start of construction	August 1960
Reactor critical	December 1962
Full power operation	February 1963
Costs	\$11.15 million










FIGURE 1  
SCHEMATIC FLOW DIAGRAM OF THE ELK RIVER  
POWER REACTOR



FIGURE 2

SCHMATIC FLOW DIAGRAM OF THE PIQUA  
NUCLEAR POWER FACILITY






FIGURE 3

SIMPLIFIED SCHEMATIC DIAGRAM OF THE  
BONUS POWER REACTOR






FIGURE 4

SCHMATIC DIAGRAM OF THE PATHFINDER  
POWER REACTOR

